



---

# Source Water Assessment

A Hydrogeologic Susceptibility and  
Vulnerability Assessment for  
LKSD Kilbuck Elementary  
Drinking Water System,  
Bethel, Alaska

PWSID # 270493.001

April 2004

DRINKING WATER PROTECTION PROGRAM REPORT 1094  
Alaska Department of Environmental Conservation

# Source Water Assessment for LKSD Kilbuck Elementary Drinking Water System Bethel, Alaska

PWSID # 270493.001

DRINKING WATER PROTECTION PROGRAM REPORT 1094

The Drinking Water Protection Program (DWPP) is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (ADEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. It is anticipated this assessment will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of public drinking water source. If you have any additional information that may affect the results of this assessment, please contact the Program Coordinator of DWPP, (907) 269-7521.

## CONTENTS

EXECUTIVE SUMMARY.....	1	INVENTORY OF POTENTIAL AND EXISTING	
PUBLIC DRINKING WATER SYSTEM .....	1	CONTAMINANT SOURCES .....	2
DRINKING WATER PROTECTION AREA .....	2	RANKING OF CONTAMINANT RISKS .....	2
		VULNERABILITY OF DRINKING WATER	
		SYSTEM .....	3

## TABLES

Table 1. Definition of Zones.....	2
Table 2. Susceptibility .....	3
Table 3. Contaminant Risks.....	4
Table 4. Overall Vulnerability.....	4

## APPENDICES

APPENDIX	A. LKSD Kilbuck Elementary Drinking Water Protection Area (Map A)
	B. Contaminant Source Inventory for LKSD Kilbuck Elementary (Table 1) Contaminant Source Inventory and Risk Ranking for LKSD Kilbuck Elementary – Bacteria and Viruses (Table 2) Contaminant Source Inventory and Risk Ranking for LKSD Kilbuck Elementary – Nitrates/Nitrites (Table 3) Contaminant Source Inventory and Risk Ranking for LKSD Kilbuck Elementary – Volatile Organic Chemicals (Table 4) Contaminant Source Inventory and Risk Ranking for LKSD Kilbuck Elementary – Heavy Metals, Cyanide and Other Inorganic Chemicals (Table 5) Contaminant Source Inventory and Risk Ranking for LKSD Kilbuck Elementary – Synthetic Organic Chemicals (Table 6) Contaminant Source Inventory and Risk Ranking for LKSD Kilbuck Elementary – Other Organic Chemicals (Table 7)
	C. LKSD Kilbuck Elementary Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)
	D. Vulnerability Analysis for Contaminant Source Inventory and Risk Ranking for LKSD Kilbuck Elementary Public Drinking Water Source (Charts 1 – 14)

# Source Water Assessment for LKSD Kilbuck Elementary Source of Public Drinking Water, Bethel, Alaska

---

## Drinking Water Protection Program Alaska Department of Environmental Conservation

### EXECUTIVE SUMMARY

LKSD Kilbuck Elementary has one Public Water System (PWS) well. The well (PWS No. 270493.001) has been used as a drinking water source since it was drilled in 1958.

The well is a Class A (community and non-transient/non-community) water system located at 1010 4<sup>th</sup> Avenue in Bethel, Alaska. Available records indicate that there is water storage with a capacity of 1,240-gallons, and that the drinking water is treated with calcium hypochlorite. This system operates year round and serves approximately 640 non-residents through one service connection. The wellhead received a susceptibility rating of **Very High** and the aquifer received a susceptibility rating of **Low**. Combining these two ratings produce a **High** rating for the natural susceptibility of the well.

Identified potential and current sources of contaminants for the public drinking water source include: an injection well, aboveground fuel tanks, wastewater holding tanks, ADEC recognized contaminated site and leaking underground storage tank (LUST) sites, roads, domestic wastewater collection systems, firehouses, a domestic wastewater treatment plant disposal pond/lagoon, landfills, and a motor vehicle/general storage yard/facility. These identified potential and existing sources of contamination are considered as sources of bacteria and viruses, nitrates and/or nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemical contaminant categories.

Overall, the water well received a vulnerability rating of **Medium** for bacteria and viruses, a vulnerability rating of **High** for nitrates and nitrites, synthetic organic chemicals, and a vulnerability rating of **Very High** for volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, and other organic chemicals.

### PUBLIC DRINKING WATER SYSTEM

The LKSD Kilbuck Elementary well is a Class A (community/non-transient/non-community) public water system. The system is located at 1010 4<sup>th</sup> Avenue in Bethel, Alaska (Sec. 9, T8N, R71W, Seward Meridian; see Map A of Appendix A). Bethel serves as the regional center for 56 villages in the Yukon-Kuskokwim Delta. Food, fuel, transportation, medical care, and other services for the region are provided by Bethel. Bethel is located at the mouth of the Kuskokwim River, 40-miles inland from the Bering Sea, and approximately 400-air miles west of Anchorage. The community has a population of 5,736 (ADCED, 2003). Average annual precipitation for Bethel is 16 inches, including approximately 50 inches of snowfall. Temperatures range from 42 to 62°F in summer and -2 to 19°F in winter.

The community of Bethel obtains a portion of their water supply from city wells. Some households are served by the central piped water and sewage collection system; however, approximately 75% of households have water delivered and sewage hauled by truck. Several facilities have individual wells and septic tanks (ADCED, 2003). Bethel receives electrical power from the Bethel Utilities Corporation. Power generating facilities are fueled by diesel. Refuse is collected by the City of Bethel and transported to the City operated landfill (ADCED, 2003).

According to information supplied by ADEC for the LKSD Kilbuck Elementary PWS, the depth of the primary water well is 405 feet below the ground surface. Well construction details are unknown; however, it is assumed the well is screened in a confined aquifer based on available construction details for surrounding wells. The well is not located within a floodplain.

Information acquired from a December 2002 sanitary survey for the public water system indicated that the land surface was not sloped away from the well. Generally, land surfaces that slope away from the wellhead promote surface water drainage, which

reduces the potential of contaminant migration down the well casing annulus. The sanitary survey indicates that the well is not grouted according to ADEC regulations. Proper grouting provides added protection against contaminants traveling along the well casing annulus and into source waters.

The Bethel area is near the southern border of the continuous permafrost zone and the City, and most of the area west of the Kuskokwim River, appear to be underlain with permafrost. The permafrost generally extends to a depth of at least 300 feet bgs, with depths of over 600 feet bgs recorded in some areas. The geology in the area consists primarily of unconsolidated floodplain alluvium, silt deposits, and reworked silt. The Bethel area consists of poorly drained wetlands that have permanently ponded water in local depressions. Sloughs, small lakes, ponds, and marshes in meander scars surround Bethel (Dames & Moore, 1996).

### DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. These areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the area that contributes water to the well, the groundwater recharge area. This area is designated as the drinking water protection area (DWPA). Because releases of contaminants within the protection area are most likely to impact the drinking water well, this area will serve as the focus for voluntary protection efforts. An analytical calculation was used to determine the size and shape of the DWPA for the LKSD Kilbuck Elementary PWS. The input parameters describing the attributes of the aquifer in this calculation were adopted from Groundwater (Freeze and Cherry, 1979). Available geology and groundwater contours were also considered to take into account any uncertainties in groundwater flow and aquifer characteristics to arrive at a meaningful protection area.

The protection areas established for wells by the ADEC are usually separated into four zones, limited by the watershed. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well (Please refer to the Guidance Manual for Class A Public Water Systems for additional information).

The time of travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the four protection area zones for wells and the calculated time-of-travel for each:

**Table 1. Definition of Zones**

Zone	Definition
A	¼ the distance for the 2-yr. time-of-travel
B	Less than the 2 year time-of-travel
C	Less Than the 5 year time-of-travel
D	Less than the 10 year time-of-travel

The DWPA for the LKSD Kilbuck Elementary PWS was determined using an analytical calculation and includes Zones A, B, C, and D (See Map A of Appendix A).

### INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES

The Drinking Water Protection Program has completed an inventory of potential and existing sources of contamination within the LKSD Kilbuck Elementary DWPA. This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class A public water system assessments, six categories of drinking water contaminants were inventoried. They include:

- Bacteria and viruses,
- Nitrates and/or nitrites,
- Volatile organic chemicals,
- Heavy metals, cyanide and other inorganic chemicals,
- Synthetic organic chemicals,
- Other organic chemicals.

The sources are displayed on Map C of Appendix C and summarized in Table 1 of Appendix B.

### RANKING OF CONTAMINANT RISKS

Once the potential and existing sources of contamination have been identified, they are assigned a ranking according to what type and level of risk

they represent. Ranking of contaminant risks for a “potential” or “existing” source of contamination is a function of toxicity and volumes of specific contaminants associated with that source. Rankings include:

- Low,
- Medium,
- High, and
- Very High.

The time-of-travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. Bacteria and Viruses are only inventoried in Zones A and B because of their short life span. Only “Very High” and “High” rankings are inventoried within the outer Zone D due to the probability of contaminant dilution by the time the contaminants get to the well. Tables 2 through 4 in Appendix B contain the ranking of potential and existing sources of contamination with respect to bacteria and viruses, nitrates and/or nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals.

**VULNERABILITY OF THE DRINKING WATER SYSTEM**

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural susceptibility, and
- Contaminant risks.

Appendix D contains fourteen charts, which together form the ‘Vulnerability Analysis’ for a source water assessment for a public drinking water source. Chart 1 analyzes the ‘Susceptibility of the Wellhead’ to contamination by looking at the construction of the well and its surrounding area. Chart 2 analyzes the ‘Susceptibility of the Aquifer’ to contamination by looking at the naturally occurring attributes of the water source and influences on the groundwater system that might lead to contamination. Chart 3 analyzes ‘Contaminant Risks’ for the drinking water source with respect to bacteria and viruses. The ‘Contaminant Risks’ portion of the analysis considers potential sources of contaminants as well as a review of contamination that has or may have occurred, but has not arrived or been detected at the well. Chart 4 contains the ‘Vulnerability Analysis for Bacteria and Viruses’. Charts 5 through 14 contain the Contaminant Risks and Vulnerability Analyses for nitrates and nitrites, volatile organic chemicals, heavy

metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals, respectively.

A score for the Natural Susceptibility is reached by considering the properties of the well and the aquifer.

Susceptibility of the Wellhead (0 – 25 Points)  
(Chart 1 of Appendix D)

+

Susceptibility of the Aquifer (0 – 25 Points)  
(Chart 2 of Appendix D)

=

Natural Susceptibility (Susceptibility of the Well)  
(0 – 50 Points)

A ranking is assigned for the Natural Susceptibility according to the point score:

Natural Susceptibility Ratings	
40 to 50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

The LKSD Kilbuck Elementary water well is in a confined aquifer. Confined aquifers are less susceptible to potential groundwater quality impacts posed by the migration of surface water contaminants downward from the surface. Table 2 shows the susceptibility scores and ratings for this PWS.

**Table 2. Susceptibility**

	Score	Rating
Susceptibility of the Wellhead	25	Very High
Susceptibility of the Aquifer	7	Low
Natural Susceptibility	32	High

Contaminant risks to a drinking water source depend on the type, number or density, and distribution of contaminant sources. This score has been derived from an examination of existing and historical contamination that has been detected at the drinking water source through routine sampling. It also evaluates potential sources of contamination. Flow charts are used to assign a point score, and ratings are

assigned in the same way as for the natural susceptibility:

Contaminant Risk Ratings	
40 to 50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants.

**Table 3. Contaminant Risks**

Category	Score	Rating
Bacteria and Viruses	12	Low
Nitrates and/or Nitrites	44	Very High
Volatile Organic Chemicals	50	Very High
Heavy Metals, Cyanide and		
Other Inorganic Chemicals	50	Very High
Synthetic Organic Chemicals	41	Very High
Other Organic Chemicals	49	Very High

Finally, an overall vulnerability score is assigned for each water system by combining each of the contaminant risk scores with the natural susceptibility score:

$$\begin{array}{r}
 \text{Natural Susceptibility (0 – 50 points)} \\
 + \\
 \text{Contaminant Risks (0 – 50 points)} \\
 = \\
 \text{Vulnerability of the} \\
 \text{Drinking Water Source to Contamination (0 – 100)}.
 \end{array}$$

Again, rankings are assigned according to a point score:

Overall Vulnerability Ratings	
80 to 100 pts	Very High
60 to < 80 pts	High
40 to < 60 pts	Medium
< 40 pts	Low

Table 4 contains the overall vulnerability scores (0 – 100) and ratings for each of the six categories of drinking water contaminants. Note: scores are rounded off to the nearest five.

**Table 4. Overall Vulnerability**

Category	Score	Rating
Bacteria and Viruses	45	Medium
Nitrates and Nitrites	75	High
Volatile Organic Chemicals	80	Very High
Heavy Metals, Cyanide and		
Other Inorganic Chemicals	80	Very High
Synthetic Organic Chemicals	75	High
Other Organic Chemicals	80	Very High

**Bacteria and Viruses**

The contaminant risk for bacteria and viruses is **Low**. The risk is primarily attributed to the presence of a domestic wastewater treatment plant disposal pond/lagoon and landfills in Zone C (see Table 2 – Appendix B).

A positive bacteria count has not been reported in recent (within five years) sampling events (See Chart 3 – Contaminant Risks for Bacteria and Viruses in Appendix D). Only a small amount of bacteria and viruses are required to endanger public health.

After combining the contaminant risk for bacteria and viruses with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

**Nitrates and Nitrites**

The contaminant risk for nitrates and nitrites is **Very High**. The risk to this source of public drinking water is primarily attributed to the presence of a domestic wastewater treatment plant disposal pond/lagoon and a landfill in Zone C (see Table 3 – Appendix B).

Nitrates are very mobile, moving at approximately the same rate as water. The sampling history for this well indicates that low levels of nitrates have been detected in recent sampling events. However, the reported concentrations of nitrates do not exceed the maximum contaminant level (MCL) of 10 mg/L. Nitrate concentrations in uncontaminated groundwater are typically less than 2 mg/L; therefore, nitrate concentrations above 2 mg/L may be indicative of man-made sources (See Chart 5 - Contaminant Risks for Nitrates and/or Nitrites in Appendix D).

Nitrate levels are often derived from the decomposition of organic matter in soils. Although the nitrate source is unknown, such occurrences may be attributed to septic systems or other sources. After combining the contaminant risk for nitrates and

nitrites with the natural susceptibility of the well, the overall vulnerability of the well to nitrate and nitrite contamination is **High**.

### **Volatile Organic Chemicals**

The contaminant risk for volatile organic chemicals is **Very High**. The risk is primarily attributed to the presence of an injection well; ADEC recognized contaminated sites and LUST sites, and a landfill in Zones A and C. Numerous other potential contaminant sources are also found within the protection area (see Table 4 – Appendix B).

Detectable concentrations of trihalomethanes were reported in sampling events for this public water system. However, the detectable concentrations of trihalomethanes reported 2000 were well below the MCL of 0.08 mg/L. Trihalomethanes are considered byproducts of the water treatment process and are not from the source waters. Since the reported concentration of TTHM's in recent sampling events did not exceed the applicable MCLs, risk points were not retained.

Aside from being byproducts of the drinking water treatment process, possible sources of volatile organic chemicals include facilities with automobiles, residential areas, fuel tanks, roads, and airports. See Table 4 in Appendix D for a complete listing.

After combining the contaminant risk for volatile organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Very High**.

### **Heavy Metals, Cyanide and Other Inorganic Chemicals**

The contaminant risk for heavy metals, cyanide and other inorganic chemicals is **Very High**. The risk is primarily attributed to the presence of an injection well, a landfill, and an ADEC recognized LUST site in Zones A and C. Numerous other potential contaminant sources are also found within the protection area (see Table 5 – Appendix B).

Based on review of recent sampling records for this public water system, high levels of copper and lead have been detected in recent sampling history. Both of these analytes have exceeded their respective MCLs of 1.3 mg/L and 0.015 mg/L (see Chart 9 – Contaminant Risks for Heavy Metals, Cyanide, and Other Inorganic Chemicals in Appendix D).

After combining the contaminant risk for heavy metals, cyanide and other inorganic chemicals with the natural susceptibility of the well, the overall

vulnerability of the well to contamination is **Very High**.

### **Synthetic Organic Chemicals**

The contaminant risk for synthetic organic chemicals is **Very High**. The risk is primarily attributed to the presence of a landfill in Zone C (see Table 6 – Appendix B).

No recent sampling data was available in ADEC records for the LKSD Kilbuck Elementary (See Chart 11 – Contaminant Risks for Synthetic Organic Chemicals in Appendix D).

After combining the contaminant risk for synthetic organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **High**.

### **Other Organic Chemicals**

The contaminant risk for other organic chemicals is **Very High**. The risk is primarily attributed to the presence of landfills in Zones C and D. Numerous other potential contaminant sources are also found within the protection area (see Table 7 – Appendix B).

No recent sampling data was available in ADEC records for the LKSD Kilbuck Elementary (See Chart 13 – Contaminant Risks for Other Organic Chemicals in Appendix D).

After combining the contaminant risk for other organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Very High**.

### **Using the Source Water Assessment**

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of LKSD Kilbuck Elementary and the community of Bethel to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of the drinking water source.




## REFERENCES

- Alaska Department of Community and Economic Development (ADCED), 2003 [WWW document]. URL: [http://www.dced.state.ak.us/cbd/commdb/CF\\_COMDB.htm](http://www.dced.state.ak.us/cbd/commdb/CF_COMDB.htm)
- Alaska Department of Environmental Conservation, Contaminated Sites Database, 2003 [WWW database], URL [http://www.state.ak.us/dec/dspar/csites/cs\\_search.htm](http://www.state.ak.us/dec/dspar/csites/cs_search.htm)
- Alaska Department of Environmental Conservation, Leaking Underground Storage Tank Database, 2003 [WWW database], URL [http://www.dec.state.ak.us/spar/stp/ust/search/fac\\_search.asp](http://www.dec.state.ak.us/spar/stp/ust/search/fac_search.asp)
- Dames & Moore, 1996. Final Water and Sewer Facilities Master Plan Update Report, City of Bethel.
- Freeze, R. A., and Cherry, J.A. 1979, Groundwater, Prentice-Hall, Englewood Cliffs, New Jersey
- United States Environmental Protection Agency (EPA), 2002 [WWW document]. URL <http://www.epa.gov/safewater/mcl.html>.

# **APPENDIX A**

## **Drinking Water Protection Area Location Map (Map A)**

Public Water Well System for PWS #270493.001 LKSD Kilbuck Elementary



**LEGEND**

- Public Water System Well
- Hydrography/Physical**
  - Parcels
  - Stream
  - Lake or Pond
  - Contours
- Transportation**
  - Primary Route (Class 1)
  - Secondary Route (Class 2)
  - Road (Class 3)
  - Road (Class 4)
  - Road (Class 5, Four-wheel drive)
- Groundwater Protection Zones**
  - Zone A Protection Area- Several Months Travel Time
  - Zone B Protection Area- 2 Years Travel Time
  - Zone C Protection Area- 5 Years Travel Time
  - Zone D Protection Area- 10 Years Travel Time




Data Sources:  
 Contaminant Sources, Public Water System Wells, Contours  
 Alaska Department of Environmental Conservation (ADEC)

Critical Facilities, Federal Emergency Management Agency (FEMA)

All other data:  
 United States Geological Survey (USGS)

Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class A Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.



## **APPENDIX B**

### **Contaminant Source Inventory and Risk Ranking (Tables 1-7)**

**Table 1**

**Contaminant Source Inventory for  
LKSD Kilbuck Elementary**

**PWSID 270493.001**

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Map Number</i>	<i>Comments</i>
Injection wells (Class V) Motor Vehicle Waste Disposal Well	D42	D42-01	A	C	The Shop
Tanks, heating oil, residential (above ground)	R08	R08-01	A	C	Assume 50 or less residential heating oil tanks in Zone A
Tanks, diesel (above ground)	T06	T06-01	A	C	
Tanks, heating oil, nonresidential (aboveground)	T14	T14-01	A	C	
Wastewater Holding Tank	T22	T22-01	A	C	
Contaminated sites, DEC recognized, non-Superfund, non-RCRA	U04	U04-01	A	C	AKARNG Bethel OMS, RecKey #1998250103002, Status: Inactive, DRO contaminated soil near fuel tank and former ASTs.
Contaminated sites, DEC recognized, non-Superfund, non-RCRA	U04	U04-02	A	C	Kuskokwim Inn, RecKey #1999250120001, Status: Active, diesel contaminated soils discovered during removal of a 1,000-gallon tank. Approximately 150 cubic yards of soil was excavated and stockpiled off-site.
Open Leaking Underground Fuel Storage Tank (LUST) Sites	U07	U07-01	A	C	AKANG Bethel OMS Alaska Army National Guard Armory, RecKey #1993250002151, Event ID 1341, Facility ID 3133, release from 1,000-gallon gasoline tank, long term stockpiling plan approved, stockpile located at Bethel Airport.
Highways and roads, dirt/gravel	X24	X24-01	A	C	Assume 1-20 roads in Zone A
Domestic wastewater collection systems (sewer lines or lift stations)	D01	D01-01	B	C	
Tanks, heating oil, residential (above ground)	R08	R08-02	B	C	Assume 50 or less residential heating oil tanks in Zone B
Highways and roads, dirt/gravel	X24	X24-02	B	C	Assume 1-20 roads in Zone B
Firehouses	X38	X38-01	B	C	
Domestic wastewater collection systems (sewer lines or lift stations)	D01	D01-02	C	C	
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	C	C	
Landfills (municipal; Class II)	D50	D50-01	C	C	Bethel Landfill
Tanks, heating oil, residential (above ground)	R08	R08-03	C	C	Assume 25 or less residential heating oil tanks in Zone C
Closed leaking fuel storage tank (LUST) (aviation)	U12	U12-01	C	C	Bethel Dump, RecKey #1990250120701, Status: Closed, reported under ADEC Contaminated Sites database, old oil drums amounting in the hundreds leaking in the dump.

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Map Number</i>	<i>Comments</i>
Highways and roads, dirt/gravel	X24	X24-03	C	C	Assume 1-20 roads in Zone C
Motor vehicle/general storage yards/facilities	X27	X27-01	C	C	Arctic Moving & Delivery
Landfills (industrial; type of industrial waste?)	D52	D52-01	D	C	Bethel Asbestos Landfill

*Contaminant Source Inventory and Risk Ranking for  
LKSD Kilbuck Elementary  
Sources of Bacteria and Viruses*

PWSID 270493.001

**Table 2**

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Injection wells (Class V) Motor Vehicle Waste Disposal Well	D42	D42-01	A	Low	C	The Shop
Wastewater Holding Tank	T22	T22-01	A	Low	C	
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-01	B	Medium	C	
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-02	C	Medium	C	
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	C	High	C	
Landfills (municipal; Class II)	D50	D50-01	C	High	C	Bethel Landfill
Closed leaking fuel storage tank (LUST) (aviation)	U12	U12-01	C	Low	C	Bethel Dump, RecKey #1990250120701, Status: Closed, reported under ADEC Contaminated Sites database, old oil drums amounting in the hundred leaking in the dump.
Highways and roads, dirt/gravel	X24	X24-03	C	Low	C	Assume 1-20 roads in Zone C

*Contaminant Source Inventory and Risk Ranking for  
LKSD Kilbuck Elementary  
Sources of Nitrates/Nitrites*

*PWSID 270493.001*

**Table 3**

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Wastewater Holding Tank	T22	T22-01	A	Low	C	
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-01	B	Medium	C	
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-02	C	Medium	C	
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	C	High	C	
Landfills (municipal; Class II)	D50	D50-01	C	Very High	C	Bethel Landfill
Closed leaking fuel storage tank (LUST) (aviation)	U12	U12-01	C	Low	C	Bethel Dump, RecKey #1990250120701, Status: Closed, reported under ADEC Contaminated Sites database, old oil drums amounting in the hundred leaking in the dump.
Highways and roads, dirt/gravel	X24	X24-03	C	Low	C	Assume 1-20 roads in Zone C



*Contaminant Source Inventory and Risk Ranking for  
LKSD Kilbuck Elementary  
Sources of Volatile Organic Chemicals*

PWSID 270493.001

Table 4

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Injection wells (Class V) Motor Vehicle Waste Disposal Well	D42	D42-01	A	High	C	The Shop
Tanks, heating oil, residential (above ground)	R08	R08-01	A	Medium	C	Assume 50 or less residential heating oil tanks in Zone A
Tanks, diesel (above ground)	T06	T06-01	A	Medium	C	
Tanks, heating oil, nonresidential (aboveground)	T14	T14-01	A	Low	C	
Wastewater Holding Tank	T22	T22-01	A	Medium	C	
Contaminated sites, DEC recognized, non-Superfund non-RCRA	U04	U04-01	A	High	C	AKARNG Bethel OMS, RecKey #1998250103002, Status: Inactive, DRO contaminated soil near fuel tank and former ASTs.
Contaminated sites, DEC recognized, non-Superfund non-RCRA	U04	U04-02	A	High	C	Kuskokwim Inn, RecKey #1999250120001, Status: Active, diesel contaminated soils discovered during removal of a 1,000-gallon tank. Approximately 150 cubic yards of soil was excavated and stockpiled off-site.
Open Leaking Underground Fuel Storage Tank (LUST) Sites	U07	U07-01	A	High	C	AKANG Bethel OMS Alaska Army National Guard Armory, RecKey #1993250002151, Event ID 1341, Facility ID 3133, release from 1,000-g gasoline tank, long term stockpiling plan approved, stockpile located at Be Airport.
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-01	B	Low	C	
Tanks, heating oil, residential (above ground)	R08	R08-02	B	Medium	C	Assume 50 or less residential heating oil tanks in Zone B
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B
Firehouses	X38	X38-01	B	Low	C	
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-02	C	Low	C	
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	C	Low	C	
Landfills (municipal; Class II)	D50	D50-01	C	High	C	Bethel Landfill
Tanks, heating oil, residential (above ground)	R08	R08-03	C	Medium	C	Assume 25 or less residential heating oil tanks in Zone C
Closed leaking fuel storage tank (LUST) (aviation)	U12	U12-01	C	High	C	Bethel Dump, RecKey #1990250120701, Status: Closed, reported under ADEC Contaminated Sites database, old oil drums amounting in the hundred leaking in the dump.

*Contaminant Source Inventory and Risk Ranking for  
LKSD Kilbuck Elementary  
Sources of Volatile Organic Chemicals*

*PWSID 270493.001*

*Table 4 (continued)*

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Highways and roads, dirt/gravel	X24	X24-03	C	Low	C	Assume 1-20 roads in Zone C
Motor vehicle/general storage yards/facilities	X27	X27-01	C	Low	C	Arctic Moving & Delivery

*Contaminant Source Inventory and Risk Ranking for  
LKSD Kilbuck Elementary*

PWSID 270493.001

**Table 5**

*Sources of Heavy Metals, Cyanide and Other Inorganic Chemicals*

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Injection wells (Class V) Motor Vehicle Waste Disposal Well	D42	D42-01	A	High	C	The Shop
Tanks, heating oil, nonresidential (aboveground)	T14	T14-01	A	Low	C	
Wastewater Holding Tank	T22	T22-01	A	Medium	C	
Contaminated sites, DEC recognized, non-Superfund non-RCRA	U04	U04-01	A	Low	C	AKARNG Bethel OMS, RecKey #1998250103002, Status: Inactive, DRO contaminated soil near fuel tank and former ASTs.
Contaminated sites, DEC recognized, non-Superfund non-RCRA	U04	U04-02	A	Low	C	Kuskokwim Inn, RecKey #1999250120001, Status: Active, diesel contaminated soils discovered during removal of a 1,000-gallon tank. Approximately 150 cubic yards of soil was excavated and stockpiled off-site.
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-01	B	Low	C	
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B
Firehouses	X38	X38-01	B	Low	C	
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-02	C	Low	C	
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	C	Low	C	
Landfills (municipal; Class II)	D50	D50-01	C	High	C	Bethel Landfill
Closed leaking fuel storage tank (LUST) (aviation)	U12	U12-01	C	Very High	C	Bethel Dump, RecKey #1990250120701, Status: Closed, reported under ADEC Contaminated Sites database, old oil drums amounting in the hundreds leaking in the dump.
Highways and roads, dirt/gravel	X24	X24-03	C	Low	C	Assume 1-20 roads in Zone C

*Contaminant Source Inventory and Risk Ranking for  
LKSD Kilbuck Elementary  
Sources of Synthetic Organic Chemicals*

PWSID 270493.001

Table 6

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Injection wells (Class V) Motor Vehicle Waste Disposal Well	D42	D42-01	A	Low	C	The Shop
Contaminated sites, DEC recognized, non-Superfund non-RCRA	U04	U04-01	A	Low	C	AKARNG Bethel OMS, RecKey #1998250103002, Status: Inactive, DRO contaminated soil near fuel tank and former ASTs.
Contaminated sites, DEC recognized, non-Superfund non-RCRA	U04	U04-02	A	Low	C	Kuskokwim Inn, RecKey #1999250120001, Status: Active, diesel contaminated soils discovered during removal of a 1,000-gallon tank. Approximately 150 cubic yards of soil was excavated and stockpiled off-site.
Open Leaking Underground Fuel Storage Tank (LUST) Sites	U07	U07-01	A	Low	C	AKANG Bethel OMS Alaska Army National Guard Armory, RecKey #1993250002151, Event ID 1341, Facility ID 3133, release from 1,000-gallon gasoline tank, long term stockpiling plan approved, stockpile located at Bethel Airport.
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-01	B	Low	C	
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-02	C	Low	C	
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	C	Low	C	
Landfills (municipal; Class II)	D50	D50-01	C	Very High	C	Bethel Landfill
Closed leaking fuel storage tank (LUST) (aviation)	U12	U12-01	C	Low	C	Bethel Dump, RecKey #1990250120701, Status: Closed, reported under ADEC Contaminated Sites database, old oil drums amounting in the hundreds leaking in the dump.

*Contaminant Source Inventory and Risk Ranking for  
LKSD Kilbuck Elementary  
Sources of Other Organic Chemicals*

PWSID 270493.001


Table 7

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Injection wells (Class V) Motor Vehicle Waste Disposal Well	D42	D42-01	A	Medium	C	The Shop
Wastewater Holding Tank	T22	T22-01	A	Medium	C	
Contaminated sites, DEC recognized, non-Superfund non-RCRA	U04	U04-01	A	Low	C	AKARNG Bethel OMS, RecKey #1998250103002, Status: Inactive, DRO contaminated soil near fuel tank and former ASTs.
Contaminated sites, DEC recognized, non-Superfund non-RCRA	U04	U04-02	A	Low	C	Kuskokwim Inn, RecKey #1999250120001, Status: Active, diesel contaminated soils discovered during removal of a 1,000-gallon tank. Approximately 150 cubic yards of soil was excavated and stockpiled off-site.
Open Leaking Underground Fuel Storage Tank (LUST) Sites	U07	U07-01	A	Low	C	AKANG Bethel OMS Alaska Army National Guard Armory, RecKey #1993250002151, Event ID 1341, Facility ID 3133, release from 1,000-g gasoline tank, long term stockpiling plan approved, stockpile located at Bethel Airport.
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assume 1-20 roads in Zone A
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-01	B	Low	C	
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	Assume 1-20 roads in Zone B
Domestic wastewater collection systems (sewer line or lift stations)	D01	D01-02	C	Low	C	
Domestic wastewater treatment plant disposal ponds/lagoons	D02	D02-01	C	Low	C	
Landfills (municipal; Class II)	D50	D50-01	C	Very High	C	Bethel Landfill
Closed leaking fuel storage tank (LUST) (aviation)	U12	U12-01	C	Low	C	Bethel Dump, RecKey #1990250120701, Status: Closed, reported under ADEC Contaminated Sites database, old oil drums amounting in the hundreds leaking in the dump.
Highways and roads, dirt/gravel	X24	X24-03	C	Low	C	Assume 1-20 roads in Zone C
Motor vehicle/general storage yards/facilities	X27	X27-01	C	Low	C	Arctic Moving & Delivery
Landfills (industrial; type of industrial waste?)	D52	D52-01	D	Very High	C	Bethel Asbestos Landfill

## **APPENDIX C**

### **Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)**

**Public Water Well System for PWS #270493.001 LKSD Kilbuck Elementary  
Showing Potential and Existing Sources of Contamination**





**LEGEND**

Public Water System Well	
<b>Hydrography/Physical</b>	<b>Transportation</b>
Parcels	Primary Route (Class 1)
Stream	Secondary Route (Class 2)
Lake or Pond	Road (Class 3)
Contours	Road (Class 4)
	Road (Class 5, Four-wheel drive)
<b>Groundwater Protection Zones</b>	
Zone A Protection Area- Several Months Travel Time	
Zone B Protection Area- 2 Years Travel Time	
Zone C Protection Area- 5 Years Travel Time	
Zone D Protection Area- 10 Years Travel Time	
<b>Existing or Potential Contaminant Sources</b>	
Domestic wastewater collection systems (sewer lines) (D01)	
Domestic wastewater treatment plant disposal pond (D02)	
Injection wells (Class V) Motor vehicle waste disposal well (D42)	
Aboveground diesel tank (T06)	
Nonresidential aboveground heating oil tank (T14)	
Wastewater holding tank (T22)	
Contaminated sites, DEC recognized, non-Superfund, non-RCRA (U04)	
Open Leaking Underground Fuel Storage Tank (LUST) (lubricants or other petroleum products) (U07)	
Closed Leaking Underground Fuel Storage Tank (LUST) (aviation) (U12)	
Motor vehicle/general storage yards/facilities (X27)	
Firehouse (X38)	
Landfills (municipal; Class II) (D50)	
Landfills (industrial) (D52)	

Data Sources:  
Contaminant Sources, Public Water System Wells, Contours  
Alaska Department of Environmental Conservation (ADEC)  
Critical Facilities, Federal Emergency Management Agency (FEMA)

All other data:  
United States Geological Survey (USGS)  
Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class A Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.




## **APPENDIX D**

### **Vulnerability Analysis for Public Drinking Water Source (Charts 1-14)**




**Chart 1. Susceptibility of the wellhead - LKSD Kilbuck Elementary School (PWS No. 270493.001)**




Wellhead Susceptibility Ratings	
20 to 25 pts	very high
15 to < 20 pts	high
10 to < 15 pts	medium
< 10 pts	low


**Chart 2. Susceptibility of the aquifer LKSD Kilbuck Elementary School (PWS No. 270493.001)**




**Chart 3. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Bacteria & Viruses**



**Chart 3. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Bacteria & Viruses**



**Chart 4. Vulnerability analysis for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Bacteria & Viruses**



**Chart 5. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Nitrates and Nitrites**








Chart 5. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Nitrates and Nitrites




**Chart 5. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Nitrates and Nitrites**





**Chart 6. Vulnerability analysis for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Nitrates and Nitrites**



**Chart 7. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Volatile Organic Chemicals**








Chart 7. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Volatile Organic Chemicals




**Chart 7. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Volatile Organic Chemicals**






**Chart 8. Vulnerability analysis for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Volatile Organic Chemicals**



**Chart 9. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals**




**Chart 9. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals**



The number and magnitude of contaminant sources in Zone A determines a risk increase. See Table 5 for inventory.

**Chart 9. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals**





**Chart 10. Vulnerability analysis for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals**




Chart 11. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Synthetic Organic Chemicals






Chart 11. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Synthetic Organic Chemicals



**Chart 11. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Synthetic Organic Chemicals**



**Chart 12. Vulnerability analysis for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Synthetic Organic Chemicals**




Chart 13. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Other Organic Chemicals






Chart 13. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Other Organic Chemicals



**Chart 13. Contaminant risks for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Other Organic Chemicals**





**Chart 14. Vulnerability analysis for LKSD Kilbuck Elementary School (PWS No. 270493.001) - Other Organic Chemicals**

