



**UNITED STATES AIR FORCE  
611TH AIR SUPPORT GROUP  
611TH CIVIL ENGINEER SQUADRON**

**JOINT BASE ELMENDORF-RICHARDSON,  
ALASKA**

**DRINKING WATER SOURCE ASSESSMENT**

**KING SALMON DIVERT AIRFIELD**

**KING SALMON, ALASKA**

**DRAFT FINAL  
MARCH 2022**

**UNITED STATES AIR FORCE  
611TH AIR SUPPORT GROUP  
611TH CIVIL ENGINEER SQUADRON**

**JOINT BASE ELMENDORF-RICHARDSON,  
ALASKA**

**DRINKING WATER SOURCE ASSESSMENT**

**KING SALMON DIVERT AIRFIELD**

**KING SALMON, ALASKA**

**DRAFT FINAL  
MARCH 2022**

[THIS PAGE INTENTIONALLY LEFT BLANK]

## TABLE OF CONTENTS

<b><u>SECTION</u></b>	<b><u>PAGE</u></b>
ACRONYMS AND ABBREVIATIONS.....	vii
EXECUTIVE SUMMARY.....	1
PURPOSE .....	1
FINDINGS .....	1
<b>1.0 INTRODUCTION .....</b>	<b>2</b>
1.1 PURPOSE.....	2
1.2 AGENCY ASSISTANCE .....	2
1.3 BACKGROUND INFORMATION.....	2
1.3.1 Safe Drinking Water Act .....	3
1.3.2 ADEC Drinking Water Program Mission.....	3
1.3.3 Source of Drinking Water at KSDA.....	3
1.4 PAST SOURCES OF WATER SUPPLY AT KSDA.....	4
<b>2.0 DESCRIPTION OF KING SALMON.....</b>	<b>5</b>
2.1 CLIMATE .....	5
2.2 GEOLOGY .....	5
2.3 WATER RESOURCES.....	6
2.3.1 Surface Water.....	6
2.3.2 Groundwater.....	6
2.4 SUMMARY .....	7
<b>3.0 TECHNICAL APPROACH AND METHODS .....</b>	<b>8</b>
3.1 PROTECTION AREA DELINEATION.....	8
3.2 CONTAMINANT SOURCE INVENTORY.....	12
3.2.1 Strategy .....	12
3.2.2 Fieldwork .....	12
3.2.3 Literature Search .....	13
3.2.4 Update.....	13
3.2.5 Ranking.....	13
3.3 ASSESSING VULNERABILITY .....	14

**TABLE OF CONTENTS**  
**(continued)**

<b><u>SECTION</u></b>	<b><u>PAGE</u></b>
<b>4.0 SOURCE PROTECTION AREA AND WATER SUPPLY SYSTEM.....</b>	<b>15</b>
4.1 CURRENT WATER SUPPLY.....	15
4.1.1 System Information .....	15
4.1.2 Class and Identification .....	15
4.1.3 Owner/Operator.....	15
4.1.4 Status and Operation of Water System.....	16
4.1.5 System Modifications .....	16
4.1.6 Groundwater Collection System .....	16
4.1.7 Treatment .....	16
4.1.8 Storage .....	17
4.1.9 Distribution System.....	17
4.1.10 Connections.....	17
4.1.11 Cross Connection Control Program.....	18
4.1.12 Population Served.....	18
4.1.13 Water Use.....	18
4.1.14 Contingency Plan.....	18
4.1.15 Emergency Response Plan.....	19
4.2 SUMMARY .....	19
<b>5.0 INVENTORY OF CONTAMINANT SOURCES .....</b>	<b>20</b>
5.1 POTENTIAL SOURCES OF CONTAMINATION.....	20
5.2 HISTORIC SOURCES OF CONTAMINATION.....	21
<b>6.0 SORTING AND RANKING CONTAMINANT SOURCES.....</b>	<b>22</b>
6.1 SORTING CONTAMINANT SOURCES .....	22
6.2 RANKING CONTAMINANT SOURCES.....	23
6.3 SUMMARY.....	23
<b>7.0 VULNERABILITY OF DRINKING WATER SOURCE.....</b>	<b>24</b>
7.1 VULNERABILITY ASSESSMENT .....	24
7.2 NATURAL SUSCEPTIBILITY .....	25
7.3 VULNERABILITY TO BACTERIA /VIRUSES .....	25

**TABLE OF CONTENTS**  
**(continued)**

<b><u>SECTION</u></b>	<b><u>PAGE</u></b>
7.3.1 Vulnerability Scoring.....	25
7.4 VULNERABILITY TO NITRATES/NITRITES .....	26
7.4.1 Vulnerability Scoring.....	26
7.5 VULNERABILITY TO VOLATILE ORGANIC COMPOUNDS .....	26
7.5.1 Vulnerability Scoring.....	26
7.6 VULNERABILITY TO HEAVY METALS, CYANIDE, AND OTHER INORGANIC CHEMICALS .....	27
7.6.1 Vulnerability Scoring.....	27
7.7 VULNERABILITY TO SYNTHETIC ORGANIC CONTAMINANTS .....	27
7.8 VULNERABILITY TO OTHER ORGANIC CONTAMINANTS.....	27
7.9 OPTIMIZING ONGOING ACTIVITIES .....	28
7.10 FUTURE VULNERABILITY.....	28
7.11 CONTINGENCY WATER SUPPLY .....	28
7.12 SUMMARY .....	28
<b>8.0 RESULTS COMMUNICATION .....</b>	<b>29</b>
8.1 USAF COMMUNICATION .....	29
8.2 PUBLIC COMMUNICATION .....	29
<b>9.0 SUMMARY.....</b>	<b>30</b>
9.1 WATER SUPPLY.....	30
9.2 DRINKING WATER PROTECTION AREA.....	30
9.3 CONTAINMENT SOURCES .....	30
9.4 VULNERABILITY ASSESSMENT.....	30
9.5 COMMUNICATION.....	31
<b>10.0 RECOMMENDATIONS .....</b>	<b>32</b>
<b>11.0 REFERENCES .....</b>	<b>33</b>
<b>PERSONNEL CONTACT LIST.....</b>	<b>34</b>

**TABLE OF CONTENTS**  
**(continued)**

**SECTION**

**PAGE**

**APPENDICES**

APPENDIX A	Photo Log
APPENDIX B	Figures
Figure B-1	Vicinity Map
Figure B-2	KSDA WL0B1 Vicinity Map
Figure B-3	KSDA WL005 Vicinity Map
Figure B-4	King Salmon Source Protection Areas
Figure B-5	KSDA Source Protection Areas
Figure B-6	KSDA WL0B1 Source Protection Area
APPENDIX C	Tables
Table C-1	Six Major Categories of Contaminants Regulated for Drinking Water Sources
Table C-2	Summary of Susceptibility / Vulnerability Scores and Ratings for the Public Water System
APPENDIX D	Inventory
Table D-1	Contaminant Source Inventory, WL0B1 PWSID 260503
APPENDIX E	Inventory ranking
Table E-1	CS Ranking – Sources of Bacteria and Viruses
Table E-2	CS Ranking – Sources of Nitrates/Nitrites
Table E-3	CS Ranking – Sources of Volatile Organic Chemicals
Table E-4	CS Ranking – Sources of Heavy Metals, Cyanide, and Other Inorganic Chemicals
Table E-5	CS Ranking – Sources of Synthetic Organic Chemicals
Table E-6	CS Ranking – Sources of Other Organic Chemicals
APPENDIX F	Flow Charts
Chart F-1	Wellhead Susceptibility
Chart F-2	Aquifer Susceptibility
Chart F-3a	Risk Matrix for Bacteria/Viruses
Chart F-3c	Bacteria/Viruses Vulnerability Analysis.
Chart F-4a	Risk Matrix for Nitrates/Nitrites
Chart F-4d	Nitrates/Nitrites Vulnerability Analysis
Chart F-5a	Risk Matrix for Volatile Organic Chemicals
Chart F-5d	Volatile Organic Chemicals Vulnerability Analysis

**TABLE OF CONTENTS**  
**(continued)**

<b><u>SECTION</u></b>		<b><u>PAGE</u></b>
Chart F-6a	Risk Matrix for Heavy Metals, Cyanide, and Other Inorganic Chemicals	
	Chart F-6d Heavy Metals, Cyanide, and Other Inorganic Chemicals	
Chart F-7a	Risk Matrix for Synthetic Organic Chemicals	
Chart F-7d	Synthetic Organic Chemicals Vulnerability Analysis	
Chart F-8a	Risk Matrix for Other Organic Chemicals	
Chart F-8d	Other Organic Chemicals Vulnerability Analysis	



## ACRONYMS AND ABBREVIATIONS

AAC	Alaska Administrative Code
ADEC	Alaska Department of Environmental Conservation
AST	aboveground storage tank
BTEX	benzene, toluene, ethylbenzene, and xylenes
BOSS	Base Operational Support Services
CCR	Consumer Confidence Report
CERCLA	Comprehensive Environmental Response, Compensation, and Liability Act
DNR	Alaska Department of Natural Resources
DWPG	Drinking Water Protection Group
EPA	U.S. Environmental Protection Agency
GEI	Goldstream Engineering, Inc.
GIS	Geographic Information System
GWUDISW	groundwater under the direct influence of surface water
HDPE	high-density polyethylene
HMCIC	heavy metals, cyanide, and other inorganic chemicals
IRP	Installation Restoration Program
KSDA	King Salmon Divert Airfield
MCL	maximum contaminant levels
mg/L	milligram per liter
MSL	mean sea level
NTNC	Non-Transient, Non-Community
O&M	operations and maintenance
OOB	other organic contaminants
POL	petroleum, oil and lubricant
PWS	public water systems
PWSID	Public Water System Identification
RI/FS	remedial investigation/feasibility study
ROD	Record of Decision
ROWPU	reverse osmosis water purification unit

## ACRONYMS AND ABBREVIATIONS

SDWA	Safe Drinking Water Act
SOC	synthetic organic contaminants
SOP	standard operating procedure
SWA	Source Water Assessment
TCE	trichloroethylene
TPH	total petroleum hydrocarbon
USACE	U.S. Army Corps of Engineers, Alaska
USACHPPM	U.S. Army Center for Health Promotion and Preventative Medicine
USAF	U.S. Air Force
USGS	U.S. Geological Survey
ASRC	Arctic Slope Regional Corporation
UST	underground storage tank
VOC	volatile organic compounds
WTP	Water Treatment Plant
WWII	World War II
µg/L	micrograms per liter

## **EXECUTIVE SUMMARY**

### **PURPOSE**

The purpose of this assessment is to identify contaminant sources within the King Salmon Divert Airfield (KSDA) drinking water protection area for the active water source and to determine source water susceptibility to potential, current, and historic contaminants within the protected area. This information assists the PWS owner in mitigating water contamination and planning for possible future challenges. This assessment is based on information provided by the USAF, ADEC, and other onsite information collected on August 2021 by Goldstream Engineering, Inc. located in Fairbanks, Alaska

### **FINDINGS**

KSDA is located in King Salmon, Alaska, on the Katmai Peninsula. Groundwater wells are the source of public drinking water for the area, currently WL0B1, the active well located near the water treatment plant. A backup well (WL005) is located near the water storage tanks. The system is classified as groundwater. The water system is owned by the U.S. Air Force and operated by Arctic Slope Regional Corporation (ASRC under contract to provide Base Operational Support Services (BOSS)). The drinking water source protection area was identified by ADEC, with areas divided into Zone A and Zone B. We have no reason to suspect the source water protection area was done incorrectly. Potential, current, and historical sources of contamination were evaluated for the level of threat posed to the drinking water source. The susceptibility of the wellhead and aquifer was also assessed and collectively known as the natural susceptibility of the source water.

The overall vulnerability of the KSDA source water is judged to be low. The well appears to have been constructed properly, and it is currently being maintained to protect the water. There are very few potential sources of contamination within the source protection area designated by ADEC for the active well. Additionally, the water source is further protected by two aquitards that protect the aquifer used for drinking water from potential surface contaminants. As time goes on, the future vulnerability of the source water may change. Therefore, updating this source water assessment further in the future may be prudent.

## **1.0 INTRODUCTION**

Goldstream Engineering, Inc. created this Source Water Assessment (SWA) after collecting updated information during an onsite inspection on August 3-5, 2021.

### **1.1 PURPOSE**

The purpose of this assessment is to identify contaminant sources within the drinking water protection area and determine source water susceptibility to potential, current, and historic contaminants within the protected area. A review of the natural hydrologic sensitivity has been combined with potential, current, and historic contaminant risks to arrive at an overall decision about the vulnerability of the drinking water source to contamination. This assessment has been completed to assist the U.S. Air Force (USAF) in protecting drinking water at KSDA, King Salmon, AK.

### **1.2 AGENCY ASSISTANCE**

Numerous individuals assisted in the development of this assessment. Assistance was received from Joint Base Elmendorf-Richardson, KSDA, U.S. Army Corps of Engineers (USACE), Alaska Department of Natural Resources (DNR), U.S. Geological Survey (USGS), and the Alaska Department of Environmental Conservation (ADEC).

### **1.3 BACKGROUND INFORMATION**

A previous Source Water Assessment (SWA) was not identified for this system; therefore, GEI was contracted to create one. This document includes information collected by GEI and a drinking water protection area designated by ADEC in 2014. Source water protection requirements are addressed in ADEC 18 AAC 80.015.

### **1.3.1 Safe Drinking Water Act**

The 1986 and 1996 Safe Drinking Water Act Amendments required all states, which have primacy over their drinking water regulations, to assess every public drinking water source in their state. As a result, the U.S. Environmental Protection Agency (EPA) approved Alaska's Drinking Water Protection Program (a combination of Source Water Assessments and Wellhead Protection Programs) in April 2000. The combined program meets the statutory requirements of the State of Alaska, the Safe Drinking Water Act (SDWA), and subsequent amendments [18 Alaska Administrative Code (AAC) 80, 2002; 18 AAC 80.015, 2002]. The ADEC Environmental Health handles the administration of the program, Drinking Water Program, Anchorage, AK.

### **1.3.2 ADEC Drinking Water Program Mission**

As part of the EPA's SDWA requirements, the Alaska Drinking Water Program is responsible for requiring public water systems to supply safe drinking water for public consumption that meets minimum federal health-based standards. Alaska has had primary enforcement responsibility of the public water system supervision program (Safe Drinking Water Program) since 1978. ADEC guides owners and operators supervising the public water systems (PWS) on the design, installation, and maintenance of drinking water facilities. In addition, ADEC provides access to office files on local public drinking water systems, technical and compliance assistance, and workshops on regulatory, engineering, and drinking water public health-related issues (ADEC 2008).

### **1.3.3 Source of Drinking Water at KSDA**

KSDA is designated as a Non-Transient, Non-Community (NTNC) Public Water System. The primary source of drinking water for KSDA, King Salmon, AK, is groundwater obtained from two potable water wells. WL0B1 is the active well located near the WTP, the main water source. WL005 is a backup well located on the western side of the site, inside Building 650, that can be used for potable water if needed. The drinking water system supplies potable water to military and civilian personnel, workers, contractor personnel, and visitors to King Salmon.

#### **1.4 PAST SOURCES OF WATER SUPPLY AT KSDA**

Several potable water wells were installed in various locations on the KSDA property. Most of the wells have been abandoned; however, there is little to no documentation on how or when modifications occurred to verify proper decommissioning.

## **2.0 DESCRIPTION OF KING SALMON**

King Salmon is located on the north bank of the Naknek River near Bristol Bay on the Katmai Peninsula. KSDA is located near the village of King Salmon, approximately 15 miles upriver from Naknek, which contains the main facility of the Port of Bristol Bay. King Salmon is connected to Naknek by road and the Naknek River. King Salmon is considered remote, with transportation to the area only by airplane or boat. It is about 280 miles from Anchorage, AK.

King Salmon receives its electrical power from the Naknek Electric Association operated by the REA Cooperative. Most wastewater in the area is part of a piped sewage collection system and individual septic systems.

The BOSS Contractor, ASRC, has maintained the facilities and infrastructure in the area since October 1, 2020. Before that date, records were kept by the previous BOSS Contractor, Chugach Federal Services, Inc. (CFSI), since 2003. Current plans for the area are for continued operation under caretaker status.

### **2.1 CLIMATE**

The climate in King Salmon is considered marine, with typical moist conditions and temperature variances moderated by the Pacific Ocean. As a result, the climate is milder than expected, considering the area's latitude. The mean annual temperature is around 41 degrees Fahrenheit; the mean annual precipitation is around 19 inches. The average annual snowfall is about 44 inches. Winds typically come from the east and southeast.

### **2.2 GEOLOGY**

The terrain surrounding King Salmon is gently rolling, barren tundra with vegetation consisting of mesic to wet shrubs like alder, willow, shrub birch, and sedge tussocks. The lowland of the King Salmon area is bounded by the Kuskokwim Mountains on the north, Ahklun Mountains on the west, and the Aleutian Range to the east (USGS 1994). The nearby Aleutian Range contains peaks that exceed 7,000 feet above sea level.

Deep glacial erosion has occurred in the area, stripping surficial deposits from the underlying bedrock. This bedrock crops out mainly in the vicinity of Naknek Lake. Scattered outcrops consist of plugs, dikes, and lava flows of basaltic composition and subordinate lava flows and breccia of dacitic to andesitic composition (USGS 1994). The King Salmon area is west of Naknek Lake has few outcrops of lava flows, breccias, and lahars, interbedded with volcanoclastic sandstone, conglomerate, and shale (USGS 1994).

The surficial geology of King Salmon consists of thick unconsolidated sediment deposited during the Quaternary glaciation of the Alaska Peninsula. Till and other glacial sediments were deposited by the advance of the Mak Hill glaciation and the Brooks Lake glaciation period. The KSDA area is on outwash deposits of the Brooks Lake age that typically consist primarily of sand and silty sand, with some outwash gravel deposits (USGS 1994).

## **2.3 WATER RESOURCES**

### **2.3.1 Surface Water**

The King Salmon area is drained primarily by the Naknek River that empties into Kvichak Bay near Naknek. Several lakes, rivers, and streams are found in the area, including Eskimo Creek, which passes through the KSDA area. The lower area of the Naknek River is brackish and influenced by ocean tides up until approximately Rapids Camp. However, the probability of flooding in the area is low due to Naknek Lake's large size, which occupies most of the Naknek River drainage basin.

### **2.3.2 Groundwater**

Groundwater is the primary drinking water source in the King Salmon area, including the KSDA PWS. The area's glacial-fluvial sand and gravel deposits comprise the primary aquifer(s). The surface elevations of small lakes decrease toward the Naknek River, indicating that the direction of groundwater flow is to the south toward the river (USGS 1994). Wells in this area are drilled from about 32 feet to 300 feet. Groundwater management zones have been established for KSDA and are:



- Groundwater Zone 1 (OT027) – Base Living Area
- Groundwater Zone 2 (OT028) – Base Industrial Area
- Groundwater Zone 3 (OT029) – North and South Bluffs
- Groundwater Zone 4 (OT030) – Naknek River Storage Area
- Groundwater Zone 5 (OT031) – Landfills & Fire Training Areas
- Former Groundwater Zone 6 – Naknek Recreation Camp 1
- Naknek Recreation Camp II.

There are clay layers within these groundwater zones that separate the three aquifers, A-Aquifer, B-Aquifer, and C-Aquifer (USGS 1994). This is consistent with the well logs for the KSDA potable water wells, other contaminant studies, and monitoring well reports. Based on previous documentation, an approximate 40-foot clay layer (B-Aquitard) exists that separates the A-Aquifer (approximately 15 feet to 83 feet below ground surface) from the C-Aquifer (below 123 feet below ground surface). The potable wells for the KSDA PWS pull water from the C-Aquifer and are drilled to about 165 feet with a well screen (intake) from 143 feet to 158 feet. The active well, WL0B1, source protection area, is located within Groundwater Zone 2.

## **2.4 SUMMARY**

King Salmon is remote on the Katmai Peninsula, approximately 280 miles from Anchorage, Alaska. Groundwater is the only source of potable water for this site and is the source currently used.

### **3.0 TECHNICAL APPROACH AND METHODS**

A Source Water Assessment is comprised of three essential components that make up the technical approach and method of assessment. The first part of the assessment is delineating the protected area using an accepted means of delineation. The second is the contaminant source inventory involving many different data sources. The third is assessing the overall vulnerability of the water source to contamination.


#### **3.1 PROTECTION AREA DELINEATION**

The protection areas established for the wells are typically separated into four zones, limited by the source protection area. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well. Zones are defined as:

- Zone A –  $\frac{1}{4}$  the distance for the 2-yr. TOT
- Zone B – Less than the 2-yr TOT
- Zone C – Less than the 5-yr TOT
- Zone D – Less than the 10-yr TOT

ADEC completed the drinking water protection delineation areas for Wells WL0B1 and WL005 and last edited on 7/7/2014 according to Alaska ADEC Drinking Water Protection Area maps (Figures B-4 through B-6). This source assessment is for the active well WL0B1 since WL005 is used as a temporary backup in an emergency and a separate source protection area. These delineated protection areas are the most sensitive areas where protection efforts can have the most significant positive impact and most susceptible to adverse impacts from contaminant sources. Therefore, contaminant sources in this area must be inventoried and managed appropriately. For WL0B1, Zone A is a 100-foot radius to the south, extending in a northern direction approximately 600 feet and widening to 450 feet. Zone B commences after Zone A and continues for 1800 feet and widening to 900 feet. Zone C was not delineated.

# Alaska DEC Drinking Water Protection Areas



9/30/2021

Active Public Water System Source Locations Layer

Community Water System (C)


Non-Transient Non-Community Water System (NTNC)

Non-Community Water System (NC)

Zone A (GW-Several Months Time of Travel or SW 1000 ft buffer)

Zone B (GW-2 Yr Time of Travel or SW-1 mile buffer)


1:36,112



Alaska Department of Environmental Conservation - Division of

Figure B-5

# Alaska DEC Drinking Water Protection Areas



9/30/2021

Active Public Water System Source Locations Layer

Community Water System (C)


Non-Transient Non-Community Water System (NTNC)

Non-Community Water System (NC)

Zone A (GW-Several Months Time of Travel or SW 1000 ft buffer)

Zone B (GW-2 Yr Time of Travel or SW-1 mile buffer)


1:72,224



Alaska Department of Environmental Conservation - Division of

Figure B-4

# Alaska DEC Drinking Water Protection Areas



9/30/2021

Active Public Water System Source Locations Layer

Community Water System (C)


Non-Transient Non-Community Water System (NTNC)

Non-Community Water System (NC)

Zone A (GW-Several Months Time of Travel or SW 1000 ft buffer)

Zone B (GW-2 Yr Time of Travel or SW-1 mile buffer)

1:10,500



Alaska Department of Environmental Conservation - Division of

Goldstream Engineering, Inc.

Figure B-6

## **3.2 CONTAMINANT SOURCE INVENTORY**

The contaminant source inventory identifies potential sources of contamination associated with specific activities, industries, and land uses located within the delineated source water assessment area (Appendix B, Figure B-6).

### **3.2.1 Strategy**

Conducting an inventory of current and potential contaminant sources within the drinking water protection area defines the current and potential future risks of contamination (Appendix C, Table C-1). Existing sources (or existing contamination) are those already in the source water which have been pulled into the wells (i.e., detected in a sample).

Existing sources pose a current risk to the water supply at some level. Existing contamination may be artificial (i.e., a spill or leak) or naturally occurring (i.e., metals and nitrates dissolved in source water from the surrounding rock/soil). Potential sources (or potential contamination) may be in the source water or on the ground surface but have not reached the aquifer or well intake; potential sources have not yet contaminated the water supply. Potential sources may be a current structure or activity (i.e., an aboveground storage tank [AST] containing fuel), or it may be historic contamination in the source water that has not yet reached the water supply.

The inventory of current and potential sources at KSDA was gathered by performing fieldwork and a literature search. The fieldwork focused on visually identifying potential sources of contamination at the ground surface. The literature search focused mainly on identifying and documenting historical contamination from past activities at the station.

### **3.2.2 Fieldwork**

Fieldwork was accomplished by visual reconnaissance on 3-5 August 2021. The source protection area was surveyed by driving and walking the accessible areas and visually identifying sources of contamination. The visual reconnaissance resulted in an inventory of

contaminant sources in the WLOB1 source protection area. Inventoried sources of contamination included activities, facilities, or structures that use, produce, or store products or waste that can be released, accidentally or by design, in quantities that can significantly impact the source water quality. The contaminant source inventory is located in Appendix D.

### **3.2.3 Literature Search**

A literature search was conducted at the AFCEC Administrative Record Website and KSDA for documents, reports, and maps that contain information on the source protection area boundary. They include precipitation, surface and subsurface hydrology, the location and nature of historic contamination, and potential contaminant sources in and around the source protection area. In addition, the 611 Civil Engineer Squadron (CES) at Joint Base Elmendorf-Richardson maintains a library of information about KSDA.

Included in the internet search was the ADEC website for the ADEC Spill Prevention and Response, Contaminated Sites database that was last modified on August 17, 2021. The search focused on the location and nature of known contaminated sites at KSDA. The search results were helpful in assessing the risk to the water source.

### **3.2.4 Update**

The fieldwork and literature search data were used to consolidate lists created by USAF, USACPPM, and ADEC of contaminant sources in and around the drinking water protection area. The list was sorted by category of contaminants regulated in drinking water sources.

### **3.2.5 Ranking**

The contaminant sources were ranked according to the degree of risk posed to human health based on the volume of contaminants typically associated with the inventoried activity, facility, or structure and the toxicity, persistence, and mobility of contaminants involved. This was accomplished by comparing the inventoried source to the previous ADEC risk-ranking list to determine the rank. Five ranks are defined: very high, high, medium, low, and very low.

### 3.3 ASSESSING VULNERABILITY

The results of the contaminant source inventory, along with information about the gallery's construction and the hydrological characteristics of the source protection area, were used to assess the vulnerability of the drinking water source to contamination (Appendix C, Table C-2).

ADEC describes vulnerability: natural susceptibility + contaminant risks = vulnerability of surface water source. The components in the equation (natural susceptibility and contaminant risks) are defined by analyses that incorporate various physical/hydrological criteria, including the susceptibility of the wellhead and aquifer. The Alaska regulatory authorities have specified the criteria for the analysis. Each analysis results in a numerical score. The two numerical scores are added together to provide an overall vulnerability for the source water.

A series of flow charts (Appendix F) for conducting the vulnerability assessment and guidance on how to use the charts were provided by the ADEC. The charts provide a structure for evaluating numerous criteria associated with each analysis. Natural susceptibility was assessed by applying the ADEC criteria and using the charts provided by the ADEC to obtain numerical scores for each analysis.

The procedure for evaluating contaminant risk is somewhat different. Six major categories of contaminants are regulated for drinking water sources by the State of Alaska (Appendix C, Table C-1). Contaminant risk was assessed by progressing through the charts six times, once for each category of contaminants, providing a numerical score for each category of contaminant. Then, numerical scores for each of the two analyses (natural susceptibility and contaminant risks) were combined to provide an overall vulnerability for the water source.



## **4.0 SOURCE PROTECTION AREA AND WATER SUPPLY SYSTEM**

### **4.1 CURRENT WATER SUPPLY**

#### **4.1.1 System Information**

The current source for the public water system at KSDA is groundwater. The following description of the current system comes from field observations during the August 3-5, 2021, period and desktop research.

#### **4.1.2 Class and Identification**

The ADEC has identified the KSDA PWS as a non-transient, non-community, groundwater, public water source. The Public Water System Identification (PWSID) number is 260503. The PWS supplies potable water for human consumption, including cooking and bathing.

#### **4.1.3 Owner/Operator**

The USAF owns the water system, 611th CES/CEAN 10471 20<sup>th</sup> Street, Suite 337, Joint Base Elmendorf-Richardson, AK, 99506-2200, telephone: (907) 552-5655. Jessica Morris is the 611th CES Water Compliance Manager at Joint Base Elmendorf-Richardson. It is operated and maintained under contract by ASRC as of October 1, 2020. We understand that there was not an ASRC Environmental Manager at the time of our evaluation. The ASRC KSDA Site Operations Manager/Fire Chief is Jason McMichael, and the certified water system operator is Roy Chelf.

#### **4.1.4 Status and Operation of Water System**

The water system status was active during the field investigation for this study. The system operates every day throughout the year. The contractor, ASRC, employs a minimum of one certified water treatment operator onsite at all times.

#### **4.1.5 System Modifications**

Modifications to the system have occurred periodically over the years of the water system's existence. It appears that ADEC has approved these modifications.

#### **4.1.6 Groundwater Collection System**

The active well and primary source for the PWS is Well WL0B1, located next to the WTP (Building 303). The 6-inch diameter well with a bentonite seal pulls water from the C-Aquifer and is drilled to about 165 feet with a well screen (intake) from 143 feet to 158 feet. The static water level is approximately 19 feet below grade, indicating artesian conditions. Water is pumped through a 2-inch HDPE below-grade water line to the WTP. The backup well is WL005, located inside Building 650, and is maintained for use if needed. Based on the well log, WL005 is an 8-inch diameter well that also appears to pull water from C-Aquifer and drilled to a depth of 237 feet. Again, the static water level was noted at 35 feet below grade.

#### **4.1.7 Treatment**

The raw water is pumped from well WL0B1 to the WTP where the water enters four 30-inch diameter by 72-inch-tall Granulated Activated Carbon (GAC) tanks operated in parallel. The water lines inside the WTP consist mainly of a 4-inch PVC pipe. Three pressure tanks are located before the GAC tanks to maintain pressure throughout the treatment process without short cycling the well pump. Water is then injected with sodium hypochlorite generated from the MIOX unit and enters two contact chambers for iron and manganese oxidation. After the contact chambers, water enters four 30-inch diameter by 87-inch tall Macrolite tanks operated in parallel for iron/manganese removal. Backwash for the GAC and Microlite tanks enters a floor drain with an air gap. The floor drain is connected to a soil absorption system

approximately 105 feet from the WTP. After treatment, filtered water is injected again with sodium hypochlorite generated from the MIOX unit then conveyed through a 4-inch ductile iron pipe to Building 638, where the water storage tanks are located.

#### **4.1.8 Storage**

After treatment, water is pumped to Building 638, where the storage tanks are located. There are two tanks, ST001 and ST002, that are almost identical and operated parallel. Each storage tank has a 25,000-gallon holding capacity. The well pump is the only pump used in the system, and these storage tanks are pressure vessels, operated more like pressure tanks. From these tanks, water enters the distribution system. In addition, there is a large Fire Suppression Storage Tank located outside of Building 138 that is filled by a manually operated valve located inside Building 138.

#### **4.1.9 Distribution System**

There are no additional distribution pumps as the well pump produces pressure and flow for the PWS. Water is pumped through the distribution system to the buildings where people work, eat, and sleep. Detailed maps, pipe material, and sizing information are kept at the station for review. Many of the buildings that are not actively being used have been disconnected from service to cut down on the occurrence of dead-end piping.

#### **4.1.10 Connections**

There are at least 12 service connections associated with the distribution system, including but not limited to the facility headquarters, contractor's offices, fire station, gym, hangars, warehouses, office buildings, shops, fire pump stations, dormitories, and communication buildings. This number will likely reduce in the future as buildings are disconnected and demolished.

#### **4.1.11 Cross Connection Control Program**

There is an active cross-connection control program that was available at the time of the August 3-5, 2021, onsite investigation. A cross-connection control survey of the devices and the program has been performed. The PWS operator, Roy Chelf, is also certified to test the backflow prevention devices onsite and does this yearly.

#### **4.1.12 Population Served**

The population consists of 4 residents, 20 non-transients, and 15 transients, for 39 people. It is possible that during a military exercise, the population could increase up to 100 people for a week period, but these exercises are not a common occurrence. The entire population on KSDA is present for work purposes.

#### **4.1.13 Water Use**

Workers and visitors use the water in the buildings for consumption, cooking, washing, cleaning, firefighting, and other potable purposes. ADEC reports water pressure, quantity, and quality to comply with current regulations.

#### **4.1.14 Contingency Plan**

Due to the isolation of the C Aquifer, the likelihood of an accidental release of a contaminant reaching the well intake is moderately low. Therefore, the main challenge presented onsite is the loss of power. Power outages in this area are common, and the water system can maintain at least 20 psi during these short-duration outages. According to site personnel, KSDA does not have any backup generators connected to water system components to provide power during extended outages. If contaminants enter the water source aquifer and cannot be treated or removed by the existing treatment components, the water system will need to be evaluated at that time. KSDA currently has ample stored potable water in the water storage tanks and a stored supply of bottled water that could be utilized in the event of a short-term interruption of water production. Additional bottled water would be flown/barged to Naknek and transported to KSDA to meet immediate and interim needs.

#### **4.1.15 Emergency Response Plan**

In the event of a catastrophe, the main challenge will be the loss of power since power is provided by the Naknek Electric Association operated by the REA Cooperative. There were generators observed onsite, but site personnel indicates that they are not connected to any water system components. The water storage tanks will likely supply pressure to most facilities for a short duration. Alternatively, valves could be closed, and the storage tanks could be used only to fill potable water containers for drinking water purposes. Stored bottled water may also be kept onsite and used. Several barges and flights in the summer months access King Salmon/Naknek areas, so receiving supplies should be less challenging. In the winter months, acquiring supplies is more challenging. Few public water systems in this area have their own backup generators to operate their water system and cannot be relied upon for emergency water. It is suggested that the drinking water emergency plan be re-examined and updated as necessary. It is recommended that the base continue storing bulk and bottled water on site.

#### **4.2 SUMMARY**

The system has undergone modifications throughout its existence to meet the needs of the USAF and has been maintained to meet permit and regulatory standards. The current system is being appropriately maintained but requires periodic adjustments and modifications to meet changing ADEC requirements and modernized equipment. The ADEC refers to this system as a non-community / non-transient public water system with the PWSID 260503 and has designated the source as groundwater. Currently, the system typically serves about 39 people, although it can increase up to 100 people for a short duration (week) during a military exercise. The potable water is treated, disinfected, stored in tanks, and distributed to various buildings throughout the area.

## **5.0 INVENTORY OF CONTAMINANT SOURCES**

Potential, current, and historical sources of contamination were inventoried (Appendix D), and the locations of all inventoried sources were mapped (Figures B-6). Both onsite fieldwork and a records search were used to create the inventory. Potential sources of contaminants were inventoried because they represent the possibility of future contamination. There were no Current or Historical sources of contamination documented within the source protection area of C-Aquifer within the source protection area. However, it has been documented that contamination is present in the A-Aquifer and B-Aquifer of Groundwater Zone 2.

### **5.1 POTENTIAL SOURCES OF CONTAMINATION**

Potential sources of contamination are defined as those that pose a future risk to the drinking water source. For example, an AST that has never leaked is not a current source of contamination, but the tank can leak in the future. Therefore, the tank presents a potential for future contamination.

Potential sources of contamination are mainly associated with the use of three buildings (Buildings 327, 335, and the UAF Shed). In addition, the unpaved roads that traverse the source protection area, the leach field for the water treatment backwash, and the existing contamination that has been found within the A-Aquifer in Groundwater Zone 2. Section 5.2 further details potential sources of contamination. Buildings 327 and 335 have been abandoned and are pending demolition. The UAF Shed consists of electronics that support the UAF Antenna Array.

Dirt/gravel roads run through Zones A and B of the drinking water source protection area. Therefore, there is the possibility of spills contamination due to a transportation incident, releasing hazardous materials directly to the ground and infiltrating downward to groundwater. These spills have the potential to contaminate A-Aquifer and possibly B-Aquifer. However, it is unlikely that contaminants from a spill will reach the intake of the well due to the water source coming from C-Aquifer based on the information we have at the time.

Previous studies indicate that A-Aquifer in Groundwater Zone 2 is contaminated with trichloroethene (TCE), benzene, toluene, ethylbenzene, xylenes, gasoline range organics

(GRO), and recent studies are ongoing to evaluate PFAS and PFC's. Previous studies also indicate hydraulic communication through the aquitard that separates the A-Aquifer and B-Aquifer in Groundwater Zone 1. Since the soil characteristics are relatively similar to Groundwater Zone 2, the same conditions likely occur in Groundwater Zone 2.

Two monitoring wells are located inside the source protection area, CF5MW1901 and MW-707 (near drinking water source well WL0B1). CF5MW1901 consists of a 2-inch diameter PVC casing installed to a depth of approximately 25 feet (A-Aquifer). MW-707 consists of a 2-inch diameter PVC casing installed to a depth of approximately 29 feet (A-Aquifer). We could not find sample data from these two monitoring wells to verify contamination of A-Aquifer within the source protection area. There are no monitoring wells in B-Aquifer or C-Aquifer within the source protection area to verify contamination. No raw water sample results we found for the drinking water well WL0B1.

A leach field that disposes of the backwash water from the water treatment plant is located approximately 105 feet from WL0B1. This leach field is considered a Class V Injection Well based on EPA's definition; "A Class V Injection Well is used to inject non-hazardous fluids underground." This leach field is installed inside the A-Aquifer.

## **5.2 HISTORIC SOURCES OF CONTAMINATION**

Historical sources of contamination are defined as sources that have already contaminated the surface or subsurface, particularly groundwater. These situations have usually been discovered and documented, the source removed, and the contamination has typically undergone some form of remediation. For the WL0B1 drinking water protection area, no recorded historical sources of contamination were found in the C-Aquifer.

## 6.0 SORTING AND RANKING CONTAMINANT SOURCES

Potential and historical sources of contamination were sorted and ranked according to the type and level of risk they present. Contaminant sources were sorted into six categories regulated for drinking water sources and then ranked from very high to low.

Contaminant sources were ranked based on guidance from the State of Alaska. In situations where no guidance was given, professional judgment was used. For example, the State of Alaska does not guide ranking contaminated sites or groundwater monitoring wells that may define the lateral and vertical extent of contamination at a site. Therefore, professional judgment was used to rank these contaminant sources based on four factors:

- The lateral and vertical extent, plus the nature and magnitude of the contamination
- The toxicity and volumes associated with a given source
- The number and density of contaminant sources
- The proximity of sources to the infiltration gallery

The six major categories of contaminants are bacteria and viruses, nitrites and nitrates, VOC, heavy metals, synthetic organic contaminants (SOC), and other organic contaminants (OOC). These contaminant categories and the possible sources are listed in Table C-1.

### 6.1 SORTING CONTAMINANT SOURCES

Contaminant sources were sorted into six categories (Table C-1). The results of the sorting produced six tables of inventoried contaminant sources. Each table is for one category of regulated drinking water contaminants.

**Table C-1. Six Major Categories of Contaminants Regulated for Drinking Water Sources.**

<b>CONTAMINANT CATEGORY</b>	<b>POSSIBLE SOURCE</b>
1. Bacteria/Viruses	Sewage lagoons, septic systems
2. Nitrates/Nitrites	Septic systems, fertilizers, manure piles
3. Volatile Organic Chemicals	Gasoline, fuels, heating oil
4. Heavy Metals	Inorganic chemicals, cyanide, landfills
5. Synthetic Organic Chemicals	Agricultural fields, utility easements, fuels
6. Other Organic Chemicals	Transformers, crude oil, industrial sources



## **6.2 RANKING CONTAMINANT SOURCES**

Contaminant sources were ranked based on the risk criteria mentioned above. Four risk ranks are defined by ADEC: very high, high, medium, and low. All potential sources of contamination received a low score for each risk criteria listed.

## **6.3 SUMMARY**

Potential and historic contamination sources at KSDA were sorted into six categories regulated for drinking water sources, then ranked from very high to low risk. Only the sources in Zones A and B were sorted and ranked. The historical sources of contamination were based on water sampling data that we received from ADEC; however, the data may not be from the raw water itself. Each potential source of contamination received a low-risk score.

## 7.0 VULNERABILITY OF DRINKING WATER SOURCE

Vulnerability is a combination of the natural susceptibility and contaminant risks to the drinking water source. The natural susceptibility is the sum of the wellhead and aquifer susceptibilities. The susceptibility of the wellhead is assessed by looking at the construction of the well and its surrounding area. The susceptibility of the aquifer is assessed by looking at naturally occurring attributes of the water source and influences on the groundwater system that might lead to contamination. Contaminant risks range from a value of 0 (no contaminant risk) to 50 (maximum contaminant risk). The equation used to determine natural susceptibility is:

$$\text{Susceptibility of the Wellhead (0 to 25 points) + Susceptibility of the Aquifer (0 to 25 points) = Natural Susceptibility (0 to 50 points)}$$

Contaminant risks to a drinking water source depend on the type, density, and distribution of sources. A score of 0 to 50 points is assigned based on the findings of the existing and historical contaminant risks identified in the contaminant risk inventory. Contaminants are separated into six categories, Bacteria/Viruses, Nitrates/Nitrites, Volatile Organic Chemicals, Heavy Metals, Synthetic Organic Chemicals, and Other Organic Chemicals. The equation used to determine the overall vulnerability rating for each category is:

$$\text{Natural Susceptibility (0 to 50 points) + Contaminant Risks (0 to 50 points) = Overall Vulnerability (0 to 100 points)}$$

The overall vulnerability score is as follows:

80 to 100 pts	Very High
60 to <80 pts	High
40 to <60 pts	Medium
<40 pts	Low

### 7.1 VULNERABILITY ASSESSMENT

A series of charts for conducting the vulnerability assessment on the water source was provided by the ADEC. These charts are presented in Appendix F. Chart F-1 shows the susceptibility of the wellhead, and Chart F-2 shows the susceptibility of the aquifer, which sum to be the natural susceptibility. The vulnerability to each category of regulated contaminants is shown in charts F-3a to F-8d.

## **7.2 NATURAL SUSCEPTIBILITY**

The susceptibility of the wellhead score was 0 (low) primarily due to the well-being capped and not located within a flood plain. The surface sloped away from the well, and the well was documented as adequately grouted (see Chart F-1). The susceptibility of the aquifer score was 8 (low), mostly due to the thickness of the two aquitards that separate the drinking water aquifer from contamination in the A-Aquifer. These total a natural susceptibility score of 8 points (see Chart F-2). Based on guidance from the ADEC, this score means a low natural susceptibility to contamination.

## **7.3 VULNERABILITY TO BACTERIA /VIRUSES**

A water source's vulnerability to bacteria and virus contamination is usually attributed to wastewater release through sewage lagoons or septic systems.

### **7.3.1 Vulnerability Scoring**

The overall source water score for vulnerability to bacteria/viruses is 10, with a rating of low (see Charts F-3a through F-3c). The low score results from a low natural susceptibility plus a low risk for bacteria/viruses. There did not appear to be any sewage lagoons or septic systems located within the source protection area. However, there is some uncertainty about the bacteria/viruses contaminant risk, mainly regarding the previous use of buildings 327 and 335, located in Zone B. These buildings have been abandoned and are pending demolition. In addition, the roads within the source protection area are open to the public. Therefore, it is unclear what contaminants may be transported.

A leach field is located approximately 80 feet away from the well that is used to dispose of the backwash water from the water treatment plant. Although technically located outside of the source protection area, it was included due to the proximity to the well. Therefore, it is unlikely that this soil absorption system will increase the risks.

## **7.4 VULNERABILITY TO NITRATES/NITRITES**

A water source's vulnerability to nitrates and nitrites contamination is usually attributed to septic systems, fertilizers, and animal manure piles.

### **7.4.1 Vulnerability Scoring**

The overall source water score for vulnerability to nitrates/nitrites is 10, with a low rating (see Charts F-4a through F-4d and Table C-2). The low score results from a low natural susceptibility plus a low risk for nitrates/nitrites. There did not appear to be any sewage lagoons or septic systems located within the source protection area. There is uncertainty about the nitrates/nitrites contaminant risk, mainly regarding the previous use of buildings 327 and 335, located in Zone B. These buildings have been abandoned and are pending demolition. In addition, the roads within the source protection area are open to the public. Therefore, it is unclear what contaminants may be transported. A leach field is located approximately 80 feet away from the well used to dispose of the backwash water from the water treatment plant. Although technically located outside of the source protection area, it was included due to the proximity to the well. It is unlikely that this soil absorption system will increase the risk to the well.

## **7.5 VULNERABILITY TO VOLATILE ORGANIC COMPOUNDS**

A water source's vulnerability to VOC contamination is usually attributed to a spill of gasoline, fuels, or heating oil in the source protection area.

### **7.5.1 Vulnerability Scoring**

The overall source water score for vulnerability to VOC is 10, with a rating of low (see Charts F-5a through F-5d and Table C-2). The low score results from a low natural susceptibility plus a low risk for VOC. There did not appear to be any fuel tanks inside the source protection area. However, several roads within the source protection area are open to the public; therefore, it would be difficult to control the possibility of a fuel leak during transportation. TCE, BTEX, and other contaminants have been documented in A-Aquifer.

## **7.6 VULNERABILITY TO HEAVY METALS, CYANIDE, AND OTHER INORGANIC CHEMICALS**

A water source's vulnerability to heavy metals contamination is usually attributed to inorganic chemicals, cyanide, and landfill leaching.

### **7.6.1 Vulnerability Scoring**

The overall source water score for vulnerability to heavy metals is 10, with a low rating (see Charts F-6a through F-6d and Table C-2). The low score results from a low natural susceptibility plus a low risk for heavy metals. There did not appear to be any landfills or other potential sources located inside the source protection area; however, several roads within the source protection area are open to the public. Therefore, it would not be easy to control the contaminants that may be transported.

## **7.7 VULNERABILITY TO SYNTHETIC ORGANIC CONTAMINANTS**

The overall source water score for vulnerability to SOC's is 10, with a rating of low (see Charts F-7a through F-7d and Table C-2). The low score results from a low natural susceptibility plus a low risk for SOC's. There did not appear to be any potential sources inside the source protection area. However, several roads within the source protection area are open to the public; therefore, it would be difficult to control the contaminants that may be transported. PFAS has been documented within the A-Aquifer in Groundwater Zone 2. There are ongoing efforts to determine the sources and extent of the contamination.

## **7.8 VULNERABILITY TO OTHER ORGANIC CONTAMINANTS**

The overall source water score for vulnerability to OOC's is 10, with a rating of low (see Charts F-8a through F-8d and Table C-2). The low score results from a low natural susceptibility plus a low risk for OOC's. There did not appear to be any potential sources within the source protection area. However, there are roads open to the public.

## **7.9 OPTIMIZING ONGOING ACTIVITIES**

The source water assessment results can be used to optimize ongoing activities that have the potential to affect the quality of the drinking water source.

## **7.10 FUTURE VULNERABILITY**

Although the air station is currently in caretaker status, there are ongoing activities at the facility. Therefore, with continuing activities at KSDA, conditions, structures, activities, and potential sources of contamination may change.

The State of Alaska recommends source water assessment updates for active facilities every 5 years following initial assessments to reflect changes in local conditions. Therefore, it would be prudent to update this source water assessment in 5 years to reflect any changes in local conditions. For example, if buildings 327 and 335 are demolished and removed, this may reduce the overall assessment or may also increase depending on if any contamination is found.

## **7.11 CONTINGENCY WATER SUPPLY**

The backup well WL005 may be used as a contingent water source. Although the water source was not included in this source water assessment, more potential sources of contamination likely exist for this well. Water stored inside the storage tanks could be used when there is a power loss. If both wells become contaminated with contaminants that the existing treatment system cannot remove, bottled water may be used. More bottled water could also be flown or barged in to supplement the existing supply.

## **7.12 SUMMARY**

The overall vulnerability of the KSDA source water is judged to be low. The well appears to have been constructed properly, and it is currently being maintained to protect the water. There are very few potential sources of contamination within the source protection area designated by ADEC for the active well. Additionally, the water source is further protected by two aquitards that protect the aquifer used for drinking water from potential surface contaminants. As time goes on, the future vulnerability of the source water may change.

## **8.0 RESULTS COMMUNICATION**

It is essential that the owners/operators of the water system, consumers of the water produced by the system, and anyone who can preserve or compromise the quality of the water in the system receive the results of this assessment.

### **8.1 USAF COMMUNICATION**

Most of these people are USAF personnel and their contractors at Joint Base Elmendorf-Richardson and KSDA. Because of this, it is recommended that Table C-2 (the susceptibility/vulnerability results for the source protection area and raw water source) be published in the CCR.

### **8.2 PUBLIC COMMUNICATION**

Typically, Source Water Assessments are distributed to water system owners and operators, local governments, and other entities interested in preserving the quality of the water supply. In addition, the results are posted on the ADEC Drinking Water Protection Program website ([www.state.ak.us/dec/water/source](http://www.state.ak.us/dec/water/source)) and placed on reserve at a local library in the area of the water system. This document may be distributed to the public to meet the goals of Alaska's drinking water program; however, the document is often only summarized for the public due to security concerns. It is recommended that direct coordination with the ADEC be conducted to determine the appropriate public communication.

## **9.0 SUMMARY**

### **9.1 WATER SUPPLY**

Groundwater wells are the source of public drinking water for the area. There is currently WL0B1, the active well located near the water treatment plant. In addition, a backup well (WL005) is located near the water storage tanks. The system is classified as groundwater. The water system is owned by the U.S. Air Force and operated by Arctic Slope Regional Corporation (ASRC under contract to provide Base Operational Support Services (BOSS). ADEC identified the drinking water source protection areas divided into Zone A and Zone B. Therefore, we have no reason to suspect the source water protection area was done incorrectly.

### **9.2 DRINKING WATER PROTECTION AREA**

The drinking water protection area was identified by ADEC in 2014 and consisted of two zones, Zone A and Zone B. As displayed in Appendix B, Figure B- 6, the source protection area boundary is believed to be hydrologically correct and is the boundary used for this source water assessment.

### **9.3 CONTAMINANT SOURCES**

Potential and historical sources of contamination were inventoried, sorted, and ranked according to the type and level of risk they present. Contaminant sources were sorted into six categories regulated for drinking water sources and then ranked very high to very low. Very few potential sources were found.

### **9.4 VULNERABILITY ASSESSMENT**

Potential, current, and historic sources of contamination were evaluated for the level of threat posed to the drinking water source. In addition, the susceptibility of the wellhead and aquifer was also assessed and collectively known as the natural susceptibility of the source water.



The overall vulnerability of the KSDA source water is judged to be low. The well appears to have been constructed correctly, and it is currently being maintained to protect the water. There are very few potential sources of contamination within the source protection area designated by ADEC for the active well. Additionally, the water source is further protected by two aquitards that protect the aquifer used for drinking water from potential surface contaminants. As time goes on, the future vulnerability of the source water may change. Therefore, updating this source water assessment further in the future may be prudent.

## **9.5 COMMUNICATION**

In order to meet the regulatory requirements of notification to the public about the water source, the Executive Summary of the Source Water Assessment should be published in the annual Consumer Confidence Report (CCR). It is recommended that Table C-2 (the susceptibility vulnerability results for the source protection area and raw water source) and Figure B-1 (the source protection area map) be published in the CCR.

## 10.0 RECOMMENDATIONS

- Should abandoned Buildings 327 and 335 be demolished, any contaminants found during demolition should be reported and evaluated as a potential source of contamination to the well WL0B1.
- We understand that a well is located at Buildings 327/335, which may have been used to provide water to these buildings. Little information is known about this well, such as the construction or depth. We recommend well testing to verify the depth and water samples collected to verify the presence of contamination at the source intake depth. This well may be upgradient from WL0B1, and could potentially be an indicator of future challenges that may be experienced at the active well WL0B1, especially if they are in the same aquifer.
- Place signs that restrict fuel trucks and other hazardous materials from traveling within 200 feet of well WL0B1.
- Coordinate directly with ADEC to determine appropriate public communication. Typically, this assessment is included in the yearly Consumer Confidence Report.
- Publish the Executive Summary, Table C-2, and Figure B-6 in the Consumer Confidence Report (CCR).
- Re-examine the drinking water emergency plan for adequacy.
- Collect raw water samples from WL0B1 every year for contaminants found in A-Aquifer in Groundwater Zone 2.
- Additional monitoring wells that may be potentially installed within the source protection area of Well WL0B1 should be carefully evaluated and designed to protect the groundwater.
- All wells that access the B or C-Aquifers that are not in use should be properly decommissioned. Re-evaluate Drinking Water Source Area in five years.
- A Source Water Assessment should be completed for the Emergency Backup Well WL005.
- Additional recommendations regarding the water system are included in the KSDA PWS Recommendation Letter submitted October 27, 2021, by Goldstream Engineering, Inc.

## 11.0 REFERENCES

- ADEC (Alaska Department of Environmental Conservation). 2021. *Contaminated Site Database, Site Reports*.
- ADEC. 2021. *Mission and Services*.
- ADEC. 2001. *Alaska Drinking Water Protection Program: Guidance Manual for Class A (Community and Non-transient Non-community) Public Water Systems - Guidance on the Completion and Meaning of Source Water Assessments and Options for the Protection of Public Drinking Water Sources, Drinking Water and Wastewater Program*. 555 Cordova Street, Anchorage, AK 99501, (907) 269-7647.
- USGS (U.S. Geological Survey). 1994. *Overview of Environmental and Hydrogeologic Conditions at King Salmon, Alaska*, Open-File Report 94-323, prepared by Christopher F. Waythomas in Cooperation with the Federal Aviation Administration.
- E.A. Engineering, Science, and Technology, Inc. 2014. *Follow-On Investigation at Site OT027 Report. King Salmon Air Station, Alaska*. AR547430
- CH2M Hill. March 2018. *Preliminary Assessment Report for Perfluorinated Compounds. King Salmon Divert, Alaska*. AR608532
- Jacobs Engineering Group Inc. September 2020. *Expanded Remedial Investigations: Groundwater Zones 2 (OT028) and 5 (OT031) and Source Area and Remedy Evaluation: Lower Naknek River Storage Area Site (SS012 Lower)*. AR608553
- Jacobs Engineering Group Inc. April 2021. *Groundwater Zones 1 and 2 Aqueous Film-Forming Foam Remedial Investigation Work Plan*. AR608571
- Paug-Vik Contractors, LLC. March 2021. *Monitoring Well Survey. King Salmon Divert, Alaska*.

## PERSONNEL CONTACT LIST

Jessica Morris, USAF, 611 CES/CEPT, 10471 20<sup>th</sup> Street Suite 315, Joint Base Elmendorf-Richardson, AK 99506, commercial: 907-552-5655, DSN: 317-552-5655, Jessica.morris.14@us.af.mil

Charley Palmer, ADEC, 555 Cordova St., Anchorage, AK 99501, 907-269-0292

Chris Miller, ADEC, Hydrogeologist, 555 Cordova St., Anchorage, AK, 907-269-7549

Roy Chelf, Water Plant Operator, 100 Silver Street, King Salmon, AK 99613. 907-721-3050. [rchelf@asrcfederal.com](mailto:rchelf@asrcfederal.com)

Jason McMichael, site Operation Manager/Fire Chief, 100 Silver Street, King Salmon, AK 99613. 907-721-3001. [jmcmichael@asrcfederal.com](mailto:jmcmichael@asrcfederal.com)

Col. Paul Cornwell, 10471 20<sup>th</sup> Street, Suite 265, Joint Base Elmendorf-Richardson, AK, commercial: 907-552-3442

## **APPENDIX A**

### **Photo Log**



Photo No. 1 WL0B1 and WTP Looking West



Photo No. 2  
WL0B1 and WTP Looking East



Photo No. 3 WL0B1 and WTP  
Looking Northeast



Photo No. 4 Soil Absorption  
System near WTP for the GAC &  
Microlite Filter Backwash  
View Looking Northwest



Photo No. 5 Monitoring Well 707 in  
front of WL0B1 and WTP  
View Looking East



Photo No. 6 Source Protection Area  
View Looking South






Photo No. 7 Typical Building Double Walled Fuel Tank – Outside of Source Protection Area  
View Looking Northeast



Photo No. 8 Building 327 and 335  
View Looking Northwest

## **APPENDIX B**

### **Figures**



THIS VICINITY MAP IS FOR REFERENCE ONLY AS PART OF THE 2021 SANITARY SURVEY.

Figure B-1




**GOLDSTREAM ENGINEERING**  
 CIVIL ★ ENVIRONMENTAL ★ STRUCTURAL  
 PERMITTING ★ DESIGN ★ PROJECT MANAGEMENT  
 WWW.GOLDSTREAMENGINEERING.COM  
 (907) 450-0563 FAX: (907) 450-0564

USAF KING SALMON  
 VICINITY MAP  
 2021 SANITARY SURVEY

DATE:	8/16/2021
PROJ MGR:	AH
DRAWN:	AH



C1




**ACTIVE WELL WLOB1**  
SCALE: 1"=150'

Figure B-2

THIS VICINITY MAP IS FOR REFERENCE ONLY AS PART OF THE 2021 SANITARY SURVEY.




**BACKUP WELL WL005**  
SCALE: 1"=150'



THIS VICINITY MAP IS FOR REFERENCE ONLY AS PART OF THE 2021  
SANITARY SURVEY.

Figure B-3

# Alaska DEC Drinking Water Protection Areas




9/30/2021

Active Public Water System Source Locations Layer

- ⊕ Community Water System (C)
- Non-Transient Non-Community Water System (NTNC)

- Non-Community Water System (NC)
- Zone A (GW-Several Months Time of Travel or SW 1000 ft buffer)
- Zone B (GW-2 Yr Time of Travel or SW-1 mile buffer)


1:72,224



by Alaska Department of Environmental Conservation - Division of

Figure B-4

# Alaska DEC Drinking Water Protection Areas



9/30/2021

Active Public Water System Source Locations Layer

Community Water System (C)


Non-Transient Non-Community Water System (NTNC)

Non-Community Water System (NC)

Zone A (GW-Several Months Time of Travel or SW 1000 ft buffer)

Zone B (GW-2 Yr Time of Travel or SW-1 mile buffer)


1:36,112



Alaska Department of Environmental Conservation - Division of

Figure B-5

# Alaska DEC Drinking Water Protection Areas




9/30/2021

Active Public Water System Source Locations Layer

- ⊕ Community Water System (C)
- Non-Transient Non-Community Water System (NTNC)

- Non-Community Water System (NC)
- Zone A (GW-Several Months Time of Travel or SW 1000 ft buffer)
- Zone B (GW-2 Yr Time of Travel or SW-1 mile buffer)

1:10,500



Alaska Department of Environmental Conservation - Division of

Goldstream Engineering, Inc.

Figure B-6



## **APPENDIX C**

### **Tables**

**Table C-1. Six Major Categories of Contaminants Regulated for Drinking Water Sources.**

<b>CONTAMINANT CATEGORY</b>	<b>POSSIBLE SOURCE</b>
1. Bacteria/Viruses	Sewage lagoons, septic systems
2. Nitrates/Nitrites	Septic systems, fertilizers, manure piles
3. Volatile Organic Chemicals	Gasoline, fuels, heating oil
4. Heavy Metals	Inorganic chemicals, cyanide, landfills
5. Synthetic Organic Chemicals	Agricultural fields, utility easements, fuels
6. Other Organic Chemicals	Transformers, crude oil, industrial sources

**Table C-2. Summary of Susceptibility /Vulnerability Scores and Ratings for the Water Supply Source Protection Area, KSDA, AK.**

	<b>Vulnerability Score (points)</b>	<b>Vulnerability Rating</b>
WELLHEAD SUSCEPTIBILITY	0	Low
AQUIFER SUSCEPTIBILITY	8	Low
<b>CONTAMINANT RISKS</b>		
1. Bacteria/viruses	10	Low
2. Nitrates/nitrites	10	Low
3. Volatile organic chemicals	10	Low
4. Metals, cyanide, other inorganics	10	Low
5. Synthetic organic chemicals	10	Low
6. Other synthetic organic chemicals	10	Low
<b>OVERALL VULNERABILITY</b>	10	Low

NOTE: wellhead susceptibility + aquifer susceptibility + contaminant risks = vulnerability.

## **APPENDIX D**

### **Inventory**

### APPENDIX D CONTAMINANT SOURCE INVENTORY

**TABLE D-1. CONTAMINANT SOURCE (CS) INVENTORY, PWSID 260503, KSDA, AK**

CS Category <sup>1</sup>	CS ID <sup>2</sup>	CS ID tag <sup>3</sup>	Zone <sup>4</sup>	Location <sup>5</sup>	Source of Information	Comments
<b>Current contaminant sources</b>						
None	N/A	N/A	A & B	N/A	ADEC Contaminated Sites Database	No historical contamination is noted within the WL0B1 Source Protection Delineation Area.
<b>Historical contaminant sources – monitoring wells</b>						
None	N/A	N/A	A & B	N/A	ADEC Contaminated Sites Database	No historical contamination is noted within the WL0B1 Source Protection Delineation Area.
Monitoring Well CF5MW1901	W6	1	A	Approximately 300 feet from WL0B1	AFC Admin Record	No data found on sample results
Monitoring Well MW-707	W6	2	A	Near WL0B1 well	AFC Admin Record	No data found on sample results
<b>Historical contaminant sources – source areas</b>						
None	N/A	N/A	A & B	N/A	ADEC Contaminated Sites Database	No historical contamination is noted within the WL0B1 Source Protection Delineation Area.
<b>Potential contaminant sources</b>						
Injection Well (Class V)	D10	3	A	105 feet from WTP	Onsite Observations	Backwash water disposal from GAC and Microlite filters.
Dirt/gravel roads	X24	4	A, B	Approximately 0.25 miles of gravel road in source protection area.	Onsite Observations	Beluga Blvd. and Shooting Range Rd.
UAF Shed	X27	5	B	800 feet from WL0B1	Onsite Observations	Small shed that contains communication equipment for the University of Alaska Fairbanks to support the antenna array.
Buildings 327 and 335	X27	6	B	1800 feet from WL0B1	Onsite Observations	Building is abandoned, no longer in use, and pending demolition.
GZ2 – A-Aquifer Contamination		7	A, B	Varies, throughout	AFC Admin Record (referenced in report)	Existing contamination may be present in A-Aquifer within source protection area.

NOTES: 1. Categories are established by contaminant source numbers in Figure 6.

2. Contaminant source identification numbers (CS ID) are established by ADEC. These numbers correspond to 4. Zones A and B defined in Figure 6. 5. See Figures 1-6.

USAF KSDA, Alaska, March 2022

[THIS PAGE INTENTIONALLY LEFT BLANK]

## **APPENDIX E**

### **Inventory Ranking**

**APPENDIX E  
CONTAMINANT SOURCE SORTING AND RANKING**

**TABLE E-1. CS RANKING – SOURCES OF BACTERIA AND VIRUSES, KSDA, AK**

<b>C.S. Category <sup>1</sup></b>	<b>CS ID <sup>2</sup></b>	<b>CS ID tag <sup>3</sup></b>	<b>Zone<sup>4</sup></b>	<b>Location <sup>5</sup></b>	<b>Risk Ranking</b>	<b>Comments</b>
Injection Well (Class V)	D10	3	A	105 feet from WTP	Low	Not a significant source of bacteria/viruses.
Dirt/gravel roads	X24	4	A, B	Approximately 0.25 miles of gravel road in source protection area.	Low	Not a significant source of bacteria/viruses.
UAF Shed	X27	5	B	800 feet from WL0B1	Low	Not a significant source of bacteria/viruses.
Buildings 327 and 335	X27	6	B	1800 feet from WL0B1	Low	No longer in use, not a significant source of bacteria/viruses.
GZ2 – A-Aquifer Contamination		7	A, B	Varies, throughout	Low	Not a significant source of bacteria/viruses.

**TABLE E-2. CS RANKING – SOURCES OF NITRATES/NITRITES, KSDA, AK**

<b>C.S. Category <sup>1</sup></b>	<b>CS ID <sup>2</sup></b>	<b>CS ID tag <sup>3</sup></b>	<b>Zone<sup>4</sup></b>	<b>Location <sup>5</sup></b>	<b>Risk Ranking</b>	<b>Comments</b>
Injection Well (Class V)	D10	3	A	105 feet from WTP	Low	Not a significant source of Nitrates/Nitrites.
Dirt/gravel roads	X24	4	A, B	Approximately 0.25 miles of gravel road in source protection area.	Low	Not a significant source of Nitrates/Nitrites.
UAF Shed	X27	5	B	800 feet from WL0B1	Low	Not a significant source of Nitrates/Nitrites.
Buildings 327 and 335	X27	6	B	1800 feet from WL0B1	Low	Not a significant source of Nitrates/Nitrites.
GZ2 – A-Aquifer Contamination		7	A, B	Varies, throughout	Low	Not a significant source of Nitrates/Nitrites.

**TABLE E-3. CS RANKING – SOURCES OF VOLATILE ORGANIC CHEMICALS, KSDA, AK**

C.S. Category <sup>1</sup>	CS ID <sup>2</sup>	CS ID tag <sup>3</sup>	Zone <sup>4</sup>	Location <sup>5</sup>	Risk Ranking	Comments
Injection Well (Class V)	D10	3	A	105 feet from WTP	Low	Not a significant source of VOC's.
Dirt/gravel roads	X24	4	A, B	Approximately 0.25 miles of gravel road in source protection area.	Low	Not a significant source of VOC's.
UAF Shed	X27	5	B	800 feet from WL0B1	Low	Not a significant source of VOC's.
Buildings 327 and 335	X27	6	B	1800 feet from WL0B1	Low	Not a significant source of VOC's.
GZ2 – A-Aquifer Contamination		7	A, B	Varies, throughout	Low	TCE, BTEX documented in A-Aquifer for GWZ 2.

**TABLE E-4. CS RANKING – SOURCES OF HEAVY METALS, CYANIDE, AND OTHER INORGANIC CHEMICALS, KSDA, AK**

C.S. Category <sup>1</sup>	CS ID <sup>2</sup>	CS ID tag <sup>3</sup>	Zone <sup>4</sup>	Location <sup>5</sup>	Risk Ranking	Comments
Injection Well (Class V)	D10	3	A	105 feet from WTP	Low	Not a significant source.
Dirt/gravel roads	X24	4	A, B	Approximately 0.25 miles of gravel road in the source protection area.	Low	Not a significant source.
UAF Shed	X27	5	B	800 feet from WL0B1	Low	Not a significant source.
Buildings 327 and 335	X27	6	B	1800 feet from WL0B1	Low	Not a significant source.
GZ2 – A-Aquifer Contamination		7	A, B	Varies, throughout	Low	Not a significant source.

NOTES:

Only those contaminant sources that are inside the drinking water protection area shown on Figure 6 (zones A and B) are in this list.

1. Categories are established by EPA/ADEC.
2. Contaminant source identification numbers (CS ID) are established by EPA/ADEC.
3. These numbers correspond to contaminant source numbers in Figure 6.
4. Zones A and B defined in Figure 6.
5. See Figures 1-6.



**TABLE E-5. CS RANKING – SOURCES OF SYNTHETIC ORGANIC CHEMICALS, KSDA, AK**

C.S. Category <sup>1</sup>	CS ID <sup>2</sup>	CS ID tag <sup>3</sup>	Zone <sup>4</sup>	Location <sup>5</sup>	Risk Ranking	Comments
Injection Well (Class V)	D10	3	A	105 feet from WTP	Low	Not a significant source of SOC's.
Dirt/gravel roads	X24	4	A, B	Approximately 0.25 miles of gravel road in source protection area.	Low	Not a significant source of SOC's.
UAF Shed	X27	5	B	800 feet from WL0B1	Low	Not a significant source of SOC's.
Buildings 327 and 335	X27	6	B	1800 feet from WL0B1	Low	Not a significant source of SOC's.
GZ2 – A-Aquifer Contamination		7	A, B	Varies, throughout	Low	PFAS documented in A-Aquifer for GWZ2, investigation ongoing.

**TABLE E-6. CS RANKING – SOURCES OF OTHER SYNTHETIC ORGANIC CHEMICALS, KSDA, AK**

C.S. Category <sup>1</sup>	CS ID <sup>2</sup>	CS ID tag <sup>3</sup>	Zone <sup>4</sup>	Location <sup>5</sup>	Risk Ranking	Comments
Injection Well (Class V)	D10	1	A	105 feet from WTP	Low	Not a significant source of other SOC's.
Dirt/gravel roads	X24	1	A, B	Approximately 0.25 miles of gravel road in source protection area.	Low	Not a significant source of other SOC's.
UAF Shed	X27	1	B	800 feet from WL0B1	Low	Not a significant source of other SOC's.
Buildings 327 and 335	X27	2	B	1800 feet from WL0B1	Low	Not a significant source of other SOC's.
GZ2 – A-Aquifer Contamination			A, B	Varies, throughout	Low	Other contaminants documented in A-Aquifer for GWZ2, investigation on going.

NOTES:

Only those contaminant sources that are inside the drinking water protection area shown on Figure C-10 (zones A and B) are in this list.

- 6. Categories are established by EPA/ADEC.
- 7. Contaminant source identification numbers (CS ID) are established by EPA/ADEC.
- 8. These numbers correspond to contaminant source numbers in Figure 6.
- 9. Zones A and B defined in Figure 6.
- 10. See Figures 1-6.

**APPENDIX F**

**Flow Charts**

KSDA, Alaska, March 2022

[THIS PAGE INTENTIONALLY LEFT BLANK]

Chart F-1. Susceptibility of the wellhead - USAF King Salmon




Chart F-2. Susceptibility of the aquifer - USAF King Salmon







Chart F-3a. Contaminant risks for USAF King Salmon - Bacteria & Viruses



Risk Rankings for Contaminant Sources Identified in Zones A and B



	Zone A	Zone B	Total
Very High(s)	0	0	0
High(s)	0	0	0
Medium(s)	0	0	0
Low(s)	2	2	4

	LOW	MEDIUM	HIGH	VERY HIGH
LOW	≥ 10 sources	≥ 10 sources	≥ 20 sources	----
MEDIUM	----	≥ 2 sources	≥ 5 sources	≥ 10 sources
HIGH	----	----	≥ 1 source	≥ 2 sources
VERY HIGH	----	----	----	≥ 1 source


Matrix Score 0

Note: Septic systems, sewerlines, and roads are each assigned a risk ranking for each individual contaminant source in the CSI. The VA, however, counts these contaminant sources as a group and assigns a calculated number of either "lows" or "mediums" based on the density.

Chart F-3b. Contaminant risks for USAF King Salmon - Bacteria & Viruses



Contaminant Risk Ratings	
40 to 50 pts	very high
30 to < 40 pts	high
20 to < 30 pts	medium
< 20 pts	low



Existing	0 pts
+	
Potential	2 pts
=	
Contaminant Risk	2 pts

\* Truncate risk at 50 pts

**Chart F-3c. Vulnerability analysis for USAF King Salmon - Bacteria & Viruses**






Chart F-4a. Contaminant risks for USAF King Salmon - Nitrates and Nitrites




Chart F-4b. Contaminant risks for USAF King Salmon - Nitrates and Nitrites









Chart F-4c. Contaminant risks for USAF King Salmon - Nitrates and Nitrites



**Chart F-4d. Vulnerability analysis for USAF King Salmon - Nitrates and Nitrites**




Chart F-5a. Contaminant risks for USAF King Salmon - Volatile Organic Chemicals




Chart F-5b. Contaminant risks for USAF King Salmon - Volatile Organic Chemicals







Chart F-5c. Contaminant risks for USAF King Salmon - Volatile Organic Chemicals



**Chart F-5d. Vulnerability analysis for USAF King Salmon - Volatile Organic Chemicals**






Chart F-6a. Contaminant risks for USAF King Salmon - Heavy Metals, Cyanide and Other Inorganic Chemicals




Chart F-6b. Contaminant risks for USAF King Salmon - Heavy Metals, Cyanide and Other Inorganic Chemicals







Chart 9. Contaminant risks for USAF King Salmon - Heavy Metals, Cyanide and Other Inorganic Chemicals

Chart F-6c. Contaminant risks for USAF King Salmon - Heavy Metals, Cyanide and Other Inorganic Chemicals



+ 0 pts

- 0 pts


Existing  
1 pts  
+  
Potential  
2 pts  
=  
Contaminant Risk  
3 pts

\*Truncate risk at 50 pts

Contaminant Risk Ratings

40 to 50 pts	very high
30 to < 40 pts	high
20 to < 30 pts	medium
< 20 pts	low

**Chart F-6d. Vulnerability analysis for USAF King Salmon - Heavy Metals, Cyanide and Other Inorganic Chemicals**



KSDA, Alaska, March 2022

Chart F-7a. Contaminant risks for USAF King Salmon - Synthetic Organic Chemicals






Chart F-7b. Contaminant risks for USAF King Salmon - Synthetic Organic Chemicals



Risk Levels for Contaminant Sources identified in Zones A, B and C			
	Zone A	Zones B&C	Total
Very High(s)	0	0	0
High(s)	0	0	0
Medium(s)	0	0	0
Low(s)	1	2	3

	LOW 10 pts	MEDIUM 20 pts	HIGH 30 pts	VERY HIGH 40 pts
LOW	≥ 10 sources + 10 pts	≥ 10 sources + 5 pts	≥ 20 sources + 5 pts	---
MEDIUM	---	≥ 2 sources + 5 pts	≥ 5 sources + 5 pts	≥ 10 sources + 5 pts
HIGH	---	---	≥ 1 source + 10 pts	≥ 2 sources + 10 pts
VERY HIGH	---	---	---	≥ 1 source + 10 pts

Matrix Score 0

Note: Septic systems, sewerlines, and roads are each assigned a risk ranking for each individual contaminant source in the CSI. The VA, however, counts these contaminant sources as a group and assigns a calculated number of either "lows" or "mediums" based on the density.








Chart F-7c. Contaminant risks for USAF King Salmon - Synthetic Organic Chemicals



**Chart F-7d. Vulnerability analysis for USAF King Salmon - Synthetic Organic Chemicals**






Chart F-8a. Contaminant risks for USAF King Salmon - Other Organic Chemicals





Chart F-8b. Contaminant risks for USAF King Salmon - Other Organic Chemicals



Risk Levels for Contaminant Sources identified in Zones A, B and C			
	Zone A	Zones B&C	Total
Very High(s)	0	0	0
High(s)	0	0	0
Medium(s)	0	0	0
Low(s)	2	2	4

	LOW 10 pts	MEDIUM 20 pts	HIGH 30 pts	VERY HIGH 40 pts
LOW	≥ 10 sources + 10 pts	≥ 10 sources + 5 pts	≥ 20 sources + 5 pts	---
MEDIUM	---	≥ 2 sources + 5 pts	≥ 5 sources + 5 pts	≥ 10 sources + 5 pts
HIGH	---	---	≥ 1 source + 10 pts	≥ 2 sources + 10 pts
VERY HIGH	---	---	---	≥ 1 source + 10 pts

Matrix Score 0

Note: Septic systems, sewerlines, and roads are each assigned a risk ranking for each individual contaminant source in the CSI. The VA, however, counts these contaminant sources as a group and assigns a calculated number of either "lows" or "mediums" based on the density.






Chart F-8c. Contaminant risks for USAF King Salmon - Other Organic Chemicals



**Chart F-8d. Vulnerability analysis for USAF King Salmon - Other Organic Chemicals**

