



---

# Source Water Assessment

A Hydrogeologic Susceptibility and  
Vulnerability Assessment for  
Chilkat River Adventures Public Drinking  
Water System,  
Klukwan, Alaska  
PWSID # 111526.001

DRINKING WATER PROTECTION REPORT 1602

Alaska Department of Environmental Conservation

December, 2008

Source Water Assessment for Chilkat  
River Adventures Public Drinking Water  
System  
Klukwan, Alaska  
PWSID# 111526.001

DRINKING WATER PROTECTION REPORT 1602

The Drinking Water Protection (DWP) section of the Drinking Water Program is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (DEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. It is anticipated this assessment will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of public drinking water source. If you have any additional information that may affect the results of this assessment, please contact the DWP staff at the following toll-free number: 1-866-956-7656.

December, 2008

## CONTENTS

	Page		Page
Executive Summary .....	1	Vulnerability of Chilkat River Adventures Drinking	
Chilkat River Adventures Public Drinking Water		Water System .....	2
System .....	1	References .....	5
Chilkat River Adventures Drinking Water Protection		Appendix A .....	7
Area .....	1	Appendix B.....	9
Inventory of Potential and Existing Contaminant		Appendix C.....	11
Sources .....	2		
Ranking of Contaminant Risks .....	2		

## TABLES

Table 1. Definition of Zones.....	2
Table 2. Susceptibility .....	3
Table 3. Contaminant Risks.....	3
Table 4. Overall Vulnerability.....	3

## APPENDICES

- APPENDIX
- A. Chilkat River Adventures Drinking Water Protection Area (Map A)
  - B. Contaminant Source Inventory for Chilkat River Adventures (Table 1)  
 Contaminant Source Inventory and Risk Ranking for Chilkat River Adventures –  
 Nitrates/Nitrites (Table 2)  
 Contaminant Source Inventory and Risk Ranking for Chilkat River Adventures – Volatile  
 Organic Chemicals (Table 3)
  - C. Chilkat River Adventures Drinking Water Protection Area and Potential and Existing  
 Contaminant Sources (Map C)

# Source Water Assessment for Chilkat River Adventures Source of Public Drinking Water, Klukwan, Alaska

---

## Drinking Water Protection Alaska Department of Environmental Conservation

### EXECUTIVE SUMMARY

The public water system for Chilkat River Adventures is a Class B (transient/non-community) water system consisting of one well on Haines Highway about 2 miles northwest of Klukwan, Alaska. The wellhead received a susceptibility rating of **Low** and the aquifer received a susceptibility rating of **High**. Combining these two ratings produces a **Low** rating for the natural susceptibility of the well. Identified potential and current sources of contaminants for Chilkat River Adventures public drinking water source include a quarry. This identified potential and existing source of contamination is considered a potential source of nitrates and/or nitrites, and volatile organic chemicals. It is not considered a potential source of bacteria and viruses. Overall, the public water sources for Chilkat River Adventures received a vulnerability rating of **Low** for all three contaminant categories. This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Chilkat River Adventures to protect public health.

### CHILKAT RIVER ADVENTURES PUBLIC DRINKING WATER SYSTEM

Chilkat River Adventures public water system is a Class B (transient/non-community) water system. The system consists of one well on the north side of the Haines Highway approximately 2 miles northwest of Klukwan, Alaska (See Map A of Appendix A). Klukwan is located on the Chilkat River near the confluence of the Kleheni and Tsirku Rivers. It lies on the Haines Highway about 22 miles north of Haines.

Residents of the Klukwan area typically derive their water from a groundwater infiltration gallery. About 90% of homes are connected to this water supply and have full plumbing. A local landfill exists and electricity is provided by Inside Passage Electric Cooperative (ADEC 2008).

According to the well log, the depth of the well is 64 feet below the ground surface. The well is screened in sand and gravel in an unconfined aquifer. The Sanitary Survey (8/19/2005) for the water system indicates the land surface is appropriately sloped away from the well

providing adequate surface water drainage. The well is also grouted according to DEC regulations. Proper grouting provides added protection against contaminants travelling along the well casing and into source waters.

This system operates from May to September and serves approximately 80 non-residents and one resident through five service connections.

### CHILKAT RIVER ADVENTURES DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. These areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the drinking water protection area. The drinking water protection area is the area circling the well (the area influenced by pumping) and also the area upgradient of the well, usually forming a parabola shape. Because releases of contaminants within the protection area are most likely to impact the well, this area will serve as the focus for voluntary protection efforts.

There are many different methods for calculating the size of protection areas. Drinking Water Protection (DWP) uses a combination of two simple groundwater flow equations, the Thiem and uniform flow equations for all groundwater wells screened in unconsolidated material. The orientation of the protection zone is then drawn using a water table elevation map (if available) or a land surface elevation map of the area. The protection zone calculated by DWP is an estimate using the available information and resources, and may differ slightly from the actual capture zone. Because of uncertainties and changing site conditions, a factor of safety is added to the protection zone to form the drinking water protection area for the well.

The parameters used to calculate the shape of this protection zone are general for the whole alluvial plain and were obtained from various United States Geological Survey (USGS) reports, area well logs, and

the Groundwater textbook by Freeze and Cherry (Freeze and Cherry, 1979).

The protection areas established for wells by the DEC are usually separated into two zones, limited by the watershed. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well. An analytical calculation was used to determine the size and shape of the protection area.

The time-of-travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the two protection area zones for wells and the calculated time-of-travel for each:

**Table 1. Definition of Zones**

Zone	Definition
A	Several months time-of-travel
B	Less than the 2 year time-of-travel

The drinking water protection area for Chilkat River Adventures was determined using an analytical calculation and includes Zones A and B (See Map A of Appendix A).

**INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES**

The DWP has completed an inventory of potential and existing sources of contamination within the Chilkat River Adventures drinking water protection area . This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class B public water system assessments, the following three categories of drinking water contaminants were inventoried:

- Bacteria and viruses;
- Nitrates and/or nitrites;
- Volatile organic chemicals

The sources are displayed on Map C of Appendix C and summarized in Table 1 of Appendix B.

**RANKING OF CONTAMINANT RISKS**

Once the potential and existing sources of contamination have been identified, they are assigned a ranking according to what type and level of risk they represent. Ranking of contaminant risks for a

“potential” or “existing” source of contamination is a function of toxicity and volumes of specific contaminants associated with that source. Rankings include:

- Low;
- Medium;
- High; and
- Very High.

Tables 2 and 3 in Appendix B contain the ranking of potential and existing sources of contamination with respect to nitrates and/or nitrites, and volatile organic chemicals.

**VULNERABILITY OF CHILKAT RIVER ADVENTURES DRINKING WATER SYSTEM**

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural Susceptibility; and
- Contaminant Risks.

A score for the Natural Susceptibility of the well is reached by considering the properties of the well and the aquifer.

$$\begin{aligned}
 &\text{Susceptibility of the Wellhead (0-25 Points)} \\
 &\quad + \\
 &\text{Susceptibility of the Aquifer (0-25 Points)} \\
 &\quad = \\
 &\text{Natural Susceptibility of the Well (0-50 Points)}
 \end{aligned}$$

A ranking is assigned for the Natural Susceptibility according to the point score:

Natural Susceptibility Ratings	
40-50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Factors contributing to the susceptibility of the wellhead are: whether the sanitary seal is in place, protection from flooding, and if the well casing is properly grouted.

The wellhead for the AK Division of Parks received a **Low** susceptibility rating. The most recent sanitary survey (8/19/2005) indicates the well is capped with a sanitary seal, the land surface is sloped away from the well, and the well is grouted.

Factors contributing to the susceptibility of the aquifer are: whether the aquifer is confined or unconfined, whether the well is completed in unconsolidated or

fractured bedrock, whether wells and bore holes are penetrating the aquifer and, if applicable, the confining layer.

The aquifer for the Chilkat River Adventures well is unconfined and consists largely of sand and gravel. The aquifer received a **High** susceptibility rating. The highly transmissive aquifer material and the high water table in the area (5 feet bgs) allow contaminants to travel downward from the surface with the precipitation and surface water runoff.

Table 2 summarizes the Susceptibility scores and ratings for the Chilkat River Adventures system.

**Table 2. Susceptibility**

	Score	Rating
Susceptibility of the Wellhead	0	Low
Susceptibility of the Aquifer	17	High
Natural Susceptibility	17	Low

Contaminant risks are derived from an evaluation of the routine sampling results of the water system and the presence of potential sources of contamination. Contaminant risks to a drinking water source depend on the type and distribution of contaminant sources. Flow charts are used to assign a point score, and ratings are assigned in the same way as for the natural susceptibility:

Contaminant Risk Ratings	
40-50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants for the Chilkat River Adventures system.

**Table 3. Contaminant Risks**

Category	Score	Rating
Bacteria and Viruses	0	Low
Nitrates and/or Nitrites	15	Low
Volatile Organic Chemicals	10	Low

Finally, an overall vulnerability score is assigned for each water system by combining each of the

contaminant risk scores with the natural susceptibility score:

$$\begin{aligned}
 &\text{Natural Susceptibility (0-50 Points)} \\
 &+ \\
 &\text{Contaminant Risks (0-50 Points)} \\
 &= \\
 &\text{Vulnerability of the Drinking Water Source to} \\
 &\text{Contamination (0-100 Points)}
 \end{aligned}$$

Again, rankings are assigned according to a point score:

Overall Vulnerability Ratings	
80-100 pts	Very High
60 to < 80 pts	High
40 to < 60 pts	Medium
< 40 pts	Low

Table 4 contains the overall vulnerability scores (0-100) and ratings for each of the three categories of drinking water contaminants for the Chilkat River Adventures system. Note: scores are rounded off to the nearest five.

**Table 4. Overall Vulnerability**

Category	Score	Rating
Bacteria and Viruses	15	Low
Nitrates and/or Nitrites	30	Low
Volatile Organic Chemicals	25	Low

### Bacteria and Viruses

The contaminant risk for bacteria and viruses is low with no potential contaminant sources contributing to the risk to the drinking water well.

Coliforms (a bacteria) are found naturally in the environment and although they aren't necessarily a health threat, they are an indicator of other potentially harmful bacteria in the water, more specifically, fecal coliforms and E. coli, which only come from human and animal fecal waste. Harmful bacteria can cause diarrhea, cramps, nausea, headaches, or other symptoms (EPA, 2008). Positive samples increase the overall vulnerability of the drinking water source, indicating that the source is susceptible to bacteria and virus contamination.

Only a small amount of bacteria and viruses are required to endanger public health. Bacteria and viruses have not been detected during recent water sampling of the system at Chilkat River Adventures.

After combining the contaminant risk for bacteria and viruses with the natural susceptibility of the well, the overall vulnerability of the well to contamination is low.

### **Nitrates and Nitrites**

The contaminant risk for nitrates and nitrites is low with the quarry contributing to the risk to this source of public drinking water. Nitrates are very mobile, moving at approximately the same rate as water.

Sampling history for Chilkat River Adventures well indicates that nitrates have been detected in the water, but only in low concentrations (the highest detected level within the last 5 years of sampling was 1.09 mg/l on 6/18/2007, data was reviewed in April, 2008). After combining the contaminant risk for nitrates and nitrites with the natural susceptibility of the well, the overall vulnerability of the well to contamination is low.

### **Volatile Organic Chemicals**

The contaminant risk for volatile organic chemicals is low with the quarry contributing to the risk of volatile organic chemicals.

The drinking water at Chilkat River Adventures has not been sampled for Volatile Organic Chemicals recently. After combining the contaminant risk for volatile organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is low.

### **Using the Source Water Assessment**

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Chilkat River Adventures to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of Chilkat River Adventures drinking water source.

## **REFERENCES**

Alaska Department of Community and Economic Development (ADCED), Accessed 2008 [WWW document].

URL: [http://www.commerce.state.ak.us/dca/commdb/CF\\_COMDB.htm](http://www.commerce.state.ak.us/dca/commdb/CF_COMDB.htm)

Freeze, R.A. and Cherry, J.A., 1979. Groundwater. Prentice-Hall, Englewood Cliffs, NJ.

United States Environmental Protection Agency (EPA), Accessed 2008 [WWW document]. URL:

<http://www.epa.gov/safewater/contaminants/index.html>.






## **APPENDIX A**

### **Chilkat River Adventures Drinking Water Protection Area Location Map (Map A)**

Public Water Well System for PWS #111526.001 Chilkat River Adventures



**Legend**

-  Class B Public Water System
- Groundwater Protection Zones**
-  Zone A Protection Area - Several Months Travel Time
-  Zone B Protection Area - 2 Years Travel Time




Chilkat River Adventures  
PWSID:111526.001

**Data Sources:**  
Contaminant Sources, Public Water System Wells, Alaska Department of Environmental Conservation (ADEC)

**All other data:**  
Alaska Statewide Digital Mapping Initiative (SDMI)

**Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class B Public Water Systems" published by ADEC**

**URS Corporation does not guarantee the accuracy or validity of the data provided.**



## **APPENDIX B**

### **Contaminant Source Inventory and Risk Ranking for Chilkat River Adventures (Tables 1-3)**

**Table 1**

**Contaminant Source Inventory for  
Chilkat River Adventures**

**PWSID 111526.001**

<b>Contaminant Source Type</b>	<b>Contaminant Source ID</b>	<b>CS ID tag</b>	<b>Zone</b>	<b>Map Number</b>	<b>Comments</b>
Quarries (sand, gravel, rock, other?)	E10	E10-01	B	C	

**Table 2**

*Contaminant Source Inventory and Risk Ranking for  
Chilkat River Adventures  
Sources of Nitrates/Nitrites*

*PWSID 111526.001*

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Quarries (sand, gravel, rock, other?)	E10	E10-01	B	Low	C	

**Table 3**

*Contaminant Source Inventory and Risk Ranking for  
Chilkat River Adventures  
Sources of Volatile Organic Chemicals*


*PWSID 111526.001*

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Quarries (sand, gravel, rock, other?)	E10	E10-01	B	Low	C	

## **APPENDIX C**

### **Chilkat River Adventures Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)**

**Public Water Well System for PWS #111526.001 Chilkat River Adventures  
Showing Potential and Existing Sources of Contamination**



**Legend**

- Class B Public Water System
- Groundwater Protection Zones**
- Zone A Protection Area - Several Months Travel Time
- Zone B Protection Area - 2 Years Travel Time
- Potential and Existing Contaminant Sources**
- ✕ Quarries (sand, gravel, rock, other) (E10)

**Data Sources:**  
Contaminant Sources, Public Water System Wells, Alaska Department of Environmental Conservation (ADEC)

**All other data:**  
Alaska Statewide Digital Mapping Initiative (SDMI)

**Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class B Public Water Systems" published by ADEC**

**URS Corporation does not guarantee the accuracy or validity of the data provided.**

