



Source Water Assessment

A Hydrogeologic Susceptibility and Vulnerability Assessment for McKinley Learning Center Drinking Water System, McKinley Park, Alaska PWSID # 391312

DRINKING WATER PROTECTION PROGRAM REPORT # 325
Alaska Department of Environmental Conservation

Source Water Assessment for McKinley Learning Center Drinking Water System, McKinley Park, Alaska PWSID # 391312

By Ecology & Environment, Inc.

DRINKING WATER PROTECTION PROGRAM REPORT # 325

August 2002

The Drinking Water Protection Program is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (ADEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. If you have any additional information that may affect the results of this assessment, please contact the Program Coordinator of DWPP, (907) 269-7521.

CONTENTS

Executive Summary Introduction Description of the McKinley Park/McKinley Village Area, Alaska McKinley Learning Center Public Drinking Water System McKinley Learning Center Drinking Water Protection Area		Inventory of Potential and Existing Contaminant Sources Ranking of Contaminant Risks Vulnerability of McKinley Learning Center Drinking Water Source Summary References Cited	Page 2 3 4 5 5		
	TAI	BLES			
 Na Na Co 	efinition of Zones atural Susceptibility - Susceptibil and Aquifer to Contamination ontaminant Risks verall Vulnerability of McKinley	ity of the Wellhead Learning Center to Contamination	2 3 4 4		
	FIG	URES			
FIGURE 1. Ind	lex map showing the location of t	he McKinley Park and McKinley Village area	1		
	APPE	NDICES			
APPENDIX A. M	cKinley Learning Center Drinkin	ng Water Protection Area (Map 1)			
B. Co	Contaminant Source Inventory Bacteria and Viruses Contaminant Source Inventory Nitrates/Nitrites (Tab	y and Risk Ranking for McKinley Learning Cente le 3) y and Risk Ranking for McKinley Learning Cente	r–		
C. M	cKinley Learning Center Drinkin Existing Contaminant Sources	g Water Protection Area and Potential and (Map 2)			
D. V	 D. Vulnerability Analysis for Contaminant Source Inventory and Risk Ranking for McKinley Learning Center Public Drinking Water Source (Charts 1 – 8) 				

Source Water Assessment for McKinley Learning Center Source of Public Drinking Water, McKinley Village, Alaska

By Ecology & Environment, Inc.

Drinking Water Protection Program Alaska Department of Environmental Conservation

EXECUTIVE SUMMARY

McKinley Learning Center is a Class B (transient/non-community) water system consisting of one well in McKinley Village, Alaska. Identified potential and current sources of contaminants for McKinley Learning Center public drinking water source include: a paved road and an airport. These identified potential and existing sources of contamination are considered sources of bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals. Overall, the public water sources for McKinley Learning Center received a vulnerability rating of Medium for bacteria and viruses, Medium for nitrates and nitrites, and High for volatile organic chemicals.

INTRODUCTION

The Alaska Department of Environmental Conservation (ADEC) is completing source water assessments for all public drinking water sources in the State of Alaska. The purpose of this assessment is to provide owners and/or operators, communities, and local governments with information they can use to preserve the quality of Alaska's public drinking water supplies. The results of this source water assessment can be used to decide where voluntary protection efforts are needed and feasible, and also what efforts will be most effective in reducing contaminant risks to your water system. Ecology and Environment, Inc. has been contracted to perform these assessments under the supervision of ADEC.

This source water assessment combines a review of the natural conditions at the site and the potential and existing contaminant risks. These are combined to determine the overall vulnerability of the drinking water source to contamination.

DESCRIPTION OF THE MCKINLEY PARK AND MCKINLEY VILLAGE AREA

Location

The McKinley Park area is located at the junction of the George Parks Highway and McKinley Park Road at mile 231 of the highway, at the entrance of Denali National Park. McKinley Village is located to the south, near the confluence of the Yanert Fork and the Nenana River (Figure 1).



Figure 1

Precipitation

The McKinley Park/McKinley Village area averages about 15 inches of precipitation per year, with approximately 81 inches of snowfall (ACRC 2002).

Topography and Drainage

McKinley Park and McKinley Village lie in the Nenana River valley, which cuts through the steeply rising peaks of the Alaska Range. Most of the businesses are located along the river or on the gentler slopes at the base of the mountains.

Groundwater Use

There is no municipal water supply. Most of the seasonally-used private homes in the area haul their drinking water. The lodges and other businesses which cater to tourists generally have their own wells and septic systems (ADCED 2002).

Geology and Soils

The geology of the McKinley Park and McKinley Village area is characterized by glacial sediments overlying bedrock. The glacial till has been reworked by rivers in some areas, and may consist of well-rounded to angular rock fragments mixed with sand and silt. Local fractures in the bedrock can provide pathways for the migration of groundwater (Lanning 1994).

MCKINLEY LEARNING CENTER PUBLIC DRINKING WATER SYSTEM

McKinley Learning Center is a Class B (transient/non-community) water system. The system consists of one well near the Parks Highway milepost 231 in McKinley Village.

There is no well log on file for this well; if one could be located, it would help improve the accuracy of this report. According to the most recent Sanitary Survey (5/25/99), installation of the well occurred in 1989 to a total depth of approximately 40 feet below ground surface. The well is capped and has a sanitary seal. A properly installed sanitary seal may provide protection against contaminants from entering the source waters at the well casing. The land surface is also appropriately sloped away from the well providing adequate surface water drainage. The well apparently was not grouted according to ADEC regulations (grouting was not required prior to 1993). Proper grouting provides added protection against contaminants travelling along the well casing and into source waters. The aquifer is assumed to be unconfined based on the depth of the well.

This system operates from May 25 to September 15 and serves approximately 50 non-residents.

MCKINLEY LEARNING CENTER DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. Some areas are more likely to allow contamination to reach the well than others. These

areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the area that contributes water to the well, the groundwater recharge area. This area is designated as the Drinking Water Protection Area (DWPA). Because a release of contaminants within the DWPA are most likely to impact the drinking water well, this area will serve as the focus for voluntary protection efforts.

An analytical calculation was used to determine the size and shape of the DWPA. The input parameters describing the attributes of the aquifer in this calculation were adopted from the U.S. Geological Survey (*Patrick et al. 1989*). Additional methods were also used to take into account any uncertainties in groundwater flow and aquifer characteristics to arrive at a meaningful DWPA (Please refer to the Guidance Manual for Class B Water Systems for additional information).

The DWPAs established for wells by the ADEC are separated into four zones. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well. The time of travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the four DWPA zones and the calculated time-of-travel for each:

Table 1. Definition of Zones

Zone	Definition						
A	¹ / ₄ the distance to the 2-year TOT						
В	Less than the 2-year TOT						
C	Less than the 5-year TOT						
D	Less than the 10 year TOT						

As an example, water moving through the aquifer in Zone B will most likely reach the well in less than 2 years from the time it crosses the outer limit of Zone B.

Zone A also incorporates the area downgradient from the well to take into account the area of the aquifer that is influenced by pumping of the well. Water within the aquifer in Zone A will reach the well in several hours to several months.

INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES

The Drinking Water Protection Program has completed an inventory of potential and existing sources of contamination within the McKinley Learning Center DWPA. This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class B water system assessments, three categories of drinking water contaminants were inventoried. They include:

- Bacteria and viruses:
- Nitrates and/or nitrites; and
- Volatile organic chemicals.

Inventoried potential sources of contamination within Zones A through Zone D were associated with residential and light industrial type activities. The sources are summarized in the tables in Appendix B of the Guidance Manual.

RANKING OF CONTAMINANT RISKS

Once the potential and existing sources of contamination have been identified, they are sorted and ranked according to what type and level of risk they represent. Ranking of contaminant risks for a "potential" or "existing" source of contamination is a function of toxicity and volumes of specific contaminants associated with that source. Further, contaminant risks are a function of the number and density of those types of contaminant sources as well as the proximity of those sources to the well.

VULNERABILITY OF MCKINLEY LEARNING CENTER DRINKING WATER SOURCE

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural susceptibility; and
- Contaminant risks.

Each of the three categories of drinking water contaminants has been analyzed and an overall vulnerability score of 0 to 100 is ultimately assigned:

Natural Susceptibility (0 - 50 points)

Contaminant Risks (0 – 50 points)

Vulnerability of the Drinking Water Source to Contamination (0 - 100).

A score for the Natural Susceptibility is achieved by analyzing the properties of the well and the aquifer.

Susceptibility of the Wellhead (0 - 25 Points)

+

Susceptibility of the Aquifer (0 - 25 Points)

=

Natural Susceptibility (Susceptibility of the Well) (0-50 Points)

Appendix D contains eight charts, which together form the 'Vulnerability Analysis' for a source water assessment for a public drinking water source. Chart 1 analyzes the 'Susceptibility of the Wellhead' to contamination by looking at the construction of the well and its surrounding area. Chart 2 analyzes the 'Susceptibility of the Aquifer' to contamination by looking at the naturally occurring attributes of the water source and influences on the groundwater system that might lead to contamination. Chart 3 analyzes 'Contaminant Risks' for the drinking water source with respect to bacteria and viruses. The 'Contaminant Risks' portion of the analysis considers potential sources of contaminants as well as a review of contamination that has or may have occurred, but has not arrived or been detected at the well. Lastly, Chart 4 contains the 'Vulnerability Analysis for Bacteria and Viruses'. Charts 5 through 8 contain the Contaminant Risks and Vulnerability Analyses for nitrates and nitrites and volatile organic chemicals, respectively.

Table 2 shows the Overall Susceptibility score and rating for McKinley Learning Center (see Charts 1 and 2).

Table 2. Natural Susceptibility - Susceptibility of the Wellhead and Aquifer to Contamination

Susceptibility of the	Score 15	Rating High
Wellhead Susceptibility of the	15	High
Aquifer Natural Susceptibility	30	High

Contaminant risks to a drinking water source depend on the type, number or density, and distribution of contaminant sources. This data has been derived from an examination of existing or historical contamination that has been detected at the drinking water source through routine sampling. It also evaluates potential sources of contamination. Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants (see Charts 3, 5, and 7).

Table 3. Contaminant Risks

Category	Score	Rating
Bacteria and Viruses	12	Low
Nitrates and/or Nitrites	13	Low
Volatile Organic Chemicals	40	Very High

Table 4 contains the overall vulnerability scores (0 – 100) and ratings for each of the three categories of drinking water contaminants. Note: scores are rounded off to the nearest five (see Charts 4, 6, and 8).

Table 4. Overall Vulnerability of McKinley Learning Center to Contamination by Category

Category	Score	Rating
Bacteria and Viruses	40	Medium
Nitrates and Nitrites	45	Medium
Volatile Organic Chemicals	70	High

Tables 2 through 4 in Appendix B contain a list of potential and existing sources of contamination with respect to bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals.

Only a small amount of bacteria and viruses are required to endanger public health. If bacteria and viruses have been detected during recent water sampling of the system at McKinley Learning Center, the result is a maximum score on Chart 3.

The sampling history for McKinley Learning Center well indicates that nitrates and/or nitrites are found in natural background concentration at this site, as elsewhere throughout Alaska. Nitrate concentrations in uncontaminated groundwater are typically less than 2 milligrams per liter (mg/L) and are derived primarily from the decomposition of organic matter in soils [Wang, Strelakos, Jokela, 2000]. Existing nitrate concentration in McKinley Learning Center well is approximately 0.2 mg/L or 2% of the Maximum Contaminant Level (MCL) of 10mg/L. The MCL is the maximum level of contaminant that is allowed to exist in drinking water and still be consumed by humans without harmful health effects. Due to the high solubility and weak retention by soil, nitrates are very mobile, moving at approximately the same rate as water. Though existing nitrate contamination was detected at the site, concentrations remain at safe levels with respect to human health (See Chart 5 -Contaminant Risks for Nitrates and/or Nitrites in

Appendix D).

Class B Public Water systems are not required to test for volatile organic chemicals (VOCs); therefore, no score for pre-existing contamination has been assigned. The vulnerability score for VOCs reflects the potential for contamination from the sources indicated on Table 4 in Appendix B.

SUMMARY

A Source Water Assessment has been completed for the sources of public drinking water serving McKinley Learning Center. The overall vulnerability of this source to contamination is **Medium** for bacteria and viruses, **Medium** for nitrates and nitrites, and **High** for volatile organic chemicals. This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of McKinley Learning Center to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of McKinley Learning Center public drinking water source.


REFERENCES CITED

- Alaska Climate Research Center (ACRC), 2002 [WWW document]. URL http://climate.gi.alaska.edu/climatology/data.html.
- Alaska Department of Community and Economic Development (ADCED), 2002 [WWW document]. URL http://www.dced.state.ak.us/cbd/commdb/CF_BLOCK.cfm
- Lanning, David, 1994, Re: Request for Approval of a New Class B Well at Grizzly Bear Campground, Denali National Park, Alaska. Letter to the Alaska Department of Environmental Conservation dated May 11, 1994, Fairbanks, Alaska.
- Patrick, L.D., Brabets, T.P., and Glass, R.L., 1989, Simulation of ground-water flow at Anchorage, Alaska: US Geological Survey Water-Resources Investigations Report 88-4139, 41p.
- Wang, B., Strelakos, P.M., and Jokela, B., 2000, Nitrate Source Indicators In Groundwater of the Scimitar Subdivision, Peters Creek Area, Anchorage Alaska: U.S. Geological Survey Water-Resources Investigations Report 00-4137, 25p.

APPENDIX A

McKinley Learning Center Drinking Water Protection Area (Map 1)

Drinking Water Protection Area for McKinley Learning Center



APPENDIX B

Contaminant Source Inventory and Risk Ranking for McKinley Learning Center (Tables 1-4)

PWSID 391312.001

Contaminant Source Inventory for McKinley Learning Center

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Location	Map Number	Comments
Airports	X14	X14-1	A	DENALI LANDING STRIP	2	
Highways and roads, paved (cement or asphalt)	X20	X20-1	A	GEORGE PARK'S HWY	2	

Contaminant Source Inventory and Risk Ranking for McKinley Learning Center Sources of Bacteria and Viruses

PWSID 391312.001

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Risk Ranking for Analysis	Location	Map Number	Comments
Highways and roads, paved (cement or asphalt)	X20	X20-1	A	Low	GEORGE PARK'S HWY	2	

Table 3

Contaminant Source Inventory and Risk Ranking for McKinley Learning Center Sources of Nitrates/Nitrites

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Risk Ranking for Analysis	Location	Map Number	Comments
Airports	X14	X14-1	A	Low	DENALI LANDING STRIP	2	
Highways and roads, paved (cement or asphalt)	X20	X20-1	A	Low	GEORGE PARK'S HWY	2	

Table 4


Contaminant Source Inventory and Risk Ranking for McKinley Learning Center Sources of Volatile Organic Chemicals

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Risk Ranking for Analysis	Location	Map Number	Comments
Airports	X14	X14-1	A	High	DENALI LANDING STRIP	2	
Highways and roads, paved (cement or asphalt)	X20	X20-1	A	Low	GEORGE PARK'S HWY	2	

APPENDIX C

McKinley Learning Center
Drinking Water Protection Area
and Potential and Existing Contaminant Sources
(Map 2)

Drinking Water Protection Area for McKinley Learning Center and Existing and Potential Contaminant Sources



APPENDIX D

Vulnerability Analysis for McKinley Learning Center Public Drinking Water Source (Charts 1-8)

Chart 1. Susceptibility of the wellhead - McKinley Learning Center




Chart 2. Susceptibility of the aquifer - McKinley Learning Center





Chart 3. Contaminant risks for McKinley Learning Center - Bacteria & Viruses



+ 10 pts

VERY HIGH

40 pts

≥ 10 sources


+ 5 pts


≥ 2 sources

+ 10 pts

 ≥ 1 source

+ 10 pts









Chart 5. Contaminant risks for McKinley Learning Center - Nitrates and Nitrites



10 pts

Risk Levels for Contaminant Sources identified in Zones A, B and C						
	Zone A Zones B&C Total					
Very Highs(s)	0	0	0			
High(s)	0	0	0			
Medium(s)	0	0	0			
Low(s)	2	0	2			

	LOW 10 pts	MEDIUM 20 pts	HIGH 30 pts	VERY HIGH 40 pts
LOW	* 10 sources + 10 pts	≥ 10 sources + 5 pts	≥ 20 sources + 5 pts	
MEDIUM		≥ 2 sources + 5 pts	≥ 5 sources + 5 pts	≥ 10 sources + 5 pts
HIGH			≥ 1 source + 10 pts	≥ 2 sources + 10 pts
VERY HIGH				≥ 1 source + 10 pts

Matrix	Score	10

Note: Septic systems, sewerlines, and roads are each assigned a risk ranking for each individual contaminant source in the CSI. The VA, however, counts these contaminant sources as a group and assigns a calculated number of either "lows" or "mediums" based on the density.





Chart 5. Contaminant risks for McKinley Learning Center - Nitrates and Nitrites Existing NO Are there conditions 1 pts Risk unchanged that warrant upgrading risk? Risk due to existing Potential contamination 12 pts Risk posed by potential sources of contamination with controls Contaminant Risk YES 13 pts Contaminant risks 0 pts Increase risk 1 - 10 pts Risk posed by potential sources of contamination 12 pts Contaminant risks* *Truncate risk at 50 pts 13 Are there sufficient Contaminant Risk Ratings Low controls, conditions, NO. Risk unchanged 40 to 50 pts very high or monitoring to 30 to < 40 pts warrant downgrading high risk? 20 to < 30 pts medium < 20 pts low YES 0 pts Decrease risk 1 - 10 pts Risk posed by potential sources of contamination with controls 12 pts







Chart 7. Contaminant risks for McKinley Learning Center - Volatile Organic Chemicals




30 pts

Risk Levels for Contaminant Sources identified in Zones A, B and C						
	Zone A	Zones B&C	Total			
Very Highs(s)	0	0	0			
High(s)	1	0	1			
Medium(s)	0	0	0			
Low(s)	1	0	1			

	LOW 10 pts	MEDIUM 20 pts	HIGH 30 pts	VERY HIGH 40 pts	
LOW	3 10 sources + 10 pts	≥ 10 sources + 5 pts	≥ 20 sources + 5 pts		
MEDIUM		≥ 2 sources + 5 pts	≥ 5 sources + 5 pts	≥ 10 sources + 5 pts	
HIGH			≥ 1 source + 10 pts	≥ 2 sources + 10 pts	
VERY HIGH				≥ 1 source + 10 pts	

	Matrix	Score	30
--	--------	-------	----

Note: Septic systems, sewerlines, and roads are each assigned a risk ranking for each individual contaminant source in the CSI. The VA, however, counts these contaminant sources as a group and assigns a calculated number of either "lows" or "mediums" based on the density.






Chart 8. Vulnerability analysis for McKinley Learning Center - Volatile Organic Chemicals (Chart 1. Susceptibility of the wellhead) Susceptibility of well High 30 pts Evaluate the susceptibility of the wellhead (Chart 7. Contaminant risks for wells - Volatile Organic Chemicals) Evaluate contaminant Susceptibility of wellhead High risks 15 pts Evaluate the (Chart 2. Susceptibility of the aquifer) Contaminant risks Very High susceptibility of the 40 pts aquifer within the protection area Susceptibility of aquifer High 15 pts Susceptibility of the well Contaminant risks Vulnerability of drinking water well to contamination Susceptibility of the wellhead Overall Vulnerability Ratings Susceptibility of aquifer 80 to 100 pts very high 60 to < 80 pts high Susceptibility of well 40 to < 60 pts Vulnerability of drinking water medium < 40 pts well low 70 pts High **70**