



---

# Source Water Assessment

A Hydrogeologic Susceptibility and  
Vulnerability Assessment for  
Leader Creek Inn  
Public Drinking Water System,  
Naknek, Alaska  
PWSID # 261402.001

DRINKING WATER PROTECTION REPORT 1756

Alaska Department of Environmental Conservation

January, 2009

Source Water Assessment for  
Leader Creek Inn  
Public Drinking Water System,  
Naknek, Alaska  
PWSID# 261402.001

DRINKING WATER PROTECTION REPORT 1756

The Drinking Water Protection (DWP) section of the Drinking Water Program is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (DEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. It is anticipated this assessment will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of public drinking water source. If you have any additional information that may affect the results of this assessment, please contact the DWP staff at the following toll-free number 1-866-956-7656.

January, 2009

## CONTENTS

	Page		Page
Executive Summary.....	1	Vulnerability of Leader Creek Inn	
Leader Creek Inn Public Drinking Water System .....	1	Drinking Water System.....	2
Leader Creek Inn Drinking Water Protection Area .....	1	References.....	5
Inventory of Potential and		Appendix A .....	7
Existing Contaminant Sources.....	2	Appendix B .....	9
Ranking of Contaminant Risks.....	2	Appendix C .....	11

## TABLES

Table 1. Definition of Zones.....	2
Table 2. Susceptibility .....	3
Table 3. Contaminant Risks.....	3
Table 4. Overall Vulnerability .....	3

## APPENDICES

APPENDIX	A. Leader Creek Inn Drinking Water Protection Area (Map A)
	B. Contaminant Source Inventory for Leader Creek Inn (Table 1)
	Contaminant Source Inventory and Risk Ranking for Leader Creek Inn – Bacteria and Viruses (Table 2)
	Contaminant Source Inventory and Risk Ranking for Leader Creek Inn – Nitrates/Nitrites (Table 3)
	Contaminant Source Inventory and Risk Ranking for Leader Creek Inn – Volatile Organic Chemicals (Table 4)
	C. Leader Creek Inn Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)

# Source Water Assessment for Leader Creek Inn

## Source of Public Drinking Water, Naknek, Alaska

---

### Drinking Water Protection Alaska Department of Environmental Conservation

#### EXECUTIVE SUMMARY

The public water system for Leader Creek Inn is a Class B (transient/non-community) water system consisting of one well located on King Salmon – Naknek Road in Naknek, Alaska. The wellhead received a susceptibility rating of **Very High** and the aquifer received a susceptibility rating of **High**. Combining these two ratings produces a **Very High** rating for the natural susceptibility of the well. Identified potential and current sources of contaminants for Leader Creek Inn public drinking water source include: assumed septic systems, assumed heating oil tanks, a road, diesel and gasoline tanks, a water supply well, and a boat yard. These identified potential and existing sources of contamination are considered as sources of bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals. Overall, the public water sources for Leader Creek Inn received a vulnerability rating of **Medium** for bacteria and viruses, **Medium** for nitrates and nitrites, and **High** for volatile organic chemicals. This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Leader Creek Inn to protect public health.

#### LEADER CREEK INN PUBLIC DRINKING WATER SYSTEM

Leader Creek Inn public water system is a Class B (transient/non-community) water system. The system consists of one well located between Olga Street and King Salmon – Naknek Road in Naknek, Alaska (see Map A in Appendix A). Naknek is located on the northern end of Bristol Bay, on the north bank of the Naknek River, about 297 miles southwest of Anchorage. Temperatures in the summer range from 42 to 63 degrees Fahrenheit and from 29 to 44 degrees in the winter. The area receives 20 inches of precipitation annually, including 45 inches of snowfall (ADCCED, 2009).

Most homes in Naknek use individual wells. The Bristol Bay Borough operates a piped sewage system that services most homes, though some still use septic systems. Electricity is provided by Naknek Electric Association (ADCCED, 2009).

According to the well log (03/06/1988), the well extends approximately 163 feet below the ground surface and is completed in a confined aquifer. This system serves 300 non-residents.

#### LEADER CREEK INN DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. These areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the drinking water protection area. The drinking water protection area is the area circling the well (the area influenced by pumping) and also the area upgradient of the well, usually forming a parabola shape. Because releases of contaminants within the protection area are most likely to impact the well, this area will serve as the focus for voluntary protection efforts.

There are many different methods for calculating the size of protection areas. Drinking Water Protection (DWP) uses a combination of two simple groundwater flow equations, the Thiem and uniform flow equations for all groundwater wells screened in unconsolidated material. The orientation of the protection zone is then drawn using a water table elevation map (if available) or a land surface elevation map of the area. The protection zone calculated by DWP is an estimate using the available information and resources, and may differ slightly from the actual capture zone. Because of uncertainties and changing site conditions, a factor of safety is added to the protection zone to form the drinking water protection area for the well.

The parameters used to calculate the shape of this protection zone are general for the whole alluvial plain and were obtained from various United States Geological Survey (USGS) reports, area well logs, and the Groundwater textbook by Freeze and Cherry (Freeze and Cherry, 1979).

The protection areas established for wells by the DEC are usually separated into two zones, limited by the watershed. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well. An analytical calculation was used to determine the size and shape of the protection area.

The time-of-travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the two protection area zones for wells and the calculated time-of-travel for each:

**Table 1. Definition of Zones**

Zone	Definition
A	Several months time-of-travel
B	Less than the 2 year time-of-travel

The drinking water protection areas for Leader Creek Inn was determined using an analytical calculation and includes Zones A and B (see Map A in Appendix A).

### INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES

DWP has completed an inventory of potential and existing sources of contamination within the Leader Creek Inn drinking water protection area. This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class B public water system assessments, the following three categories of drinking water contaminants were inventoried:

- Bacteria and viruses;
- Nitrates and/or nitrites;
- Volatile organic chemicals

The sources are displayed on Map C of Appendix C and summarized in Table 1 of Appendix B.

### RANKING OF CONTAMINANT RISKS

Once the potential and existing sources of contamination have been identified, they are assigned a ranking according to what type and level of risk they represent. Ranking of contaminant risks for a “potential” or “existing” source of contamination is a function of toxicity and volumes of specific

contaminants associated with that source. Rankings include:

- Low;
- Medium;
- High; and
- Very High.

Tables 2 through 4 in Appendix B contain the ranking of potential and existing sources of contamination with respect to bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals.

### VULNERABILITY OF LEADER CREEK INN DRINKING WATER SYSTEM

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural Susceptibility; and
- Contaminant Risks.

A score for the Natural Susceptibility of the well is reached by considering the properties of the well and the aquifer.

$$\begin{aligned} & \text{Susceptibility of the Wellhead (0-25 Points)} \\ & \quad + \\ & \text{Susceptibility of the Aquifer (0-25 Points)} \\ & \quad = \\ & \text{Natural Susceptibility of the Well (0-50 Points)} \end{aligned}$$

A ranking is assigned for the Natural Susceptibility according to the point score:

Natural Susceptibility Ratings	
40-50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Factors contributing to the susceptibility of the wellhead are: whether the sanitary seal is in place, protection from flooding, and if the well casing is properly grouted.

The wellhead for the Leader Creek Inn received a **Very High** susceptibility rating, due to its location within a floodplain. The well log (03/06/1988) indicates that a sanitary seal is installed on the well. The status of the ground slope around the well and grouting is unknown as there is no sanitary survey for this system. Sanitary seals prevent potential contaminants from entering the well, while sloping of the land surface away from the wellhead provides adequate surface water drainage, and concrete or grouting around the wellhead helps to prevent potential contaminants from traveling down the outside of the well casing. Additionally, the wellhead

lies within a floodplain, which is the main contributing factor to the susceptibility rating for this system.

Factors contributing to the susceptibility of the aquifer are: whether the aquifer is confined or unconfined, whether the well is completed in unconsolidated or fractured bedrock, whether wells and bore holes are penetrating the aquifer and, if applicable, the confining layer.

The Leader Creek Inn system draws water from a confined aquifer overlain by 88 feet of silty sand and clay. It received a **High** susceptibility rating because of the presence of another well that penetrates the vadose zone within the protection area. Wells that penetrate the vadose zone can allow contaminants to travel down to the aquifer with precipitation and runoff.

Table 2 summarizes the Susceptibility scores and ratings for the Leader Creek Inn system.

**Table 2. Susceptibility**

	<b>Score</b>	<b>Rating</b>
Susceptibility of the Wellhead	25	Very High
Susceptibility of the Aquifer	17	High
Natural Susceptibility	42	Very High

Contaminant risks are derived from an evaluation of the routine sampling results of the water system and the presence of potential sources of contamination. Contaminant risks to a drinking water source depend on the type and distribution of contaminant sources. Flow charts are used to assign a point score, and ratings are assigned in the same way as for the natural susceptibility:

<b>Contaminant Risk Ratings</b>	
40-50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants for the Leader Creek Inn system.

**Table 3. Contaminant Risks**

<b>Category</b>	<b>Score</b>	<b>Rating</b>
Bacteria and Viruses	12	Low
Nitrates and/or Nitrites	12	Low
Volatile Organic Chemicals	35	High

Finally, an overall vulnerability score is assigned for each water system by combining each of the contaminant risk scores with the natural susceptibility score:

$$\begin{aligned}
 &\text{Natural Susceptibility (0-50 Points)} \\
 &+ \\
 &\text{Contaminant Risks (0-50 Points)} \\
 &= \\
 &\text{Vulnerability of the Drinking Water Source to} \\
 &\text{Contamination (0-100 Points)}
 \end{aligned}$$

Again, rankings are assigned according to a point score:

<b>Overall Vulnerability Ratings</b>	
80-100 pts	Very High
60 to < 80 pts	High
40 to < 60 pts	Medium
< 40 pts	Low

Table 4 contains the overall vulnerability scores (0-100) and ratings for each of the three categories of drinking water contaminants for the Leader Creek Inn system. Note: scores are rounded off to the nearest five.

**Table 4. Overall Vulnerability**

<b>Category</b>	<b>Score</b>	<b>Rating</b>
Bacteria and Viruses	55	Medium
Nitrates and/or Nitrites	55	Medium
Volatile Organic Chemicals	75	High

**Bacteria and Viruses**

The contaminant risk for bacteria and viruses is **Low** with septic systems and a road contributing to the risk to the drinking water well.

Coliforms (a bacteria) are found naturally in the environment and while not necessarily a direct health threat, they are an indicator of other potentially harmful bacteria in the water, more specifically fecal coliforms and E. coli. These bacteria only come from human and animal fecal waste and can cause diarrhea, cramps, nausea, headaches, and other symptoms (EPA, 2008).

Only a small number of bacteria and viruses are required to endanger public health. Bacteria and viruses have not been detected within the last 5 years of water sampling of the Leader Creek Inn system (data reviewed in April, 2008).

After combining the contaminant risk for bacteria and viruses with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

#### **Nitrates and Nitrites**

The contaminant risk for nitrates and nitrites is **Low** with septic systems and a road contributing to the risk to the drinking water well.

The sampling history for Leader Creek Inn well indicates that nitrates have not been detected in the water within the last 5 years of sampling (data reviewed in April, 2008).

After combining the contaminant risk for nitrates and nitrites with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

#### **Volatile Organic Chemicals**

The contaminant risk for volatile organic chemicals is **High** with septic systems, heating oil tanks, a road, gasoline and diesel tanks, and a boat yard contributing to the risk to the drinking water well.

The drinking water at Leader Creek Inn has not recently been sampled for volatile organic chemicals (data reviewed in April, 2008).

After combining the contaminant risk for volatile organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **High**.

#### **Using the Source Water Assessment**

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Leader Creek Inn to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of Leader Creek Inn drinking water source.

## REFERENCES

Alaska Department of Commerce, Community and Economic Development (ADCCED), Accessed 2009 [WWW document]. URL: [http://www.commerce.state.ak.us/dca/commdb/CF\\_COMDB.htm](http://www.commerce.state.ak.us/dca/commdb/CF_COMDB.htm)

Freeze, R.A. and Cherry, J.A., 1979. Groundwater. Prentice-Hall, Englewood Cliffs, NJ.

United States Environmental Protection Agency (EPA), Accessed 2008 [WWW document]. URL: <http://www.epa.gov/safewater/contaminants/index.html>.



## **APPENDIX A**

### **Leader Creek Inn Drinking Water Protection Area Location Map (Map A)**

Public Water Well System for PWS #261402.001 Leader Creek Inn



Legend



- Class B Public Water System Well
- Groundwater Protection Zones**
- Zone A Protection Area - Several Months Travel Time
- Zone B Protection Area - 2 Years Travel Time

Data Sources:  
Contaminant Sources, Public Water System Wells, Alaska Department of Environmental Conservation (ADEC)

All other data:  
Alaska Statewide Digital Mapping Initiative (SDMI)

Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class B Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.



Leader Creek Inn  
PWS 261402.001  
Appendix A Map A

## **APPENDIX B**

### **Contaminant Source Inventory and Risk Ranking for Leader Creek Inn (Tables 1-4)**

**Table 1**

**Contaminant Source Inventory for  
LEADER CREEK INN**

**PWSID 261402.001**

<b>Contaminant Source Type</b>	<b>Contaminant Source ID</b>	<b>CS ID tag</b>	<b>Zone</b>	<b>Map Number</b>	<b>Comments</b>
Septic systems (serves one single-family home)	R02	R02	A	C	10 assumed septic systems
Tanks, heating oil, residential (above ground)	R08	R08	A	C	10 assumed heating oil tanks
Tanks, diesel (above ground)	T06	T06-01	A	C	
Tanks, diesel (above ground)	T06	T06-02	A	C	
Tanks, diesel (above ground)	T06	T06-03	A	C	
Tanks, gasoline (above ground)	T10	T10-01	A	C	
Water supply wells	W09	W09-01	A	C	
Boat yards and marinas	X15	X15-01	A	C	
Highways and roads, paved (cement or asphalt)	X20	X20	A	C	1 road

**Table 2**

*Contaminant Source Inventory and Risk Ranking for  
LEADER CREEK INN  
Sources of Bacteria and Viruses*

**PWSID 261402.001**

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Septic systems (serves one single-family home)	R02	R02	A	Low	C	10 assumed septic systems
Highways and roads, paved (cement or asphalt)	X20	X20	A	Low	C	1 road

Table 3

*Contaminant Source Inventory and Risk Ranking for  
LEADER CREEK INN  
Sources of Nitrates/Nitrites*

PWSID 261402.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Septic systems (serves one single-family home)	R02	R02	A	Low	C	10 assumed septic systems
Highways and roads, paved (cement or asphalt)	X20	X20	A	Low	C	1 road

Table 4

*Contaminant Source Inventory and Risk Ranking for  
LEADER CREEK INN  
Sources of Volatile Organic Chemicals*

PWSID 261402.001


<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Septic systems (serves one single-family home)	R02	R02	A	Low	C	10 assumed septic systems
Tanks, heating oil, residential (above ground)	R08	R08	A	Medium	C	10 assumed heating oil tanks
Tanks, diesel (above ground)	T06	T06-01	A	Medium	C	
Tanks, diesel (above ground)	T06	T06-02	A	Medium	C	
Tanks, diesel (above ground)	T06	T06-03	A	Medium	C	
Tanks, gasoline (above ground)	T10	T10-01	A	Medium	C	
Boat yards and marinas	X15	X15-01	A	Low	C	
Highways and roads, paved (cement or asphalt)	X20	X20	A	Low	C	1 road

## **APPENDIX C**

### **Leader Creek Inn Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)**



**Public Water Well System for PWS #261402.001 Leader Creek Inn  
Showing Potential and Existing Sources of Contamination**



**Legend**

- Class B Public Water System Well
- Groundwater Protection Zones**
- Zone A Protection Area - Several Months Travel Time
- Zone B Protection Area - 2 Years Travel Time
- Potential and Existing Contaminant Sources**
- Tanks, diesel (above ground) (T06)
- Tanks, gasoline (above ground) (T10)
- Water supply wells (W09)
- Boat yards and marinas (X15)

**Data Sources:**  
Contaminant Sources, Public Water System Wells, Alaska Department of Environmental Conservation (ADEC)

**All other data:**  
Alaska Statewide Digital Mapping Initiative (SDMI)

**Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class B Public Water Systems" published by ADEC**

**URS Corporation does not guarantee the accuracy or validity of the data provided.**

