

Source Water Assessment

A Hydrogeologic Susceptibility and
Vulnerability Assessment for
Wards Cove Packing-South Naknek Fish Plant
Drinking Water System,
Naknek, Alaska

PWSID # 261151.001

March 2004

DRINKING WATER PROTECTION PROGRAM REPORT 1166
Alaska Department of Environmental Conservation

Source Water Assessment for
Wards Cove Packing-South Naknek Fish Plant
Drinking Water System
Naknek, Alaska

PWSID# 261151.001

DRINKING WATER PROTECTION PROGRAM REPORT 1166

The Drinking Water Protection Program (DWPP) is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (ADEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. It is anticipated this assessment will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of public drinking water source. If you have any additional information that may affect the results of this assessment, please contact the Program Coordinator of DWPP, (907) 269-7521.

CONTENTS

EXECUTIVE SUMMARY	1	INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES.....	2
WARDS COVE PACKING - SOUTH NAKNEK FISH PLANT PUBLIC DRINKING WATER SYSTEM.....	1	RANKING OF CONTAMINANT RISKS.....	2
WARDS COVE PACKING - SOUTH NAKNEK FISH PLANT DRINKING WATER PROTECTION AREA.....	2	VULNERABILITY OF WARDS COVE PACKING - SOUTH NAKNEK FISH PLANT DRINKING WATER SYSTEM	3

TABLES

Table 1. Definition of Zones.....	2
Table 2. Susceptibility.....	3
Table 3. Contaminant Risks.....	4
Table 4. Overall Vulnerability.....	4

APPENDICES

APPENDIX	A. Wards Cove Packing-South Naknek Fish Plant Drinking Water Protection Area (Map A)
	B. Contaminant Source Inventory for Wards Cove Packing-South Naknek Fish Plant (Table 1) Contaminant Source Inventory and Risk Ranking for Wards Cove Packing-South Naknek Fish Plant –Bacteria and Viruses (Table 2) Contaminant Source Inventory and Risk Ranking for Wards Cove Packing-South Naknek Fish Plant – Nitrates/Nitrites (Table 3) Contaminant Source Inventory and Risk Ranking for Wards Cove Packing-South Naknek Fish Plant – Volatile Organic Chemicals (Table 4)
	C. Wards Cove Packing-South Naknek Fish Plant Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)
	D. Vulnerability Analysis for Contaminant Source Inventory and Risk Ranking for Wards Cove Packing-South Naknek Fish Plant Public Drinking Water Source (Charts 1 – 8)

Source Water Assessment for Ward's Cove Packing, South Naknek Fish Plant

Source of Public Drinking Water, Naknek, Alaska

Drinking Water Protection Program Alaska Department of Environmental Conservation

EXECUTIVE SUMMARY

Ward's Cove Packing, South Naknek Fish Plant has a total of two water wells. The primary well used as a drinking water source was installed in 1994. This source water assessment report is exclusively limited to the primary water well (PWSID 261151.001). The second water well was installed in 1969, and is used to supplement water supply demands. Based on available data, it is assumed that drinking water from each well is treated by independent systems. No Public Water System (PWS) Identification (ID) was listed for the second well.

The primary water well is a Class B (transient/non-community) water system located immediately south of the processing facility in Naknek, Alaska. The wellhead received a susceptibility rating of **Low** and the aquifer received a susceptibility rating of **High**. Combining these two ratings produces a **Low** rating for the natural susceptibility of the well. Identified potential and current sources of contaminants for the primary public drinking water source include: seafood processing, highways and roads, and a landfill. These identified potential and existing sources of contamination are considered as sources of bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals. Overall, the primary water well received a vulnerability rating of **Medium** for the bacteria and viruses, a vulnerability rating of **High** for nitrates and nitrites, and a vulnerability rating of **Medium** for volatile organic chemicals contaminant categories.

WARDS COVE PACKING-SOUTH NAKNEK FISH PLANT PUBLIC DRINKING WATER SYSTEM

The primary well (PWSID 261151.001) is a Class B (transient/non-community) public water system. The system consists of one well located south of the processing plant in Naknek, Alaska (Sec. 03, T017S, R047W, Seward Meridian; see Map A of Appendix A). Naknek is the primary fishery center in Bristol Bay, located about 12 miles northwest of King Salmon and 300 miles southwest of Anchorage. The

community has a population of 642 (ADCED, 2003). The Wards Cove Packing-South Naknek Fish Plant has a seasonal resident population of about 150, housed in bunkhouses on the cannery property. Average annual precipitation in Naknek is 20 inches, including approximately 45 inches of snowfall. Temperatures range from 42 to 63°F in summer and -4 to 16°F in winter. Temperatures can be as extreme as -46 to 88°F.

The community of Naknek, near the Wards Cove Packing-South Naknek Fish Plant, gets most of their water supply from individual wells. Most households are served by the piped sewage collection system operated by the Borough and the remaining households have individual septic tanks (ADCED, 2003). Naknek receives electrical power from the Naknek Electric Association operated by the REA Cooperative. Power generating facilities are fueled by diesel. Refuse is collected by the Patterson Sanitation Company and trucked to the Borough operated landfill located five miles outside of the community (ADCED, 2003).

According to information supplied by ADEC for the Ward's Cove Packing-South Naknek Fish Plant PWS the depth of the primary water well is 246 feet below the ground surface. Based on available construction details for a nearby PWSID (260935.001), this well is likely screened in an unconfined aquifer. In comparison to confined aquifers, unconfined aquifers are likely to be more susceptible to groundwater impacts resulting from the downward migration of surface contaminants. Based on available data for PWSID's in the local area, the well is assumed to be screened in a sandy material. The well is not located in a floodplain.

This system operates from May to August and serves approximately 150 seasonal residents through one service connection. Water from both the primary and secondary wells is injected with chlorine as the water is piped to the storage tanks. Treated water is stored in several tanks totaling 185,000 gallons of total storage capacity.

Information acquired from a May 1999 sanitary

survey for the public water system indicated that the land surface was sloped away from the well. Generally, land surfaces that slope away from the wellhead promote surface water drainage, which reduces potential of contaminant migration down the well casing annulus. The well is grouted according to ADEC regulations. Proper grouting provides added protection against contaminants traveling along the well casing annulus and into source waters.

Naknek is located in an area that has been mapped as being underlain by isolated masses of permafrost; predominantly fine-grained deposits. Permafrost is usually found either at a considerable depth as relict permafrost or near the surface as thin lenses of small extent where ground insulation is high or low. The terrain in this area consists of low hills with many shallow lakes. The lakes resulted from the delayed melting of buried ice blocks (ADOT&PF, 1982).

WARDS COVE PACKING-SOUTH NAKNEK FISH PLANT DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. These areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the area that contributes water to the well, the groundwater recharge area. This area is designated as the drinking water protection area (DWPA). Because releases of contaminants within the protection area are most likely to impact the drinking water well, this area will serve as the focus for voluntary protection efforts. An analytical calculation was used to determine the size and shape of the DWPA for the Wards Cove Packing-South Naknek Fish Plant PWS. The input parameters describing the attributes of the aquifer in this calculation were adopted from Groundwater (Freeze and Cherry, 1979). Available geology and groundwater contours were also considered to take into account any uncertainties in groundwater flow and aquifer characteristics to arrive at a meaningful protection area.

The protection areas established for wells by the ADEC are usually separated into four zones, limited by the watershed. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well (Please refer

to the Guidance Manual for Class B Public Water Systems for additional information).

The time of travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the four protection area zones for wells and the calculated time-of-travel for each:

Table 1. Definition of Zones

Zone	Definition
A	¼ the distance for the 2-yr. time-of-travel
B	Less than the 2 year time-of-travel
C	Less Than the 5 year time-of-travel
D	Less than the 10 year time-of-travel

The DWPA for the Wards Cove Packing-South Naknek Fish Plant PWS was determined using an analytical calculation and includes Zone A, B, C, and D (See Map A of Appendix A).

INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES

The Drinking Water Protection Program has completed an inventory of potential and existing sources of contamination within the Wards Cove Packing-South Naknek Fish Plant DWPA. This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class B public water system assessments, three categories of drinking water contaminants were inventoried. They include:

- Bacteria and viruses,
- Nitrates and/or nitrites,
- Volatile organic chemicals.

The sources are displayed on Map C of Appendix C and summarized in Table 1 of Appendix B.

RANKING OF CONTAMINANT RISKS

Once the potential and existing sources of contamination have been identified, they are assigned a ranking according to what type and level of risk they represent. Ranking of contaminant risks for a “potential” or “existing” source of contamination is a

function of toxicity and volumes of specific contaminants associated with that source. Rankings include:

- Low,
- Medium,
- High, and
- Very High.

The time-of-travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. Bacteria and Viruses are only inventoried in Zones A and B because of their short life span. Only “Very High” and “High” rankings are inventoried within the outer Zone D due to the probability of contaminant dilution by the time the contaminants get to the well.

Tables 2 through 4 in Appendix B contain the ranking of potential and existing sources of contamination with respect to bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals.

VULNERABILITY OF THE WARDS COVE PACKING-SOUTH NAKNEK FISH PLANT DRINKING WATER SYSTEM

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural susceptibility, and
- Contaminant risks.

Appendix D contains eight charts, which together form the ‘Vulnerability Analysis’ for a source water assessment for a public drinking water source. Chart 1 analyzes the ‘Susceptibility of the Wellhead’ to contamination by looking at the construction of the well and its surrounding area. Chart 2 analyzes the ‘Susceptibility of the Aquifer’ to contamination by looking at the naturally occurring attributes of the water source and influences on the groundwater system that might lead to contamination. Chart 3 analyzes ‘Contaminant Risks’ for the drinking water source with respect to bacteria and viruses. The ‘Contaminant Risks’ portion of the analysis considers potential sources of contaminants as well as a review of contamination that has or may have occurred, but has not arrived or been detected at the well. Lastly, Chart 4 contains the ‘Vulnerability Analysis for Bacteria and Viruses’. Charts 5 through 8 contain the Contaminant Risks and Vulnerability Analyses for nitrates and nitrites and volatile organic chemicals, respectively.

A score for the Natural Susceptibility is reached by considering the properties of the well and the aquifer.

Susceptibility of the Wellhead (0 – 25 Points)
(Chart 1 of Appendix D)

+

Susceptibility of the Aquifer (0 – 25 Points)
(Chart 2 of Appendix D)

=

Natural Susceptibility (Susceptibility of the Well)
(0 – 50 Points)

A ranking is assigned for the Natural Susceptibility according to the point score:

Natural Susceptibility Ratings	
40 to 50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

The Wards Cove Packing-South Naknek Fish Plant’s primary water well is in an unconfined aquifer. Unconfined aquifers are more susceptible to potential groundwater quality impacts posed by the migration of surface water contaminants downward from the surface. Table 2 shows the Susceptibility scores and ratings for this PWS.

Table 2. Susceptibility

	Score	Rating
Susceptibility of the Wellhead	0	Low
Susceptibility of the Aquifer	15	High
Natural Susceptibility	15	Low

Contaminant risks to a drinking water source depend on the type, number or density, and distribution of contaminant sources. This score has been derived from an examination of existing and historical contamination that has been detected at the drinking water source through routine sampling. It also evaluates potential sources of contamination. Flow charts are used to assign a point score, and ratings are assigned in the same way as for the natural susceptibility:

Contaminant Risk Ratings	
40 to 50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants.

Table 3. Contaminant Risks

Category	Score	Rating
Bacteria and Viruses	35	High
Nitrates and/or Nitrites	45	Very High
Volatile Organic Chemicals	32	High

Finally, an overall vulnerability score is assigned for each water system by combining each of the contaminant risk scores with the natural susceptibility score:

$$\begin{array}{r}
 \text{Natural Susceptibility (0 – 50 points)} \\
 + \\
 \text{Contaminant Risks (0 – 50 points)} \\
 = \\
 \text{Vulnerability of the} \\
 \text{Drinking Water Source to Contamination (0 – 100)}.
 \end{array}$$

Again, rankings are assigned according to a point score:

Overall Vulnerability Ratings	
80 to 100 pts	Very High
60 to < 80 pts	High
40 to < 60 pts	Medium
< 40 pts	Low

Table 4 contains the overall vulnerability scores (0 – 100) and ratings for each of the three categories of drinking water contaminants. Note: scores are rounded off to the nearest five.

Table 4. Overall Vulnerability

Category	Score	Rating
Bacteria and Viruses	50	Medium
Nitrates and Nitrites	60	High
Volatile Organic Chemicals	50	Medium

Bacteria and Viruses

The contaminant risk for bacteria and viruses is **High**. The risk is primarily attributed to the presence of the landfill in Zone B and the seafood processing

in Zone A (See Chart 3 – Contaminant Risks for Bacteria and Viruses in Appendix D).

No positive bacteria counts were reported in recent (previous five years) sampling events. Only a small amount of bacteria and viruses are required to endanger public health.

After combining the contaminant risk for bacteria and viruses with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

Nitrates and Nitrites

The contaminant risk for nitrates and nitrites is **Very High**. The high risk to this source of public drinking water is primarily attributed to the landfill in Zone A and partially attributed to seafood processing and roads (See Chart 5 - Contaminant Risks for Nitrates and/or Nitrites in Appendix D).

Nitrates are very mobile, moving at approximately the same rate as water. The sampling history for this well indicates that only low levels of nitrates have been detected in the water. Nitrate concentrations in uncontaminated groundwater are typically less than 2 mg/L; therefore, nitrate concentrations above 2 mg/L may be indicative of man-made sources.

Nitrate levels are often derived from the decomposition of organic matter in soils. Although the nitrate source is unknown, such occurrences may be attributed to septic systems or other sources. After combining the contaminant risk for nitrates and nitrites with the natural susceptibility of the well, the overall vulnerability of the well to nitrate and nitrite contamination is **High**.

Volatile Organic Chemicals

The contaminant risk for volatile organic chemicals is **High**. The risk is primarily attributed to the presence of the landfill in Zone B and partially attributed to roads in Zones A, B, and C.

No recent sampling data was available in ADEC records for the South Naknek Fish Plant (See Chart 7 – Contaminant Risks for Volatile Organic Chemicals in Appendix D).

After combining the contaminant risk for volatile organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

Using the Source Water Assessment

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Ward's Cove Packing Company-South Naknek Fish Plant and the community of Naknek to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of the drinking water source.


REFERENCES

- Alaska Department of Community and Economic Development (ADCED), 2003 [WWW document]. URL: http://www.dced.state.ak.us/cbd/commdb/CF_COMDB.htm
- Alaska Department of Environmental Conservation, Contaminated Sites Database, 2003 [WWW database], URL http://www.state.ak.us/dec/dspar/csites/cs_search.htm
- Alaska Department of Environmental Conservation, Leaking Underground Storage Tank Database, 2003 [WWW database], URL http://www.dec.state.ak.us/spar/stp/ust/search/fac_search.asp
- Alaska Department of Transportation and Public Facilities (ADOT&PF), 1982, Engineering Geology and Soils Report, North Naknek Materials Investigation.
- Freeze, R. A., and Cherry, J.A. 1979, Groundwater, Prentice-Hall, Englewood Cliffs, New Jersey
- United States Environmental Protection Agency (EPA), 2002 [WWW document]. URL <http://www.epa.gov/safewater/mcl.html>.

APPENDIX A

Drinking Water Protection Area Location Map (Map A)

Public Water Well System for PWS #261151.001 South Naknek Fish Plant (Yard Arm Knot/Yack Fisheries)



LEGEND

- Public Water System Well
- Hydrography/Physical**
 - Parcels
 - Stream
 - Lake or Pond
 - Contours
- Transportation**
 - Primary Route (Class 1)
 - Secondary Route (Class 2)
 - Road (Class 3)
 - Road (Class 4)
 - Road (Class 5, Four-wheel drive)
 - Road Ferry Crossing
- Groundwater Protection Zones**
 - Zone A Protection Area— Several Months Travel Time
 - Zone B Protection Area— 2 Years Travel Time
 - Zone C Protection Area— 5 Years Travel Time
 - Zone D Protection Area— 10 Years Travel Time




Data Sources:
 Contaminant Sources, Public Water System Wells, Contours
 Alaska Department of Environmental Conservation (ADEC)

Critical Facilities, Federal Emergency Management Agency (FEMA)

All other data:
 United States Geological Survey (USGS)

Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class B Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.



South Naknek Fish Plant (Yard Arm Knot/ Yack Fisheries)
 PWS 261151.001

APPENDIX B

Contaminant Source Inventory and Risk Rankings (Tables 1-4)

Table 1

**Contaminant Source Inventory for
Wards Cove Packing - S. Naknek Fish Plant**

PWSID 261151.00.

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Map Number	Comments
Seafood processing	N10	N10-01	A	C	
Residential Areas	R01	R01-01	A	C	Assumed that 1 to 50 acres of residential area located in Zone A
Water supply wells	W09	W09-01	A	C	Old cannery water well installed in 1969, supplements current water demands
Highways and roads, dirt/gravel	X24	X24-01	A	C	Assumed that 1 to 20 roads are located in Zone A
Landfills (municipal; Class III)	D51	D51-01	B	C	Landfill/Incinerator
Highways and roads, dirt/gravel	X24	X24-02	B	C	2 roads located in Zone B
Highways and roads, dirt/gravel	X24	X24-03	C	C	1 road located in Zone C

Table 2

*Contaminant Source Inventory and Risk Ranking for
Wards Cove Packing - S. Naknek Fish Plant
Sources of Bacteria and Viruses*

PWSID 261151.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Seafood processing	N10	N10-01	A	Medium	C	
Residential Areas	R01	R01-01	A	Low	C	Assumed that 1 to 50 acres of residential area located in Zone A
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assumed that 1 to 20 roads are located in Zone A
Landfills (municipal; Class III)	D51	D51-01	B	High	C	Landfill/Incinerator
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	2 roads located in Zone B

Table 3

*Contaminant Source Inventory and Risk Ranking for
Wards Cove Packing - S. Naknek Fish Plant
Sources of Nitrates/Nitrites*

PWSID 261151.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Seafood processing	N10	N10-01	A	Low	C	
Residential Areas	R01	R01-01	A	Low	C	Assumed that 1 to 50 acres of residential area located in Zone A
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assumed that 1 to 20 roads are located in Zone A
Landfills (municipal; Class III)	D51	D51-01	B	Very High	C	Landfill/Incinerator
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	2 roads located in Zone B
Highways and roads, dirt/gravel	X24	X24-03	C	Low	C	1 road located in Zone C

Table 4

*Contaminant Source Inventory and Risk Ranking for
Wards Cove Packing - S. Naknek Fish Plant
Sources of Volatile Organic Chemicals*


PWSID 261151.001

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Residential Areas	R01	R01-01	A	Low	C	Assumed that 1 to 50 acres of residential area located in Zone A
Highways and roads, dirt/gravel	X24	X24-01	A	Low	C	Assumed that 1 to 20 roads are located in Zone A
Landfills (municipal; Class III)	D51	D51-01	B	High	C	Landfill/Incinerator
Highways and roads, dirt/gravel	X24	X24-02	B	Low	C	2 roads located in Zone B
Highways and roads, dirt/gravel	X24	X24-03	C	Low	C	1 road located in Zone C

APPENDIX C

Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)

**Public Water Well System for PWS #261151.001 South Naknek Fish Plant
Showing Potential and Existing Sources of Contamination**



LEGEND

- Public Water System Well
- Hydrography/Physical**
 - Parcels
 - Stream
 - Lake or Pond
 - Contours
- Transportation**
 - Primary Route (Class 1)
 - Secondary Route (Class 2)
 - Road (Class 3)
 - Road (Class 4)
 - Road (Class 5, Four-wheel drive)
 - Road Ferry Crossing
- Groundwater Protection Zones**
 - Zone A Protection Area— Several Months Travel Time
 - Zone B Protection Area— 2 Years Travel Time
 - Zone C Protection Area— 5 Years Travel Time
 - Zone D Protection Area— 10 Years Travel Time
- Existing or Potential Contaminant Sources**
 - Landfills (municipal; Class III) (D51)



Data Sources:
Contaminant Sources, Public Water System Wells, Contours
Alaska Department of Environmental Conservation (ADEC)

Critical Facilities, Federal Emergency Management Agency (FEMA)

All other data:
United States Geological Survey (USGS)

Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class B Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.



APPENDIX D

Vulnerability Analysis for Public Drinking Water Source (Charts 1-8)

Chart 1. Susceptibility of the wellhead - Wards Cove Packing - S. Naknek (261151.001)




Chart 2. Susceptibility of the aquifer - Wards Cove Packing - S. Naknek (261151.001)




Chart 3. Contaminant risks for Wards Cove Packing - S. Naknek (261151.001) - Bacteria & Viruses




Chart 3. Contaminant risks for Wards Cove Packing - S. Naknek (261151.001) - Bacteria & Viruses




Chart 4. Vulnerability analysis for Wards Cove Packing - S. Naknek (261151.001) - Bacteria & Viruses




Chart 5. Contaminant risks for Wards Cove Packing - S. Naknek (261151.001) - Nitrates and Nitrites




Chart 5. Contaminant risks for Wards Cove Packing - S. Naknek (261151.001) - Nitrates and Nitrites






Chart 5. Contaminant risks for Wards Cove Packing - S. Naknek (261151.001) - Nitrates and Nitrites




Chart 6. Vulnerability analysis for Wards Cove Packing - S. Naknek (261151.001) - Nitrates and Nitrites




Chart 7. Contaminant risks for Wards Cove Packing - S. Naknek (261151.001) - Volatile Organic Chemicals




Chart 7. Contaminant risks for Wards Cove Packing - S. Naknek (261151.001) - Volatile Organic Chemicals





Chart 7. Contaminant risks for Wards Cove Packing - S. Naknek (261151.001) - Volatile Organic Chemicals




Chart 8. Vulnerability analysis for Wards Cove Packing - S. Naknek (261151.001) - Volatile Organic Chemicals

