



Source Water Assessment

A Hydrogeologic Susceptibility and
Vulnerability Assessment for
Nulato River Well
Drinking Water System,
Nulato, Alaska

PWSID # 360785.001

June 2004

DRINKING WATER PROTECTION PROGRAM REPORT 1349
Alaska Department of Environmental Conservation

Source Water Assessment for Nulato River Well Drinking Water System Nulato, Alaska

PWSID # 360785.001

DRINKING WATER PROTECTION PROGRAM REPORT 1349

The Drinking Water Protection Program (DWPP) is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (ADEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. It is anticipated this assessment will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of public drinking water source. If you have any additional information that may affect the results of this assessment, please contact the Program Coordinator of DWPP, (907) 269-7521.

CONTENTS

| | | | |
|-------------------------------------|---|-------------------------------------|---|
| EXECUTIVE SUMMARY..... | 1 | INVENTORY OF POTENTIAL AND EXISTING | |
| PUBLIC DRINKING WATER SYSTEM | 1 | CONTAMINANT SOURCES | 2 |
| DRINKING WATER PROTECTION AREA..... | 2 | RANKING OF CONTAMINANT RISKS | 2 |
| | | VULNERABILITY OF DRINKING WATER | |
| | | SYSTEM | 3 |

TABLES

| | |
|-------------------------------------|---|
| Table 1. Definition of Zones | 2 |
| Table 2. Susceptibility | 3 |
| Table 3. Contaminant Risks | 3 |
| Table 4. Overall Vulnerability..... | 4 |

APPENDICES

| | |
|----------|--|
| APPENDIX | A. Nulato River Well Drinking Water Protection Area (Map A) |
| | B. Contaminant Source Inventory for Nulato River Well (Table 1) |
| | Contaminant Source Inventory and Risk Ranking for Nulato River Well |
| | – Bacteria and Viruses (Table 2) |
| | Contaminant Source Inventory and Risk Ranking for Nulato River Well |
| | – Nitrates/Nitrites (Table 3) |
| | Contaminant Source Inventory and Risk Ranking for Nulato River Well |
| | – Volatile Organic Chemicals (Table 4) |
| | Contaminant Source Inventory and Risk Ranking for Nulato River Well |
| | – Heavy Metals, Cyanide and Other Inorganic Chemicals (Table 5) |
| | Contaminant Source Inventory and Risk Ranking for Nulato River Well |
| | – Other Organic Chemicals (Table 6) |
| | C. Nulato River Well Drinking Water Protection Area and Potential |
| | and Existing Contaminant Sources (Map C) |
| | D. Vulnerability Analysis for Contaminant Source Inventory and Risk Ranking for Nulato River |
| | Well Public Drinking Water Source (Charts 1 – 14) |

Source Water Assessment for Nulato River Well Source of Public Drinking Water, Nulato, Alaska

Drinking Water Protection Program Alaska Department of Environmental Conservation

EXECUTIVE SUMMARY

The Nulato River Well has one Public Water System (PWS) well. The well (PWS No 360785.001) has been used as a drinking water source since it was drilled in 1992.

The well is a Class A (community and non-transient non-community) water system located approximately 220 feet from the Nulato River, 1.25 miles west of Nulato, Alaska. Available records indicate that there is secondary storage of drinking water, with a capacity of 130,000-gallons, and that the drinking water source is not treated. This system operates year round and serves approximately 365 residents through 80 service connections. The wellhead received a susceptibility rating of **Very High** and the aquifer received a susceptibility rating of **Medium**. Combining these two ratings produce a **High** rating for the natural susceptibility of the well.

Identified potential and current sources of contaminants for the public drinking water source include roads. These identified potential and existing sources of contamination are considered as sources of bacteria and viruses, nitrates and/or nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals contaminant categories.

Overall, the water well received a vulnerability rating of **Very High** for the bacteria and viruses and a vulnerability rating of **Medium** for nitrates and nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals and other organic chemicals, and a vulnerability rating of **Low** for the synthetic organic chemicals contaminant categories.

PUBLIC DRINKING WATER SYSTEM

The Nulato River Well well is a Class A (community/non-transient/non-community) public water system. The system located approximately 220 feet from the Nulato River, 1.25 miles west of Nulato, Alaska (Sec. 08, T009S, R004E, Kateel River

Meridian; see Map A of Appendix A). Nulato is located on the west bank of the Yukon River. The community lies 35 miles west of Galena, and 310 air miles west of Fairbanks. Nulato has a population of 342 (ADCED, 2003). Average annual precipitation in Nulato is 15.6 inches, including approximately 74 inches of snowfall. Temperatures range from the 70's°F in summer and -40°F in the winter. Temperatures can be as extreme as -55 to 90°F.

The community of Nulato obtains their water supply from community wells. Most sewage is collected via a piped system operated by City. The remaining households utilize honey bucket pits or outhouses (ADCED, 2003). Nulato receives electrical power from AVEC, a REA Cooperative. Power generating facilities are fueled by diesel. Refuse is collected by individuals and transported to the landfill (ADCED, 2003).

According to information supplied by ADEC for the Nulato River Well PWS, the depth of the primary water well is 80 feet below the ground surface. Available well construction details indicate that the well is screened. The well is completed in a confined aquifer, and is located within a floodplain.

Information acquired from an June 1998 sanitary survey for the public water system indicated that the land surface was sloped away from the well. Generally, land surfaces that slope away from the wellhead promote surface water drainage, which reduces the potential of contaminant migration down the well casing annulus. The sanitary survey indicates that the well is grouted according to ADEC regulations. Proper grouting provides added protection against contaminants traveling along the well casing annulus and into source waters.

Nulato is located in the Nulato Hills, on the west bank of the Yukon River. The low terrace on which the present community of Nulato lies is underlain by silt, sand, and gravel alluvium with finer grain deposits predominant near the surface. Low hills rise above the alluvial surface to the north and east of the community. The hills are underlain by compact silt (loess) overlying colluvial and alluvial silt and sand

underlain at varying depths by shale, siltstone, and muddy sandstone (I.H.S. 1994).

Soils in the area are generally characterized by moderately well-drained silts and sands (I.H.S. 1994).

DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. These areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the area that contributes water to the well, the groundwater recharge area. This area is designated as the drinking water protection area (DWPA). Because releases of contaminants within the protection area are most likely to impact the drinking water well, this area will serve as the focus for voluntary protection efforts. An analytical calculation was used to determine the size and shape of the DWPA for the Nulato River Well PWS. The input parameters describing the attributes of the aquifer in this calculation were adopted from Groundwater (Freeze and Cherry, 1979). Available geology and groundwater contours were also considered to take into account any uncertainties in groundwater flow and aquifer characteristics to arrive at a meaningful protection area.

The protection areas established for wells by the ADEC are usually separated into four zones, limited by the watershed. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well (Please refer to the Guidance Manual for Class A Public Water Systems for additional information).

The time of travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the four protection area zones for wells and the calculated time-of-travel for each:

Table 1. Definition of Zones

| Zone | Definition |
|-------------|---|
| A | ¼ the distance for the 2-yr. time-of-travel |
| B | Less than the 2 year time-of-travel |
| C | Less Than the 5 year time-of-travel |
| D | Less than the 10 year time-of-travel |

The DWPA for the Nulato River Well PWS was determined using an analytical calculation and includes Zones A, B, C, and D (See Map A of Appendix A).

INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES

The Drinking Water Protection Program has completed an inventory of potential and existing sources of contamination within the Nulato River Well DWPA. This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class A public water system assessments, six categories of drinking water contaminants were inventoried. They include:

- ☞ Bacteria and viruses,
- ☞ Nitrates and/or nitrites,
- ☞ Volatile organic chemicals,
- ☞ Heavy metals, cyanide and other inorganic chemicals,
- ☞ Synthetic organic chemicals,
- ☞ Other organic chemicals.

The sources are displayed on Map C of Appendix C and summarized in Table 1 of Appendix B.

RANKING OF CONTAMINANT RISKS

Once the potential and existing sources of contamination have been identified, they are assigned a ranking according to what type and level of risk they represent. Ranking of contaminant risks for a “potential” or “existing” source of contamination is a function of toxicity and volumes of specific contaminants associated with that source. Rankings include:

- ☞ Low,
- ☞ Medium,
- ☞ High, and
- ☞ Very High.

The time-of-travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. Bacteria and Viruses are only inventoried in Zones A and B

because of their short life span. Only “Very High” and “High” rankings are inventoried within the outer Zone D due to the probability of contaminant dilution by the time the contaminants get to the well. Tables 2 through 4 in Appendix B contain the ranking of potential and existing sources of contamination with respect to bacteria and viruses, nitrates and/or nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals.

VULNERABILITY OF THE DRINKING WATER SYSTEM

Vulnerability of a drinking water source to contamination is a combination of two factors:

- # Natural susceptibility, and
- # Contaminant risks.

Appendix D contains fourteen charts, which together form the ‘Vulnerability Analysis’ for a source water assessment for a public drinking water source. Chart 1 analyzes the ‘Susceptibility of the Wellhead’ to contamination by looking at the construction of the well and its surrounding area. Chart 2 analyzes the ‘Susceptibility of the Aquifer’ to contamination by looking at the naturally occurring attributes of the water source and influences on the groundwater system that might lead to contamination. Chart 3 analyzes ‘Contaminant Risks’ for the drinking water source with respect to bacteria and viruses. The ‘Contaminant Risks’ portion of the analysis considers potential sources of contaminants as well as a review of contamination that has or may have occurred, but has not arrived or been detected at the well. Chart 4 contains the ‘Vulnerability Analysis for Bacteria and Viruses’. Charts 5 through 14 contain the Contaminant Risks and Vulnerability Analyses for nitrates and nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals, respectively.

A score for the Natural Susceptibility is reached by considering the properties of the well and the aquifer.

Susceptibility of the Wellhead (0 – 25 Points)
(Chart 1 of Appendix D)

+

Susceptibility of the Aquifer (0 – 25 Points)
(Chart 2 of Appendix D)

=

Natural Susceptibility (Susceptibility of the Well)

(0 – 50 Points)

A ranking is assigned for the Natural Susceptibility according to the point score:

| Natural Susceptibility Ratings | |
|--------------------------------|-----------|
| 40 to 50 pts | Very High |
| 30 to < 40 pts | High |
| 20 to < 30 pts | Medium |
| < 20 pts | Low |

The Nulato River Well’s water well is in a confined aquifer. Confined aquifers are less susceptible to potential groundwater quality impacts posed by the migration of surface water contaminants downward from the surface. Table 2 shows the susceptibility scores and ratings for this PWS.

Table 2. Susceptibility

| | Score | Rating |
|--------------------------------|-------|-----------|
| Susceptibility of the Wellhead | 20 | Very High |
| Susceptibility of the Aquifer | 11 | Medium |
| Natural Susceptibility | 31 | High |

Contaminant risks to a drinking water source depend on the type, number or density, and distribution of contaminant sources. This score has been derived from an examination of existing and historical contamination that has been detected at the drinking water source through routine sampling. It also evaluates potential sources of contamination. Flow charts are used to assign a point score, and ratings are assigned in the same way as for the natural susceptibility:

| Contaminant Risk Ratings | |
|--------------------------|-----------|
| 40 to 50 pts | Very High |
| 30 to < 40 pts | High |
| 20 to < 30 pts | Medium |
| < 20 pts | Low |

Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants.

Table 3. Contaminant Risks

| Category | Score | Rating |
|---|-------|-----------|
| Bacteria and Viruses | 50 | Very High |
| Nitrates and/or Nitrites | 14 | Low |
| Volatile Organic Chemicals | 12 | Low |
| Heavy Metals, Cyanide and Other Inorganic Chemicals | 12 | Low |
| Synthetic Organic Chemicals | 0 | Low |
| Other Organic Chemicals | 12 | Low |

Finally, an overall vulnerability score is assigned for each water system by combining each of the contaminant risk scores with the natural susceptibility score:

$$\begin{array}{r}
 \text{Natural Susceptibility (0 – 50 points)} \\
 + \\
 \text{Contaminant Risks (0 – 50 points)} \\
 = \\
 \text{Vulnerability of the} \\
 \text{Drinking Water Source to Contamination (0 – 100).}
 \end{array}$$

Again, rankings are assigned according to a point score:

| Overall Vulnerability Ratings | |
|-------------------------------|-----------|
| 80 to 100 pts | Very High |
| 60 to < 80 pts | High |
| 40 to < 60 pts | Medium |
| < 40 pts | Low |

Table 4 contains the overall vulnerability scores (0 – 100) and ratings for each of the six categories of drinking water contaminants. Note: scores are rounded off to the nearest five.

Table 4. Overall Vulnerability

| Category | Score | Rating |
|---|-------|-----------|
| Bacteria and Viruses | 80 | Very High |
| Nitrates and Nitrites | 45 | Medium |
| Volatile Organic Chemicals | 45 | Medium |
| Heavy Metals, Cyanide and Other Inorganic Chemicals | 45 | Medium |
| Synthetic Organic Chemicals | 30 | Low |
| Other Organic Chemicals | 45 | Medium |

Bacteria and Viruses

The contaminant risk for bacteria and viruses is **Very High**. The risk is primarily attributed to the presence of bacteria and viruses in recent sampling events and roads located in Zone A (see Table 2 – Appendix B).

Coliforms (a bacteria) are found naturally in the environment and although they aren’t necessarily a health threat, they are an indicator of other potentially harmful bacteria in the water, more specifically, fecal coliforms and E. coli, which only come from human and animal fecal waste. Harmful bacteria can cause diarrhea, cramps, nausea, headaches, or other symptoms (EPA, 2002). Positive samples increase the overall vulnerability of the drinking water source, indicating that the source is susceptible to bacteria and virus contamination.

Positive bacteria counts have been reported in recent (within five years) sampling events (See Chart 3 – Contaminant Risks for Bacteria and Viruses in Appendix D). Only a small amount of bacteria and viruses are required to endanger public health.

After combining the contaminant risk for bacteria and viruses with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Very High**.

Nitrates and Nitrites

The contaminant risk for nitrates and nitrites is **Low**. The risk to this source of public drinking water is primarily attributed to the presence of roads located in Zone A (see Table 3 – Appendix B).

Nitrates are very mobile, moving at approximately the same rate as water. The sampling history for this well indicates that low levels of nitrates have been detected in recent sampling events. However, the reported concentrations of nitrates do not exceed the maximum contaminant level (MCL) of 10 mg/L. Nitrate concentrations in uncontaminated groundwater are typically less than 2 mg/L; therefore, nitrate concentrations above 2 mg/L may be indicative of man-made sources (See Chart 5 - Contaminant Risks for Nitrates and/or Nitrites in Appendix D).

Nitrate levels are often derived from the decomposition of organic matter in soils. Although the nitrate source is unknown, such occurrences may be attributed to septic systems or other sources. After combining the contaminant risk for nitrates and nitrites with the natural susceptibility of the well, the overall vulnerability of the well to nitrate and nitrite contamination is **Medium**.

Volatile Organic Chemicals

The contaminant risk for volatile organic chemicals is **Low**. The risk is primarily attributed to the presence of roads located in Zones A (see Table 4 – Appendix B).

All recent sampling data for VOC's was below detection levels for the Nulato River Well (See Chart 7 – Contaminant Risks for Volatile Organic Chemicals in Appendix D).

After combining the contaminant risk for volatile organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

Heavy Metals, Cyanide and Other Inorganic Chemicals

The contaminant risk for heavy metals, cyanide and other inorganic chemicals is **Low**. The risk is primarily attributed to the presence of roads located in Zone A (see Table 5 – Appendix B).

Based on review of recent sampling records for this public water system, moderate levels of copper have been detected in recent sampling history, but have not exceeded the MCL of 1.3 mg/L (see Chart 8 – Contaminant Risks for Heavy Metals, Cyanide, and Other Inorganic Chemicals in Appendix D).

The reported concentrations of copper are not likely to be representative of source water conditions. This analyte is likely attributed to either the water treatment process or water distribution network; therefore, no risk points were assigned based on the presence of this analyte.

After combining the contaminant risk for heavy metals, cyanide and other inorganic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

Synthetic Organic Chemicals

The contaminant risk for synthetic organic chemicals is **Low**. The risk is primarily attributed to the presence of roads located in Zones A (see Table 6 – Appendix B).

No recent sampling data was available in ADEC records for the Nulato River Well (See Chart 11 – Contaminant Risks for Synthetic Organic Chemicals in Appendix D).

After combining the contaminant risk for synthetic organic chemicals with the natural susceptibility of

the well, the overall vulnerability of the well to contamination is **Low**.

Other Organic Chemicals

The contaminant risk for other organic chemicals is **Low**. The risk is primarily attributed to the presence of roads located in Zone A (see Table 7 – Appendix B).

No recent sampling data was available in ADEC records for the Nulato River Well (See Chart 13 – Contaminant Risks for Other Organic Chemicals in Appendix D).

After combining the contaminant risk for other organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

Using the Source Water Assessment

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of the community of Nulato to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of the drinking water source.

REFERENCES

Alaska Department of Community and Economic Development (ADCED), 2003 [WWW document]. URL:
http://www.dced.state.ak.us/cbd/commdb/CF_COMDB.htm

Freeze, R. A., and Cherry, J.A. 1979, Groundwater, Prentice-Hall, Englewood Cliffs, New Jersey


Information from Project Summary, Sanitation Facilities Construction, City of Nulato, Alaska, Indian Health Services (I.H.S.), Project No. AN 94-074 dated April 1994.

United States Environmental Protection Agency (EPA), 2002 [WWW document]. URL
<http://www.epa.gov/safewater/mcl.html>.

APPENDIX A

Drinking Water Protection Area Location Map (Map A)

Public Water Well System for PWS # 360785.001 Nulato River Well



LEGEND

⊕ Public Water System Well

Hydrography/Physical

- ▭ Parcels
- ~ Stream
- ▭ Lake or Pond
- ~ Contours

Transportation

- Primary Route (Class 1)
- - - Secondary Route (Class 2)
- ▬ Road (Class 3)
- ⋯ Road (Class 4)
- ⋯⋯ Road (Class 5, Four-wheel drive)



Groundwater Protection Zones

- ▭ Zone A Protection Area— Several Months Travel Time
- ▭ Zone B Protection Area— 2 Years Travel Time
- ▭ Zone C Protection Area— 5 Years Travel Time
- ▭ Zone D Protection Area— 10 Years Travel Time

Data Sources:

- Contaminant Sources, Public Water System Wells, Contours Alaska Department of Environmental Conservation (ADEC)
 - Critical Facilities, Federal Emergency Management Agency (FEMA)
- All other data:
- United States Geological Survey (USGS)
 - Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class A Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.



Nulato River Well
PWS# 360785.001
Appendix A Map A

APPENDIX B

Contaminant Source Inventory and Risk Ranking (Tables 1-6)

Table 1

**Contaminant Source Inventory for
Nulato River Well**

PWSID 360785.00

| Contaminant Source Type | Contaminant Source ID | CS ID tag | Zone | Map Number | Comments |
|---------------------------------|------------------------------|------------------|-------------|-------------------|-----------------------------------|
| Highways and roads, dirt/gravel | X24 | X24-01 | A | C | Assume 20 or less roads in Zone A |

*Contaminant Source Inventory and Risk Ranking for
Nulato River Well
Sources of Bacteria and Viruses*

PWSID 360785.001

Table 2

| <i>Contaminant Source Type</i> | <i>Contaminant Source ID</i> | <i>CS ID tag</i> | <i>Zone</i> | <i>Risk Ranking for Analysis</i> | <i>Map Number</i> | <i>Comments</i> |
|---------------------------------|------------------------------|------------------|-------------|----------------------------------|-------------------|-----------------------------------|
| Highways and roads, dirt/gravel | X24 | X24-01 | A | Low | C | Assume 20 or less roads in Zone A |

*Contaminant Source Inventory and Risk Ranking for
Nulato River Well
Sources of Nitrates/Nitrites*

PWSID 360785.001

Table 3

| <i>Contaminant Source Type</i> | <i>Contaminant Source ID</i> | <i>CS ID tag</i> | <i>Zone</i> | <i>Risk Ranking for Analysis</i> | <i>Map Number</i> | <i>Comments</i> |
|---------------------------------|------------------------------|------------------|-------------|----------------------------------|-------------------|-----------------------------------|
| Highways and roads, dirt/gravel | X24 | X24-01 | A | Low | C | Assume 20 or less roads in Zone A |

*Contaminant Source Inventory and Risk Ranking for
Nulato River Well
Sources of Volatile Organic Chemicals*

PWSID 360785.001

Table 4

| <i>Contaminant Source Type</i> | <i>Contaminant Source ID</i> | <i>CS ID tag</i> | <i>Zone</i> | <i>Risk Ranking for Analysis</i> | <i>Map Number</i> | <i>Comments</i> |
|---------------------------------|------------------------------|------------------|-------------|----------------------------------|-------------------|-----------------------------------|
| Highways and roads, dirt/gravel | X24 | X24-01 | A | Low | C | Assume 20 or less roads in Zone A |

*Contaminant Source Inventory and Risk Ranking for
Nulato River Well*

PWSID 360785.001

Table 5

Sources of Heavy Metals, Cyanide and Other Inorganic Chemicals

| <i>Contaminant Source Type</i> | <i>Contaminant Source ID</i> | <i>CS ID tag</i> | <i>Zone</i> | <i>Risk Ranking for Analysis</i> | <i>Map Number</i> | <i>Comments</i> |
|---------------------------------|------------------------------|------------------|-------------|----------------------------------|-------------------|-----------------------------------|
| Highways and roads, dirt/gravel | X24 | X24-01 | A | Low | C | Assume 20 or less roads in Zone A |

*Contaminant Source Inventory and Risk Ranking for
Nulato River Well
Sources of Other Organic Chemicals*

PWSID 360785.001


Table 6

| <i>Contaminant Source Type</i> | <i>Contaminant Source ID</i> | <i>CS ID tag</i> | <i>Zone</i> | <i>Risk Ranking for Analysis</i> | <i>Map Number</i> | <i>Comments</i> |
|---------------------------------|------------------------------|------------------|-------------|----------------------------------|-------------------|-----------------------------------|
| Highways and roads, dirt/gravel | X24 | X24-01 | A | Low | C | Assume 20 or less roads in Zone A |

APPENDIX C

Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)

**Public Water Well System for PWS # 360785.001 Nulato River Well
Sources of Existing and Potential Contamination**



LEGEND

- Public Water System Well

Hydrography/Physical

- Parcels
- Stream
- Lake or Pond
- Contours

Transportation

- Primary Route (Class 1)
- Secondary Route (Class 2)
- Road (Class 3)
- Road (Class 4)
- Road (Class 5, Four-wheel drive)

Groundwater Protection Zones

- Zone A Protection Area- Several Months Travel Time
- Zone B Protection Area- 2 Years Travel Time
- Zone C Protection Area- 5 Years Travel Time
- Zone D Protection Area- 10 Years Travel Time

Existing or Potential Contaminant Sources

There are no reported existing or potential sources of contamination within the protection zones.



Data Sources:

- Contaminant Sources, Public Water System Wells, Contours Alaska Department of Environmental Conservation (ADEC)
- Critical Facilities, Federal Emergency Management Agency (FEMA)

All other data:

- United States Geological Survey (USGS)
- Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class A Public Water Systems" published by ADEC


URS Corporation does not guarantee the accuracy or validity of the data provided.



APPENDIX D

Vulnerability Analysis for Public Drinking Water Source (Charts 1-14)

Chart 1. Susceptibility of the wellhead - Nulato River Well (PWS No. 360785.001)



| Wellhead Susceptibility Ratings | |
|---------------------------------|-----------|
| 20 to 25 pts | very high |
| 15 to < 20 pts | high |
| 10 to < 15 pts | medium |
| < 10 pts | low |

Chart 2. Susceptibility of the aquifer Nulato River Well (PWS No. 360785.001)




Chart 3. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Bacteria & Viruses




Chart 3. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Bacteria & Viruses




Chart 4. Vulnerability analysis for Nulato River Well (PWS No. 360785.001) - Bacteria & Viruses




Chart 5. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Nitrates and Nitrites




Chart 5. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Nitrates and Nitrites






Chart 5. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Nitrates and Nitrites




Chart 6. Vulnerability analysis for Nulato River Well (PWS No. 360785.001) - Nitrates and Nitrites




Chart 7. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Volatile Organic Chemicals





Chart 7. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Volatile Organic Chemicals




Chart 8. Vulnerability analysis for Nulato River Well (PWS No. 360785.001) - Volatile Organic Chemicals




Chart 9. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals







Chart 9. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals



The number and magnitude of contaminant sources in Zone A determines a risk increase. See Table 5 for inventory.

Chart 9. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals




Chart 10. Vulnerability analysis for Nulato River Well (PWS No. 360785.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals




Chart 11. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Synthetic Organic Chemicals




Chart 11. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Synthetic Organic Chemicals




Chart 11. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Synthetic Organic Chemicals




Chart 12. Vulnerability analysis for Nulato River Well (PWS No. 360785.001) - Synthetic Organic Chemicals




Chart 13. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Other Organic Chemicals




Chart 13. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Other Organic Chemicals






Chart 13. Contaminant risks for Nulato River Well (PWS No. 360785.001) - Other Organic Chemicals




Chart 14. Vulnerability analysis for Nulato River Well (PWS No. 360785.001) - Other Organic Chemicals

