



---

# Source Water Assessment

A Hydrogeologic Susceptibility and  
Vulnerability Assessment for  
Lost Lake Boy Scout Camp  
Public Drinking Water System,  
Salcha Area, Alaska  
PWSID # 370277.002

DRINKING WATER PROTECTION REPORT 1813

Alaska Department of Environmental Conservation

February, 2009

Source Water Assessment for  
Lost Lake Boy Scout Camp  
Public Drinking Water System,  
Salcha Area, Alaska  
PWSID# 370277.002

DRINKING WATER PROTECTION REPORT 1813

The Drinking Water Protection (DWP) section of the Drinking Water Program is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (DEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. It is anticipated this assessment will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of public drinking water source. If you have any additional information that may affect the results of this assessment, please contact the DWP staff at the following toll-free number 1-866-956-7656.

February, 2009

## CONTENTS

	Page		Page
Executive Summary.....	1	Ranking of Contaminant Risks .....	2
Lost Lake Boy Scout Camp		Vulnerability of Lost Lake Boy Scout Camp	
Public Drinking Water System .....	1	Drinking Water System.....	2
Lost Lake Boy Scout Camp		References.....	5
Drinking Water Protection Area.....	1	Appendix A .....	7
Inventory of Potential and		Appendix B .....	9
Existing Contaminant Sources.....	2	Appendix C .....	11

## TABLES

Table 1. Definition of Zones.....	2
Table 2. Susceptibility .....	3
Table 3. Contaminant Risks.....	3
Table 4. Overall Vulnerability.....	3

## APPENDICES

- APPENDIX
- A. Lost Lake Boy Scout Camp Drinking Water Protection Area (Map A)
  - B. Contaminant Source Inventory for Lost Lake Boy Scout Camp (Table 1)
    - Contaminant Source Inventory and Risk Ranking for Lost Lake Boy Scout Camp – Bacteria and Viruses (Table 2)
    - Contaminant Source Inventory and Risk Ranking for Lost Lake Boy Scout Camp – Nitrates/Nitrites (Table 3)
    - Contaminant Source Inventory and Risk Ranking for Lost Lake Boy Scout Camp – Volatile Organic Chemicals (Table 4)
  - C. Lost Lake Boy Scout Camp Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)

# Source Water Assessment for Lost Lake Boy Scout Camp

## Source of Public Drinking Water, Salcha Area, Alaska

---

### Drinking Water Protection Alaska Department of Environmental Conservation

#### EXECUTIVE SUMMARY

The public water system for Lost Lake Boy Scout Camp is a Class B (transient/non-community) water system consisting of two wells located on the Richardson Highway, about 16 miles south of Salcha, Alaska. This report applies only to PWSID 370277.002. PWSID 370277.001 is no longer active. The wellhead received a susceptibility rating of **Low** and the aquifer received a susceptibility rating of **High**. Combining these two ratings produces a **Low** rating for the natural susceptibility of the well. Identified potential and current sources of contaminants for Lost Lake Boy Scout Camp public drinking water source include: an assumed septic system and an assumed heating oil tank. These identified potential and existing sources of contamination are considered as sources of bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals. Overall, the public water sources for Lost Lake Boy Scout Camp received a vulnerability rating of **Low** for bacteria and viruses, **Low** for nitrates and nitrites, and **Medium** for volatile organic chemicals. This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Lost Lake Boy Scout Camp to protect public health.

#### LOST LAKE BOY SCOUT CAMP PUBLIC DRINKING WATER SYSTEM

Lost Lake Boy Scout Camp public water system is a Class B (transient/non-community) water system. The system consists of two wells located on the Richardson Highway, about 16 road miles south of Salcha, Alaska (see Map A in Appendix A). This report applies only to PWSID 370277.002. PWSID 370277.001 is no longer active.

Salcha is located 33 miles southeast of Fairbanks on the Richardson Highway and is within the Fairbanks North Star Borough. Temperatures in January range from -19 to -2 degrees Fahrenheit and from 49 to 71 degrees in July. The area receives 11.5 inches of precipitation, including 67.8 inches of snowfall (ADCCED, 2009).

About 65% of homes in Salcha use individual wells and septic systems. The rest haul water and use outhouses. Electricity is provided by Golden Valley Electric and refuse is transported to the Borough landfill (ADCCED, 2009).

According to the well log (05/14/2003), the well extends approximately 205 feet below the ground surface and is completed in bedrock.

This system operates from June through September and serves 250 non-residents through 21 service connections.

#### LOST LAKE BOY SCOUT CAMP DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. These areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the drinking water protection area. The drinking water protection area is the area circling the well (the area influenced by pumping) and also the area upgradient of the well, usually forming a parabola shape. Because releases of contaminants within the protection area are most likely to impact the well, this area will serve as the focus for voluntary protection efforts.

There are many different methods for calculating the size of protection areas. Drinking Water Protection (DWP) uses a combination of two simple groundwater flow equations, the Thiem and uniform flow equations for all groundwater wells screened in unconsolidated material. The orientation of the protection zone is then drawn using a water table elevation map (if available) or a land surface elevation map of the area. The protection zone calculated by DWP is an estimate using the available information and resources, and may differ slightly from the actual capture zone. Because of uncertainties and changing site conditions, a factor of safety is added to the protection zone to form the drinking water protection area for the well.

The parameters used to calculate the shape of this protection zone are general for the whole alluvial plain and were obtained from various United States Geological Survey (USGS) reports, area well logs, and the Groundwater textbook by Freeze and Cherry (Freeze and Cherry, 1979).

The protection areas established for wells by the DEC are usually separated into two zones, limited by the watershed. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well. An analytical calculation was used to determine the size and shape of the protection area.

The time-of-travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the two protection area zones for wells and the calculated time-of-travel for each:

**Table 1. Definition of Zones**

Zone	Definition
A	Several months time-of-travel
B	Less than the 2 year time-of-travel

The drinking water protection area for Lost Lake Boy Scout Camp was determined using an analytical calculation and includes Zone A (see Map A in Appendix A).

**INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES**

DWP has completed an inventory of potential and existing sources of contamination within the Lost Lake Boy Scout Camp drinking water protection area. This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class B public water system assessments, the following three categories of drinking water contaminants were inventoried:

- Bacteria and viruses;
- Nitrates and/or nitrites;
- Volatile organic chemicals

The sources are displayed on Map C of Appendix C and summarized in Table 1 of Appendix B.

**RANKING OF CONTAMINANT RISKS**

Once the potential and existing sources of contamination have been identified, they are assigned a ranking according to what type and level of risk they represent. Ranking of contaminant risks for a “potential” or “existing” source of contamination is a function of toxicity and volumes of specific

contaminants associated with that source. Rankings include:

- Low;
- Medium;
- High; and
- Very High.

Tables 2 through 4 in Appendix B contain the ranking of potential and existing sources of contamination with respect to bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals.

**VULNERABILITY OF LOST LAKE BOY SCOUT CAMP DRINKING WATER SYSTEM**

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural Susceptibility; and
- Contaminant Risks.

A score for the Natural Susceptibility of the well is reached by considering the properties of the well and the aquifer.

$$\begin{aligned}
 & \text{Susceptibility of the Wellhead (0-25 Points)} \\
 & \quad + \\
 & \text{Susceptibility of the Aquifer (0-25 Points)} \\
 & \quad = \\
 & \text{Natural Susceptibility of the Well (0-50 Points)}
 \end{aligned}$$

A ranking is assigned for the Natural Susceptibility according to the point score:

Natural Susceptibility Ratings	
40-50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Factors contributing to the susceptibility of the wellhead are: whether the sanitary seal is in place, protection from flooding, and if the well casing is properly grouted.

The wellhead for the Lost Lake Boy Scout Camp received a **Low** susceptibility rating. The most recent sanitary survey (04/09/2005) indicates that a sanitary seal is installed on the well, the land surface is sloped away from the well, and the well is grouted according to DEC regulations. Sanitary seals prevent potential contaminants from entering the well, while sloping of the land surface away from the wellhead provides adequate surface water drainage, and concrete or grouting around the wellhead helps to prevent potential contaminants from traveling down the outside of the well casing.

Factors contributing to the susceptibility of the aquifer are: whether the aquifer is confined or unconfined, whether the well is completed in unconsolidated or fractured bedrock, whether wells and bore holes are penetrating the aquifer and, if applicable, the confining layer.

The Lost Lake Boy Scout Camp system draws water from an unconfined aquifer consisting of fractured bedrock. It received a **High** susceptibility rating because of its unconfined status. Because an unconfined aquifer is recharged by surface water and precipitation that migrates downward from the surface, it is susceptible to contamination from outside sources.

Table 2 summarizes the Susceptibility scores and ratings for the Lost Lake Boy Scout Camp system.

**Table 2. Susceptibility**

	<b>Score</b>	<b>Rating</b>
Susceptibility of the Wellhead	0	Low
Susceptibility of the Aquifer	17	High
Natural Susceptibility	17	Low

Contaminant risks are derived from an evaluation of the routine sampling results of the water system and the presence of potential sources of contamination. Contaminant risks to a drinking water source depend on the type and distribution of contaminant sources. Flow charts are used to assign a point score, and ratings are assigned in the same way as for the natural susceptibility:

<b>Contaminant Risk Ratings</b>	
40-50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants for the Lost Lake Boy Scout Camp system.

**Table 3. Contaminant Risks**

<b>Category</b>	<b>Score</b>	<b>Rating</b>
Bacteria and Viruses	12	Low
Nitrates and/or Nitrites	17	Low
Volatile Organic Chemicals	25	Medium

Finally, an overall vulnerability score is assigned for each water system by combining each of the contaminant risk scores with the natural susceptibility score:

$$\begin{aligned} &\text{Natural Susceptibility (0-50 Points)} \\ &+ \\ &\text{Contaminant Risks (0-50 Points)} \\ &= \end{aligned}$$

Vulnerability of the Drinking Water Source to Contamination (0-100 Points)

Again, rankings are assigned according to a point score:

<b>Overall Vulnerability Ratings</b>	
80-100 pts	Very High
60 to < 80 pts	High
40 to < 60 pts	Medium
< 40 pts	Low

Table 4 contains the overall vulnerability scores (0-100) and ratings for each of the three categories of drinking water contaminants for the Lost Lake Boy Scout Camp system. Note: scores are rounded off to the nearest five.

**Table 4. Overall Vulnerability**

<b>Category</b>	<b>Score</b>	<b>Rating</b>
Bacteria and Viruses	30	Low
Nitrates and/or Nitrites	35	Low
Volatile Organic Chemicals	40	Medium

**Bacteria and Viruses**

The contaminant risk for bacteria and viruses is **Low** with a septic system contributing to the risk to the drinking water well.

Coliforms (a bacteria) are found naturally in the environment and while not necessarily a direct health threat, they are an indicator of other potentially harmful bacteria in the water, more specifically fecal coliforms and E. coli. These bacteria only come from human and animal fecal waste and can cause diarrhea, cramps, nausea, headaches, and other symptoms (EPA, 2008).

Only a small number of bacteria and viruses are required to endanger public health. Bacteria and viruses have not been detected in the water within the last 5 years of sampling at Lost Lake Boy Scout Camp (data reviewed in April, 2008).

After combining the contaminant risk for bacteria and viruses with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Low**.

#### **Nitrates and Nitrites**

The contaminant risk for nitrates and nitrites is **Low** with a septic system contributing to the risk to the drinking water well.

The sampling history for Lost Lake Boy Scout Camp well indicates that nitrates have been detected in the water within the last 5 years of sampling, with the highest concentration of 0.883 mg/l detected on 06/09/2005 (data reviewed in April, 2008).

After combining the contaminant risk for nitrates and nitrites with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Low**.

#### **Volatile Organic Chemicals**

The contaminant risk for volatile organic chemicals is **Medium** with a septic system and a heating oil tank contributing to the risk to the drinking water well.

The drinking water at Lost Lake Boy Scout Camp has not recently been sampled for volatile organic chemicals (data reviewed in April, 2008).

After combining the contaminant risk for volatile organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

#### **Using the Source Water Assessment**

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Lost Lake Boy Scout Camp to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of Lost Lake Boy Scout Camp drinking water source.

## **REFERENCES**

Alaska Department of Commerce, Community and Economic Development (ADCCED), Accessed 2009 [WWW document]. URL: [http://www.commerce.state.ak.us/dca/commdb/CF\\_COMDB.htm](http://www.commerce.state.ak.us/dca/commdb/CF_COMDB.htm)

Freeze, R.A. and Cherry, J.A., 1979. Groundwater. Prentice-Hall, Englewood Cliffs, NJ.

United States Environmental Protection Agency (EPA), Accessed 2008 [WWW document]. URL: <http://www.epa.gov/safewater/contaminants/index.html>.



## **APPENDIX A**

### **Lost Lake Boy Scout Camp Drinking Water Protection Area Location Map (Map A)**

Public Water Well System for PWS #370277.002 Lost Lake Boy Scout Camp



Legend




- Class B Public Water System Well
- Groundwater Protection Zones**
- Zone A Protection Area - Several Months Travel Time
  - Zone B Protection Area - 2 Years Travel Time

Data Sources:  
Contaminant Sources, Public Water System Wells, Alaska Department of Environmental Conservation (ADEC)

All other data:  
United States Geological Survey (USGS)

Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class B Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.



Lost Lake Boy Scout Camp  
PWS 370277.002

Appendix A Map A

## **APPENDIX B**

### **Contaminant Source Inventory and Risk Ranking for Lost Lake Boy Scout Camp (Tables 1-4)**

*Table 1*

*Contaminant Source Inventory for  
LOST LAKE BOY SCOUT CAMP*

*PWSID 370277.002*

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Map Number</i>	<i>Comments</i>
Septic systems (serves one single-family home)	R02	R02	A	C	1 assumed septic system
Tanks, heating oil, residential (above ground)	R08	R08	A	C	1 assumed heating oil tank

**Table 2**

*Contaminant Source Inventory and Risk Ranking for  
LOST LAKE BOY SCOUT CAMP  
Sources of Bacteria and Viruses*

**PWSID 370277.002**

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Septic systems (serves one single-family home)	R02	R02	A	Low	C	1 assumed septic system

**Table 3**

*Contaminant Source Inventory and Risk Ranking for  
LOST LAKE BOY SCOUT CAMP  
Sources of Nitrates/Nitrites*

*PWSID 370277.002*

<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Septic systems (serves one single-family home)	R02	R02	A	Low	C	1 assumed septic system

**Table 4**

*Contaminant Source Inventory and Risk Ranking for  
LOST LAKE BOY SCOUT CAMP  
Sources of Volatile Organic Chemicals*

*PWSID 370277.002*


<i>Contaminant Source Type</i>	<i>Contaminant Source ID</i>	<i>CS ID tag</i>	<i>Zone</i>	<i>Risk Ranking for Analysis</i>	<i>Map Number</i>	<i>Comments</i>
Septic systems (serves one single-family home)	R02	R02	A	Low	C	1 assumed septic system
Tanks, heating oil, residential (above ground)	R08	R08	A	Medium	C	1 assumed heating oil tank

## **APPENDIX C**

### **Lost Lake Boy Scout Camp Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)**



**Public Water Well System for PWS # 370277.002 Lost Lake Boy Scout Camp  
Showing Potential and Existing Sources of Contamination**



**Legend**

- Class B Public Water System Well
- Groundwater Protection Zones**
- Zone A Protection Area - Several Months Travel Time
- Zone B Protection Area - 2 Years Travel Time

**Data Sources:**  
Contaminant Sources, Public Water System Wells, Alaska Department of Environmental Conservation (ADEC)

**All other data:**  
United States Geological Survey (USGS)

**Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class B Public Water Systems" published by ADEC**

**URS Corporation does not guarantee the accuracy or validity of the data provided.**

