

Source Water Assessment

A Hydrogeologic Susceptibility and Vulnerability Assessment for Skagway Border Station Public Drinking Water System, Skagway Area, Alaska PWSID # 111544.001

DRINKING WATER PROTECTION REPORT 1603

Alaska Department of Environmental Conservation

December, 2008

Source Water Assessment for Skagway Border Station Public Drinking Water System Skagway Area, Alaska PWSID# 111544.001

DRINKING WATER PROTECTION REPORT 1603

The Drinking Water Protection (DWP) section of the Drinking Water Program is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (DEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. It is anticipated this assessment will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of public drinking water source. If you have any additional information that may affect the results of this assessment, please contact the DWP staff at the following toll-free number 1-866-956-7656.

December, 2008

CONTENTS

Page

Executive Summary
Area
Inventory of Potential and Existing Contaminant Sources

Ranking of Contaminant Risks Vulnerability of Skagway Border Station Drinking	2
Water System	2
References	
Appendix A	7
Appendix B	9
Appendix C	

TABLES

Table 1.	Definition of Zones	.2
	Susceptibility	
Table 3.	Contaminant Risks	3
Table 4.	Overall Vulnerability	3

APPENDICES

APPENDIX

A. Skagway Border Station Drinking Water Protection Area (Map A)

- B. Contaminant Source Inventory for Skagway Border Station (Table 1) Contaminant Source Inventory and Risk Ranking for Skagway Border Station – Bacteria and Viruses (Table 2) Contaminant Source Inventory and Risk Ranking for Skagway Border Station – Nitrates/Nitrites (Table 3) Contaminant Source Inventory and Risk Ranking for Skagway Border Station – Volatile Organic Chemicals (Table 4)
- C. Skagway Border Station Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)

Source Water Assessment for Skagway Border Station Source of Public Drinking Water, Skagway Area, Alaska

Drinking Water Protection Alaska Department of Environmental Conservation

EXECUTIVE SUMMARY

The public water system for Skagway Border Station is a Class B (transient/non-community) water system consisting of one well located at Mile 6.8 of the Klondike Highway, north of Skagway, Alaska. The wellhead received a susceptibility rating of Low and the aquifer received a susceptibility rating of High. Combining these two ratings produces a Low rating for the natural susceptibility of the well. Identified potential and current sources of contaminants for Skagway Border Station public drinking water source include: a quarry, a road, a rail corridor, and a park. These identified potential and existing sources of contamination are considered as sources of bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals. Overall, the public water sources for Skagway Border Station received a vulnerability rating of High for bacteria and viruses, and Medium for nitrates and/or nitrites and volatile organic chemicals. This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Skagway Border Station to protect public health.

SKAGWAY BORDER STATION PUBLIC DRINKING WATER SYSTEM

The Skagway Border Station public water system is a Class B (transient/non-community) water system. The system consists of one well located at Mile 6.8 of the Klondike Highway, north of Skagway, Alaska (see Map A in Appendix A). Skagway is located at the head of Taiya Inlet, about 90 miles northeast of Juneau.

Within Skagway, water is drawn from three wells and piped throughout the town. Most homes are fully plumbed and sewage undergoes primary treatment before being pumped into the ocean. A few homes use wells and septic systems. Refuse is transported to the city incinerator and then to an ash fill facility. Power is provided throughout the community by Alaska Power and Telephone Company (ADCCED, 2008).

According to the sanitary survey (05/03/2004), the well extends approximately 480 feet below the ground surface and is completed in an unconfined aquifer. This system operates year-round and serves eight residents

and up to two hundred non-residents through one service connection.

SKAGWAY BORDER STATION DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. These areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the drinking water protection area. The drinking water protection area is the area circling the well (the area influenced by pumping) and also the area upgradient of the well, usually forming a parabola shape. Because releases of contaminants within the protection area are most likely to impact the well, this area will serve as the focus for voluntary protection efforts.

There are many different methods for calculating the size of protection areas. Drinking Water Protection (DWP) uses a combination of two simple groundwater flow equations, the Thiem and uniform flow equations for all groundwater wells screened in unconsolidated material. The orientation of the protection zone is then drawn using a water table elevation map (if available) or a land surface elevation map of the area. The protection zone calculated by DWP is an estimate using the available information and resources, and may differ slightly from the actual capture zone. Because of uncertainties and changing site conditions, a factor of safety is added to the protection zone to form the drinking water protection area for the well.

The parameters used to calculate the shape of this protection zone are general for the whole alluvial plain and were obtained from various United States Geological Survey (USGS) reports, area well logs, and the Groundwater textbook by Freeze and Cherry (Freeze and Cherry, 1979).

The protection areas established for wells by the DEC are usually separated into two zones, limited by the watershed. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well. An analytical calculation was used to determine the size and shape of the protection area.

The time-of-travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the two protection area zones for wells and the calculated time-of-travel for each:

Table 1. Definition of Zones

Zone	Definition
А	Several months time-of-travel
В	Less than the 2 year time-of-travel

The drinking water protection area for Skagway Border Station was determined using an analytical calculation and includes Zones A and B (See Map A of Appendix A).

INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES

DWP has completed an inventory of potential and existing sources of contamination within the Skagway Border Station drinking water protection area. This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class B public water system assessments, the following three categories of drinking water contaminants were inventoried:

- Bacteria and viruses;
- Nitrates and/or nitrites;
- Volatile organic chemicals

The sources are displayed on Map C of Appendix C and summarized in Table 1 of Appendix B.

RANKING OF CONTAMINANT RISKS

Once the potential and existing sources of contamination have been identified, they are assigned a ranking according to what type and level of risk they represent. Ranking of contaminant risks for a "potential" or "existing" source of contamination is a function of toxicity and volumes of specific contaminants associated with that source. Rankings include:

- Low;
- Medium;
- High; and
- Very High.

Tables 2 through 4 in Appendix B contain the ranking of potential and existing sources of contamination with respect to bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals.

VULNERABILITY OF SKAGWAY BORDER STATION DRINKING WATER SYSTEM

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural Susceptibility; and
- Contaminant Risks.

A score for the Natural Susceptibility of the well is reached by considering the properties of the well and the aquifer.

Natural Susceptibility of the Well (0-50 Points)

A ranking is assigned for the Natural Susceptibility according to the point score:

Natural Susceptil	oility Ratings
40-50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Factors contributing to the susceptibility of the wellhead are: whether the sanitary seal is in place, protection from flooding, and if the well casing is properly grouted.

The wellhead for the Skagway Border Station received a **Low** susceptibility rating. The sanitary survey for this system indicates that the well has a sanitary seal installed, the land surface is appropriately sloped away from the well, and the well is surrounded by a concrete pad according to DEC regulations. Sanitary seals prevent potential contaminants from entering the well, while sloping of the land surface away from the wellhead provides adequate surface water drainage, and concrete or grouting around the wellhead helps to prevent potential contaminants from traveling down the outside of the well casing. Factors contributing to the susceptibility of the aquifer are: whether the aquifer is confined or unconfined, whether the well is completed in unconsolidated or fractured bedrock, whether wells and bore holes are penetrating the aquifer and, if applicable, the confining layer.

The Skagway Border Station system draws water from an unconfined aquifer consisting of sand and gravel. The aquifer received a **High** susceptibility rating because of its shallow, unconfined nature. Because an unconfined aquifer is recharged by surface water and precipitation that migrates downward from the surface, it is susceptible to contamination from outside sources. Shallow aquifers therefore provide less protection than deeper ones.

Table 2 summarizes the Susceptibility scores and ratings for the Skagway Border Station system.

Table 2. Susceptibility

	Score	Rating
Susceptibility of the	0	Low
Wellhead		
Susceptibility of the	17	High
Aquifer		
Natural Susceptibility	17	Low

Contaminant risks are derived from an evaluation of the routine sampling results of the water system and the presence of potential sources of contamination. Contaminant risks to a drinking water source depend on the type and distribution of contaminant sources. Flow charts are used to assign a point score, and ratings are assigned in the same way as for the natural susceptibility:

Contaminant I	Risk Ratings
40-50 pts	Very High
30 to < 40 pts	High
20 to < 30 pts	Medium
< 20 pts	Low

Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants for the Skagway Border Station system.

Table 3. Contaminant Risks

Category	Score	Rating
Bacteria and Viruses	50	Very High
Nitrates and/or Nitrites	23	Medium
Volatile Organic Chemicals	25	Medium

Finally, an overall vulnerability score is assigned for each water system by combining each of the contaminant risk scores with the natural susceptibility score:

> Natural Susceptibility (0-50 Points) + Contaminant Risks (0-50 Points) =

Vulnerability of the Drinking Water Source to Contamination (0-100 Points)

• •	1.		• •	1.		•
Δαριη	rankinge	aro	accianad	according	to a	noint coora
Again.	Tankings	arc	assigned	according	iu a	point score:

Overall Vulnera	ability Ratings
80-100 pts	Very High
60 to < 80 pts	High
40 to < 60 pts	Medium
< 40 pts	Low

Table 4 contains the overall vulnerability scores (0-100) and ratings for each of the three categories of drinking water contaminants for the Skagway Border Station system. Note: scores are rounded off to the nearest five.

Table 4. Overall Vulnerability

Category	Score	Rating
Bacteria and Viruses	65	High
Nitrates and/or Nitrites	40	Medium
Volatile Organic Chemicals	40	Medium

Bacteria and Viruses

The contaminant risk for bacteria and viruses is **Very High** with risk resulting primarily from positive coliform sampling results. A road and a park further contribute to the risk to the drinking water well. Coliforms (a bacteria) are found naturally in the environment and although they aren't necessarily a health threat, they are an indicator of other potentially harmful bacteria in the water, more specifically, fecal coliforms and E. coli, which only come from human and animal fecal waste. Harmful bacteria can cause diarrhea, cramps, nausea, headaches, or other symptoms (EPA, 2008).

Only a small amount of bacteria and viruses are required to endanger public health. Positive samples increase the overall vulnerability of the drinking water source, indicating that the source is susceptible to bacteria and virus contamination. Bacteria and viruses have been detected during recent water sampling of the system at Skagway Border Station, with positive results detected on 09/25/2006 and 09/27/2006 (data reviewed in April, 2008).

After combining the contaminant risk for bacteria and viruses with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **High**.

Nitrates and Nitrites

The contaminant risk for nitrates and nitrites is **Medium** with a quarry, a road, and a park contributing to the risk to the drinking water well.

The sampling history for the Skagway Border Station well indicates that nitrates have been detected in the water within the last five years, with the highest concentration of 0.138 mg/l detected on 6/14/2006 (data reviewed in April, 2008).

After combining the contaminant risk for nitrates and nitrites with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

Volatile Organic Chemicals

The contaminant risk for volatile organic chemicals is **Medium** with a quarry, a road, and a rail corridor contributing to the risk to the drinking water well.

The drinking water at Skagway Border Station has not been recently sampled for volatile organic chemicals (data reviewed in April, 2008).

After combining the contaminant risk for volatile organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

Using the Source Water Assessment

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Skagway Border Station to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of Skagway Border Station drinking water source.

REFERENCES

Alaska Department of Community and Economic Development (ADCED), Accessed 2008 [WWW document]. URL: http://www.commerce.state.ak.us/dca/commdb/CF_COMDB.htm

Freeze, R.A. and Cherry, J.A., 1979. Groundwater. Prentice-Hall, Englewood Cliffs, NJ.

United States Environmental Protection Agency (EPA), Accessed 2008 [WWW document]. URL: http://www.epa.gov/safewater/contaminants/index.html.

APPENDIX A

Skagway Border Station Drinking Water Protection Area Location Map (Map A)



	<u>Legend</u>
11	Class B Public Water System Well
9	Groundwater Protection Zones
	Zone A Protection Area - Several Months Travel Time
	Zone B Protection Area - 2 Years Travel Time
	Data Sources: Contaminant Sources, Public Water System Wells, Alaska Department of Environmental Conservation (ADEC) All other data: Alaska Statewide Digital Mapping Initiative (SDMI) Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class B
5	Public Water Systems" published by ADEC
X	URS Corporation does not guarantee the accuracy or validity of the data provided.
とうためのです	Inset I Area of Map
	Skagway Border Station

Skagway Border Station PWS 111544.001 Appendix A Map A

APPENDIX B

Contaminant Source Inventory and Risk Ranking for Skagway Border Station (Tables 1-4)

Contaminant Source Inventory for Skagway Border Station

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Map Number	Comments
Quarries (sand, gravel, rock, other?)	E10	E10-01	А	С	
Highways and roads, paved (cement or asphalt)	X20	X20	А	С	1 road
Rail corridors	X30	X30	А	С	1 rail corridor
Municipal or city parks (with green areas)	X04	X04	В	С	Klondike Gold Rush National Historic Park
Highways and roads, paved (cement or asphalt)	X20	X20	В	С	1 road
Rail corridors	X30	X30	В	С	1 rail corridor

Table 2

Contaminant Source Inventory and Risk Ranking for

PWSID 111544.001

Skagway Border Station Sources of Bacteria and Viruses

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Risk Ranking for Analysis	Map Number	Comments
Highways and roads, paved (cement or asphalt)	X20	X20	А	Low	С	1 road
Municipal or city parks (with green areas)	X04	X04	В	Medium	С	Klondike Gold Rush National Historic Park
Highways and roads, paved (cement or asphalt)	X20	X20	В	Low	С	1 road

Table 3

Contaminant Source Inventory and Risk Ranking for

PWSID 111544.001

Skagway Border Station Sources of Nitrates/Nitrites

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Risk Ranking for Analysis	Map Number	Comments
Quarries (sand, gravel, rock, other?)	E10	E10-01	А	Low	С	
Highways and roads, paved (cement or asphalt)	X20	X20	А	Low	С	1 road
Municipal or city parks (with green areas)	X04	X04	В	Medium	С	Klondike Gold Rush National Historic Park
Highways and roads, paved (cement or asphalt)	X20	X20	В	Low	С	1 road

Table 4

Contaminant Source Inventory and Risk Ranking for


PWSID 111544.001


Skagway Border Station Sources of Volatile Organic Chemicals

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Risk Ranking for Analysis	Map Number	Comments
Quarries (sand, gravel, rock, other?)	E10	E10-01	А	Low	С	
Highways and roads, paved (cement or asphalt)	X20	X20	А	Low	С	1 road
Rail corridors	X30	X30	А	Medium	С	1 rail corridor
Highways and roads, paved (cement or asphalt)	X20	X20	В	Low	С	1 road
Rail corridors	X30	X30	В	Medium	С	1 rail corridor

APPENDIX C

Skagway Border Station Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)





Skagway Border Station PWS 111544.001 Appendix C Map C