



Source Water Assessment

A Hydrogeologic Susceptibility and
Vulnerability Assessment for
LKSD Paul Albert Memorial High School
Drinking Water System,
Tununak, Alaska

PWSID # 270613.001

April 2004

DRINKING WATER PROTECTION PROGRAM REPORT 1096
Alaska Department of Environmental Conservation

Source Water Assessment for
LKSD Paul Albert Memorial High School
Drinking Water System
Tununak, Alaska

PWSID # 270613.001

DRINKING WATER PROTECTION PROGRAM REPORT 1096

The Drinking Water Protection Program (DWPP) is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (ADEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. It is anticipated this assessment will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of public drinking water source. If you have any additional information that may affect the results of this assessment, please contact the Program Coordinator of DWPP, (907) 269-7521.

CONTENTS

| | | | |
|--------------------------------------|---|-------------------------------------|---|
| EXECUTIVE SUMMARY..... | 1 | INVENTORY OF POTENTIAL AND EXISTING | |
| PUBLIC DRINKING WATER SYSTEM | 1 | CONTAMINANT SOURCES | 2 |
| DRINKING WATER PROTECTION AREA | 2 | RANKING OF CONTAMINANT RISKS | 2 |
| | | VULNERABILITY OF DRINKING WATER | |
| | | SYSTEM | 3 |

TABLES

| | |
|-------------------------------------|---|
| Table 1. Definition of Zones..... | 2 |
| Table 2. Susceptibility | 3 |
| Table 3. Contaminant Risks..... | 4 |
| Table 4. Overall Vulnerability..... | 4 |

APPENDICES

| | |
|----------|---|
| APPENDIX | A. LKSD Paul Albert Memorial High School Drinking Water Protection Area (Map A) |
| | B. Contaminant Source Inventory for LKSD Paul Albert Memorial High School (Table 1) Contaminant Source Inventory and Risk Ranking for LKSD Paul Albert Memorial High School – Bacteria and Viruses (Table 2) Contaminant Source Inventory and Risk Ranking for LKSD Paul Albert Memorial High School – Nitrates/Nitrites (Table 3) Contaminant Source Inventory and Risk Ranking for LKSD Paul Albert Memorial High School – Volatile Organic Chemicals (Table 4) Contaminant Source Inventory and Risk Ranking for LKSD Paul Albert Memorial High School – Heavy Metals, Cyanide and Other Inorganic Chemicals (Table 5) Contaminant Source Inventory and Risk Ranking for LKSD Paul Albert Memorial High School – Synthetic Organic Chemicals (Table 6) Contaminant Source Inventory and Risk Ranking for LKSD Paul Albert Memorial High School – Other Organic Chemicals (Table 7) |
| | C. LKSD Paul Albert Memorial High School Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C) |
| | D. Vulnerability Analysis for Contaminant Source Inventory and Risk Ranking for LKSD Paul Albert Memorial High School Public Drinking Water Source (Charts 1 – 14) |

Source Water Assessment for LKSD Paul Albert Memorial High School Source of Public Drinking Water, Tununak, Alaska

Drinking Water Protection Program Alaska Department of Environmental Conservation

EXECUTIVE SUMMARY

The LKSD Paul Albert Memorial High School has one Public Water System (PWS) well. The well (PWS No. 270613.001) has been used as a drinking water source since it was drilled in 1964.

The well is a Class A (community and non-transient non-community) water system located approximately 0.125 miles east of Tununak Bay in Tununak, Alaska. Available records do not indicate if there is secondary storage of drinking water; however, do indicate that that untreated drinking water source is derived directly from the wellhead. This system operates year round and serves approximately 103 residents. The wellhead received a susceptibility rating of **Very High** and the aquifer received a susceptibility rating of **High**. Combining these two ratings produce a **Very High** rating for the natural susceptibility of the well.

Identified potential and current sources of contaminants for the public drinking water source include: a large capacity septic system, aboveground fuel tanks, petroleum product bulk station/terminals, roads, pipelines, electric power generation, and quarries. These identified potential and existing sources of contamination are considered as sources of bacteria and viruses, nitrates and/or nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals contaminant categories.

Overall, the water well received a vulnerability rating of **Very High** for the bacteria and viruses, nitrates and nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, and other organic chemicals, and a vulnerability rating of **Medium** for synthetic organic chemicals.

PUBLIC DRINKING WATER SYSTEM

The LKSD Paul Albert Memorial High School well is a Class A (community/non-transient/non-community) public water system. The system is located approximately 0.125 miles east of Tununak

Bay in Tununak, Alaska (Sec. 28, T6N, R91W, Seward Meridian; see Map A of Appendix A). Tununak is located in a small bay on the northeast coast of Nelson Island. The community is located 115 miles northwest of Bethel and 519 miles northwest of Anchorage. Tununak has a population of 304 (ADCED, 2003). Average annual precipitation in Tununak is 17 inches, including approximately 28 inches of snowfall. Temperatures range from 42 to 59°F in summer and 2 to 19°F in winter. Temperatures can be as extreme as -35 to 80°F.

The community of Tununak obtains most of their water supply from Muskox Creek. A few households are served by a flush/haul sewage system, but most households utilize honey bucket hoppers (ADCED, 2003). Tununak receives electrical power from AVEC, a REA Cooperative. Power generating facilities are fueled by diesel. Refuse is collected by the Traditional Council and transported to the landfill (ADCED, 2003).

According to information supplied by ADEC for the LKSD Paul Albert Memorial High School PWS, the depth of the primary water well is 38 feet below the ground surface and is screened in an unconfined aquifer based on available construction details. The well is located within a floodplain.

A sanitary survey for the public water system was not available through ADEC; therefore it is unknown if the land surface was sloped away from the well. Generally, land surfaces that slope away from the wellhead promote surface water drainage, which reduces the potential of contaminant migration down the well casing annulus. It is also unknown if the well is grouted according to ADEC regulations. Proper grouting provides added protection against contaminants traveling along the well casing annulus and into source waters.

Tununak is sited on a narrow spit of land extending southwest across the south of the Tununak River, which separates the Tununak River from the Bering Sea. The spit, which is approximately 4,000-geet in length, rises about 10 feet above the beach line and is

approximately 400 feet wide at the widest point. The village lies near the northwest end of the spit, where it is jointed to its headland, the lower slope of Ugchiranak Mountain. The spit that Tununak is sited on is a beach deposit formed by action of long shore currents moving from the northeast. The beach is made up of sands and gravels; and no permafrost has been encountered in the beach deposits. The slope of Ugchiranak Mountain is mantled by frozen, ice-rich silts overlying silty sands (R&M Consultants, Inc., 1979).

DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. These areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the area that contributes water to the well, the groundwater recharge area. This area is designated as the drinking water protection area (DWPA). Because releases of contaminants within the protection area are most likely to impact the drinking water well, this area will serve as the focus for voluntary protection efforts. An analytical calculation was used to determine the size and shape of the DWPA for the LKSD Paul Albert Memorial High School PWS. The input parameters describing the attributes of the aquifer in this calculation were adopted from Groundwater (Freeze and Cherry, 1979). Available geology and groundwater contours were also considered to take into account any uncertainties in groundwater flow and aquifer characteristics to arrive at a meaningful protection area.

The protection areas established for wells by the ADEC are usually separated into four zones, limited by the watershed. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well (Please refer to the Guidance Manual for Class A Public Water Systems for additional information).

The time of travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the four protection area zones for wells and the calculated time -of-travel for each:

Table 1. Definition of Zones

| Zone | Definiti on |
|-------------|--|
| A | ¼ the distance for the 2-yr. time -of-travel |
| B | Less than the 2 year time-of-travel |
| C | Less Than the 5 year time -of-travel |
| D | Less than the 10 year time -of-travel |

The DWPA for the LKSD Paul Albert Memorial High School PWS was determined using an analytical calculation and includes Zones A, B, C, and D (See Map A of Appendix A).

INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES

The Drinking Water Protection Program has completed an inventory of potential and existing sources of contamination within the LKSD Paul Albert Memorial High School DWPA. This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class A public water system assessments, six categories of drinking water contaminants were inventoried. They include:

- Bacteria and viruses,
- Nitrates and/or nitrites,
- Volatile organic chemicals,
- Heavy metals, cyanide and other inorganic chemicals,
- Synthetic organic chemicals,
- Other organic chemicals.

The sources are displayed on Map C of Appendix C and summarized in Table 1 of Appendix B.

RANKING OF CONTAMINANT RISKS

Once the potential and existing sources of contamination have been identified, they are assigned a ranking according to what type and level of risk they represent. Ranking of contaminant risks for a “potential” or “existing” source of contamination is a function of toxicity and volumes of specific contaminants associated with that source. Rankings include:

- Low,
- Medium,
- High, and
- Very High.

The time-of-travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. Bacteria and Viruses are only inventoried in Zones A and B because of their short life span. Only “Very High” and “High” rankings are inventoried within the outer Zone D due to the probability of contaminant dilution by the time the contaminants get to the well. Tables 2 through 4 in Appendix B contain the ranking of potential and existing sources of contamination with respect to bacteria and viruses, nitrates and/or nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals.

VULNERABILITY OF THE DRINKING WATER SYSTEM

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural susceptibility, and
- Contaminant risks.

Appendix D contains fourteen charts, which together form the ‘Vulnerability Analysis’ for a source water assessment for a public drinking water source. Chart 1 analyzes the ‘Susceptibility of the Wellhead’ to contamination by looking at the construction of the well and its surrounding area. Chart 2 analyzes the ‘Susceptibility of the Aquifer’ to contamination by looking at the naturally occurring attributes of the water source and influences on the groundwater system that might lead to contamination. Chart 3 analyzes ‘Contaminant Risks’ for the drinking water source with respect to bacteria and viruses. The ‘Contaminant Risks’ portion of the analysis considers potential sources of contaminants as well as a review of contamination that has or may have occurred, but has not arrived or been detected at the well. Chart 4 contains the ‘Vulnerability Analysis for Bacteria and Viruses’. Charts 5 through 14 contain the Contaminant Risks and Vulnerability Analyses for nitrates and nitrites, volatile organic chemicals, heavy metals, cyanide and other inorganic chemicals, synthetic organic chemicals, and other organic chemicals, respectively.

A score for the Natural Susceptibility is reached by considering the properties of the well and the aquifer.

Susceptibility of the Wellhead (0 – 25 Points)
(Chart 1 of Appendix D)

+

Susceptibility of the Aquifer (0 – 25 Points)
(Chart 2 of Appendix D)

=

Natural Susceptibility (Susceptibility of the Well)
(0 – 50 Points)

A ranking is assigned for the Natural Susceptibility according to the point score:

| Natural Susceptibility Ratings | |
|--------------------------------|-----------|
| 40 to 50 pts | Very High |
| 30 to < 40 pts | High |
| 20 to < 30 pts | Medium |
| < 20 pts | Low |

The LKSD Paul Albert Memorial High School’s water well is in an unconfined aquifer. Unconfined aquifers are more susceptible to potential groundwater quality impacts posed by the migration of surface water contaminants downward from the surface. Table 2 shows the susceptibility scores and ratings for this PWS.

Table 2. Susceptibility

| | Score | Rating |
|--------------------------------|-------|-----------|
| Susceptibility of the Wellhead | 25 | Very High |
| Susceptibility of the Aquifer | 18 | High |
| Natural Susceptibility | 43 | Very High |

Contaminant risks to a drinking water source depend on the type, number or density, and distribution of contaminant sources. This score has been derived from an examination of existing and historical contamination that has been detected at the drinking water source through routine sampling. It also evaluates potential sources of contamination. Flow charts are used to assign a point score, and ratings are assigned in the same way as for the natural susceptibility:

| Contaminant Risk Ratings | |
|--------------------------|-----------|
| 40 to 50 pts | Very High |
| 30 to < 40 pts | High |
| 20 to < 30 pts | Medium |
| < 20 pts | Low |

Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants.

Table 3. Contaminant Risks

| Category | Score | Rating |
|---|-------|-----------|
| Bacteria and Viruses | 40 | Very High |
| Nitrates and/or Nitrites | 44 | Very High |
| Volatile Organic Chemicals | 50 | Very High |
| Heavy Metals, Cyanide and Other Inorganic Chemicals | 50 | Very High |
| Synthetic Organic Chemicals | 12 | Low |
| Other Organic Chemicals | 50 | Very High |

Finally, an overall vulnerability score is assigned for each water system by combining each of the contaminant risk scores with the natural susceptibility score:

$$\begin{aligned}
 &\text{Natural Susceptibility (0 – 50 points)} \\
 &\quad + \\
 &\text{Contaminant Risks (0 – 50 points)} \\
 &\quad = \\
 &\text{Vulnerability of the} \\
 &\text{Drinking Water Source to Contamination (0 – 100).}
 \end{aligned}$$

Again, rankings are assigned according to a point score:

| Overall Vulnerability Ratings | |
|-------------------------------|-----------|
| 80 to 100 pts | Very High |
| 60 to < 80 pts | High |
| 40 to < 60 pts | Medium |
| < 40 pts | Low |

Table 4 contains the overall vulnerability scores (0 – 100) and ratings for each of the six categories of drinking water contaminants. Note: scores are rounded off to the nearest five.

Table 4. Overall Vulnerability

| Category | Score | Rating |
|---|-------|-----------|
| Bacteria and Viruses | 85 | Very High |
| Nitrates and Nitrites | 90 | Very High |
| Volatile Organic Chemicals | 95 | Very High |
| Heavy Metals, Cyanide and Other Inorganic Chemicals | 95 | Very High |
| Synthetic Organic Chemicals | 55 | Medium |
| Other Organic Chemicals | 95 | Very High |

Bacteria and Viruses

The contaminant risk for bacteria and viruses is **Very High**. The risk is primarily attributed to the presence of a large capacity septic system in Zone A (see Table 2 – Appendix B).

No positive bacteria counts have been reported in recent (within five years) sampling events (See Chart 3 – Contaminant Risks for Bacteria and Viruses in Appendix D). Only a small amount of bacteria and viruses are required to endanger public health.

After combining the contaminant risk for bacteria and viruses with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Very High**.

Nitrates and Nitrites

The contaminant risk for nitrates and nitrites is **Very High**. The risk to this source of public drinking water is primarily attributed to the presence of a large capacity septic system in Zone A (see Table 3 – Appendix B).

Nitrates are very mobile, moving at approximately the same rate as water. The sampling history for this well indicates that low levels of nitrates have been detected in recent sampling events. However, the reported concentrations of nitrates do not exceed the maximum contaminant level (MCL) of 10 mg/L. Nitrate concentrations in uncontaminated groundwater are typically less than 2 mg/L; therefore, nitrate concentrations above 2 mg/L may be indicative of man-made sources (See Chart 5 - Contaminant Risks for Nitrates and/or Nitrites in Appendix D).

Nitrate levels are often derived from the decomposition of organic matter in soils. Although the nitrate source is unknown, such occurrences may be attributed to septic systems or other sources. After combining the contaminant risk for nitrates and nitrites with the natural susceptibility of the well, the overall vulnerability of the well to nitrate and nitrite contamination is **Very High**.

Volatile Organic Chemicals

The contaminant risk for volatile organic chemicals is **Very High**. The risk is primarily attributed to the presence of petroleum product bulk station/terminals located in Zone A. Numerous other potential contaminant sources are also found within the protection area (see Table 4 – Appendix B).

All recent sampling data for VOCs were below detection levels for LKSD Paul Albert Memorial High School (See Chart 7 – Contaminant Risks for Volatile Organic Chemicals in Appendix D).

After combining the contaminant risk for volatile organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Very High**.

Heavy Metals, Cyanide and Other Inorganic Chemicals

The contaminant risk for heavy metals, cyanide and other inorganic chemicals is **Very High**. The risk is primarily attributed to the presence of electric power generation in Zone A. Numerous other potential contaminant sources are also found within the protection area (see Table 5 – Appendix B).

Based on review of recent sampling records for this public water system, high levels of copper have been detected. The analyte exceeded the MCL of 1.3 mg/L (See Chart 9 – Contaminant Risks for Heavy Metals, Cyanide and Other Inorganic Chemicals in Appendix D).

After combining the contaminant risk for heavy metals, cyanide and other inorganic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Very High**.

Synthetic Organic Chemicals

The contaminant risk for synthetic organic chemicals is **Low**. The risk is primarily attributed to the lack of contaminant sources present in Zone A (see Table 6 – Appendix B).

No recent sampling data was available in ADEC records for the LKSD Paul Albert Memorial High School (See Chart 11 – Contaminant Risks for Synthetic Organic Chemicals in Appendix D).

After combining the contaminant risk for synthetic organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Medium**.

Other Organic Chemicals

The contaminant risk for other organic chemicals is **Very High**. The risk is primarily attributed to the presence of petroleum product bulk station/terminals, a pipeline, and electric power generation located in Zone A. Numerous other potential contaminant sources are also found within the protection area (see Table 7 – Appendix B).

No recent sampling data was available in ADEC records for the LKSD Paul Albert Memorial High School (See Chart 13 – Contaminant Risks for Other Organic Chemicals in Appendix D).

After combining the contaminant risk for other organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Very High**.

Using the Source Water Assessment

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of the LKSD Paul Albert Memorial High School and the community of Tununak to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of the drinking water source.


REFERENCES

- Alaska Department of Community and Economic Development (ADCED), 2003 [WWW document]. URL: http://www.dced.state.ak.us/cbd/commdb/CF_COMDB.htm
- Alaska Department of Environmental Conservation, Contaminated Sites Database, 2003 [WWW database], URL http://www.state.ak.us/dec/dspar/csites/cs_search.htm
- Alaska Department of Environmental Conservation, Leaking Underground Storage Tank Database, 2003 [WWW database], URL http://www.dec.state.ak.us/spar/stp/ust/search/fac_search.asp
- Freeze, R. A., and Cherry, J.A. 1979, Groundwater, Prentice-Hall, Englewood Cliffs, New Jersey
- R&M Consultants, Inc. 1979, Lower Kuskokwim School District, School Site Investigation for Tununak, Alaska.
- United States Environmental Protection Agency (EPA), 2002 [WWW document]. URL <http://www.epa.gov/safewater/mcl.html>.

APPENDIX A

Drinking Water Protection Area Location Map (Map A)

Public Water Well System for PWS #270613.001 LKSD Tununak Paul Albert High School



LEGEND

- Public Water System Well

Hydrography/Physical

- Parcels
- Stream
- Lake or Pond
- Contours

Transportation

- Primary Route (Class 1)
- Secondary Route (Class 2)
- Road (Class 3)
- Road (Class 4)
- Road (Class 5, Four-wheel drive)

Groundwater Protection Zones

- Zone A Protection Area- Several Months Travel Time
- Zone B Protection Area- 2 Years Travel Time
- Zone C Protection Area- 5 Years Travel Time
- Zone D Protection Area- 10 Years Travel Time




Data Sources:
 Contaminant Sources, Public Water System Wells, Contours
 Alaska Department of Environmental Conservation (ADEC)

Critical Facilities, Federal Emergency Management Agency (FEMA)

All other data:
 United States Geological Survey (USGS)

Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class A Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.



LKSD Tununak Paul Albert High School
 PWS 270613.001
 Appendix A Map A

APPENDIX B

Contaminant Source Inventory and Risk Ranking (Tables 1-7)

Table 1**Contaminant Source Inventory for
LKSD Tununak Paul Albert HS****PWSID 270613.001**

| Contaminant Source Type | Contaminant Source ID | CS ID tag | Zone | Map Number | Comments |
|---|------------------------------|------------------|-------------|-------------------|-----------------------------|
| Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method) | D10 | D10-01 | A | C | Community drainfield |
| Tanks, diesel (above ground) | T06 | T06-01 | A | C | Generator |
| Tanks, diesel (above ground) | T06 | T06-02 | A | C | Old BIA School Generator |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-01 | A | C | AVEC |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-02 | A | C | Teachers Housing |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-03 | A | C | Teachers Housing 2 |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-04 | A | C | Teachers Housing 3 |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-05 | A | C | School |
| Petroleum product bulk station/terminals | X11 | X11-01 | A | C | AVEC |
| Petroleum product bulk station/terminals | X11 | X11-02 | A | C | Gas Station |
| Petroleum product bulk station/terminals | X11 | X11-03 | A | C | Old BIA School |
| Petroleum product bulk station/terminals | X11 | X11-04 | A | C | LKSD |
| Highways and roads, dirt/gravel | X24 | X24-01 | A | C | Assume 1-20 roads in Zone A |
| Pipelines (oil and gas) | X28 | X28-01 | A | C | |
| Electric power generation (fossil fuels) | X36 | X36-01 | A | C | AVEC |
| Quarries (sand, gravel, rock, other?) | E10 | E10-01 | B | C | Nelson Island |

*Contaminant Source Inventory and Risk Ranking for
LKSD Tununak Paul Albert HS
Sources of Bacteria and Viruses*

PWSID 270613.001

Table 2

| <i>Contaminant Source Type</i> | <i>Contaminant Source ID</i> | <i>CS ID tag</i> | <i>Zone</i> | <i>Risk Ranking for Analysis</i> | <i>Map Number</i> | <i>Comments</i> |
|---|------------------------------|------------------|-------------|----------------------------------|-------------------|-----------------------------|
| Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method) | D10 | D10-01 | A | High | C | Community drainfield |
| Highways and roads, dirt/gravel | X24 | X24-01 | A | Low | C | Assume 1-20 roads in Zone A |

*Contaminant Source Inventory and Risk Ranking for
LKSD Tununak Paul Albert HS
Sources of Nitrates/Nitrites*

PWSID 270613.001

Table 3

| <i>Contaminant Source Type</i> | <i>Contaminant Source ID</i> | <i>CS ID tag</i> | <i>Zone</i> | <i>Risk Ranking for Analysis</i> | <i>Map Number</i> | <i>Comments</i> |
|---|------------------------------|------------------|-------------|----------------------------------|-------------------|-----------------------------|
| Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method) | D10 | D10-01 | A | High | C | Community drainfield |
| Highways and roads, dirt/gravel | X24 | X24-01 | A | Low | C | Assume 1-20 roads in Zone A |
| Quarries (sand, gravel, rock, other?) | E10 | E10-01 | B | Low | C | Nelson Island |

Table 4

*Contaminant Source Inventory and Risk Ranking for
LKSD Tununak Paul Albert HS
Sources of Volatile Organic Chemicals*

PWSID 270613.001

| <i>Contaminant Source Type</i> | <i>Contaminant Source ID</i> | <i>CS ID tag</i> | <i>Zone</i> | <i>Risk Ranking for Analysis</i> | <i>Map Number</i> | <i>Comments</i> |
|---|------------------------------|------------------|-------------|----------------------------------|-------------------|-----------------------------|
| Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method) | D10 | D10-01 | A | Low | C | Community drainfield |
| Tanks, diesel (above ground) | T06 | T06-01 | A | Medium | C | Generator |
| Tanks, diesel (above ground) | T06 | T06-02 | A | Medium | C | Old BIA School Generator |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-01 | A | Low | C | AVEC |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-02 | A | Low | C | Teachers Housing |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-03 | A | Low | C | Teachers Housing 2 |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-04 | A | Low | C | Teachers Housing 3 |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-05 | A | Low | C | School |
| Petroleum product bulk station/terminals | X11 | X11-01 | A | Very High | C | AVEC |
| Petroleum product bulk station/terminals | X11 | X11-02 | A | Very High | C | Gas Station |
| Petroleum product bulk station/terminals | X11 | X11-03 | A | Very High | C | Old BIA School |
| Petroleum product bulk station/terminals | X11 | X11-04 | A | Very High | C | LKSD |
| Highways and roads, dirt/gravel | X24 | X24-01 | A | Low | C | Assume 1-20 roads in Zone A |
| Pipelines (oil and gas) | X28 | X28-01 | A | Medium | C | |
| Electric power generation (fossil fuels) | X36 | X36-01 | A | Medium | C | AVEC |
| Quarries (sand, gravel, rock, other?) | E10 | E10-01 | B | Low | C | Nelson Island |

*Contaminant Source Inventory and Risk Ranking for
LKSD Tununak Paul Albert HS*

PWSID 270613.001

Table 5

Sources of Heavy Metals, Cyanide and Other Inorganic Chemicals

| <i>Contaminant Source Type</i> | <i>Contaminant Source ID</i> | <i>CS ID tag</i> | <i>Zone</i> | <i>Risk Ranking for Analysis</i> | <i>Map Number</i> | <i>Comments</i> |
|---|------------------------------|------------------|-------------|----------------------------------|-------------------|-----------------------------|
| Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method) | D10 | D10-01 | A | Low | C | Community drainfield |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-01 | A | Low | C | AVEC |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-02 | A | Low | C | Teachers Housing |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-03 | A | Low | C | Teachers Housing 2 |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-04 | A | Low | C | Teachers Housing 3 |
| Tanks, heating oil, nonresidential (aboveground) | T14 | T14-05 | A | Low | C | School |
| Petroleum product bulk station/terminals | X11 | X11-01 | A | Low | C | AVEC |
| Petroleum product bulk station/terminals | X11 | X11-02 | A | Low | C | Gas Station |
| Petroleum product bulk station/terminals | X11 | X11-03 | A | Low | C | Old BIA School |
| Petroleum product bulk station/terminals | X11 | X11-04 | A | Low | C | LKSD |
| Highways and roads, dirt/gravel | X24 | X24-01 | A | Low | C | Assume 1-20 roads in Zone A |
| Pipelines (oil and gas) | X28 | X28-01 | A | Low | C | |
| Electric power generation (fossil fuels) | X36 | X36-01 | A | Medium | C | AVEC |

*Contaminant Source Inventory and Risk Ranking for
LKSD Tununak Paul Albert HS
Sources of Synthetic Organic Chemicals*

PWSID 270613.001

Table 6

| <i>Contaminant Source Type</i> | <i>Contaminant Source ID</i> | <i>CS ID tag</i> | <i>Zone</i> | <i>Risk Ranking for Analysis</i> | <i>Map Number</i> | <i>Comments</i> |
|---|------------------------------|------------------|-------------|----------------------------------|-------------------|----------------------|
| Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method) | D10 | D10-01 | A | Low | C | Community drainfield |
| Petroleum product bulk station/terminals | X11 | X11-01 | A | Low | C | AVEC |
| Petroleum product bulk station/terminals | X11 | X11-02 | A | Low | C | Gas Station |
| Petroleum product bulk station/terminals | X11 | X11-03 | A | Low | C | Old BIA School |
| Petroleum product bulk station/terminals | X11 | X11-04 | A | Low | C | LKSD |

*Contaminant Source Inventory and Risk Ranking for
LKSD Tununak Paul Albert HS
Sources of Other Organic Chemicals*

PWSID 270613.001


Table 7

| <i>Contaminant Source Type</i> | <i>Contaminant Source ID</i> | <i>CS ID tag</i> | <i>Zone</i> | <i>Risk Ranking for Analysis</i> | <i>Map Number</i> | <i>Comments</i> |
|---|------------------------------|------------------|-------------|----------------------------------|-------------------|-----------------------------|
| Injection wells (Class V) Large-Capacity Septic System (Drainfield Disposal Method) | D10 | D10-01 | A | Low | C | Community drainfield |
| Petroleum product bulk station/terminals | X11 | X11-01 | A | High | C | AVEC |
| Petroleum product bulk station/terminals | X11 | X11-02 | A | High | C | Gas Station |
| Petroleum product bulk station/terminals | X11 | X11-03 | A | High | C | Old BIA School |
| Petroleum product bulk station/terminals | X11 | X11-04 | A | High | C | LKSD |
| Highways and roads, dirt/gravel | X24 | X24-01 | A | Low | C | Assume 1-20 roads in Zone A |
| Pipelines (oil and gas) | X28 | X28-01 | A | High | C | |
| Electric power generation (fossil fuels) | X36 | X36-01 | A | High | C | AVEC |
| Quarries (sand, gravel, rock, other?) | E10 | E10-01 | B | Low | C | Nelson Island |

APPENDIX C

Drinking Water Protection Area and Potential and Existing Contaminant Sources (Map C)

**Public Water Well System for PWS #270613.001 LKSD Tununak Paul Albert High School
Showing Potential and Existing Sources of Contamination**



LEGEND

- Public Water System Well

Hydrography/Physical

- Parcels
- Stream
- Lake or Pond
- Contours

Transportation

- Primary Route (Class 1)
- Secondary Route (Class 2)
- Road (Class 3)
- Road (Class 4)
- Road (Class 5, Four-wheel drive)

Groundwater Protection Zones

- Zone A Protection Area- Several Months Travel Time
- Zone B Protection Area- 2 Years Travel Time
- Zone C Protection Area- 5 Years Travel Time
- Zone D Protection Area- 10 Years Travel Time


Existing or Potential Contaminant Sources

- Quarry (E10)
- Aboveground diesel tank (T06)
- Nonresidential aboveground heating oil tank (T14)
- Petroleum product bulk station/terminal (X11)
- Electric power generation (fossil fuels) (X36)

Data Sources:
 Contaminant Sources, Public Water System Wells, Contours
 Alaska Department of Environmental Conservation (ADEC)
 Critical Facilities, Federal Emergency Management Agency (FEMA)

All other data:
 United States Geological Survey (USGS)
 Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class A Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.



LKSD Tununak Paul Albert High School
PWS 270613.001
Appendix C Map C

APPENDIX D

Vulnerability Analysis for Public Drinking Water Source (Charts 1-14)

Chart 1. Susceptibility of the wellhead - LKSD Tununak Paul Albert High School (PWS No. 270613.001)




Chart 2. Susceptibility of the aquifer LKSD Tununak Paul Albert High School (PWS No. 270613.001)




Chart 3. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Bacteria & Viruses




Chart 3. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Bacteria & Viruses




Chart 4. Vulnerability analysis for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Bacteria & Viruses




Chart 5. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Nitrates and Nitrites




Chart 5. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Nitrates and Nitrites




Chart 5. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Nitrates and Nitrites




Chart 6. Vulnerability analysis for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Nitrates and Nitrites




Chart 7. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Volatile Organic Chemicals




Chart 7. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Volatile Organic Chemicals





Chart 7. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Volatile Organic Chemicals




Chart 8. Vulnerability analysis for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Volatile Organic Chemicals




Chart 9. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals




Chart 9. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals




Chart 9. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals




Chart 10. Vulnerability analysis for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Heavy Metals, Cyanide and Other Inorganic Chemicals




Chart 11. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Synthetic Organic Chemicals




Chart 11. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Synthetic Organic Chemicals




Chart 11. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Synthetic Organic Chemicals




Chart 12. Vulnerability analysis for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Synthetic Organic Chemicals




Chart 13. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Other Organic Chemicals




Chart 13. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Other Organic Chemicals






Chart 13. Contaminant risks for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Other Organic Chemicals




Chart 14. Vulnerability analysis for LKSD Tununak Paul Albert High School (PWS No. 270613.001) - Other Organic Chemicals

