

## **Source Water Assessment**

A Hydrogeologic Susceptibility and Vulnerability Assessment for Alaska Trails R.V. Park Public Drinking Water System, Wasilla Area, Alaska PWSID # 220160.001

DRINKING WATER PROTECTION REPORT 1646

Alaska Department of Environmental Conservation

December, 2008

# Source Water Assessment for Alaska Trails R.V. Park Public Drinking Water System, Wasilla Area, Alaska PWSID# 220160.001

### DRINKING WATER PROTECTION REPORT 1646

The Drinking Water Protection (DWP) section of the Drinking Water Program is producing Source Water Assessments in compliance with the Safe Drinking Water Act Amendments of 1996. Each assessment includes a delineation of the source water area, an inventory of potential and existing contaminant sources that may impact the water, a risk ranking for each of these contaminants, and an evaluation of the potential vulnerability of these drinking water sources.

These assessments are intended to provide public water systems owners/operators, communities, and local governments with the best available information that may be used to protect the quality of their drinking water. The assessments combine information obtained from various sources, including the U.S. Environmental Protection Agency, Alaska Department of Environmental Conservation (DEC), public water system owners/operators, and other public information sources. The results of this assessment are subject to change if additional data becomes available. It is anticipated this assessment will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of public drinking water source. If you have any additional information that may affect the results of this assessment, please contact the DWP staff at the following number: 1-866-956-7656.

## **CONTENTS**

		Page		Page
Executive Sum	mary.	1	Ranking of Contaminant Risks	2
Alaska Trails R	.V. Pa	ark Public Drinking Water System	Vulnerability of Alaska Trails R.V. Park Drinking	
		1	Water System	2
Alaska Trails R	References	5		
Area	Appendix A	7		
Inventory of Po	tentia	l and Existing Contaminant	Appendix B	9
•		2	Appendix C	11
		TAB	ELES	
Table 1. Defin	ition	of Zones		2
Table 2. Susce	eptibil	ity		3
Table 3. Conta	amina	nt Risks		3
Table 4. Overa	all Vu	Inerability		3
		APPEN	DICES	
APPENDIX	A.	Alaska Trails R.V. Park Drinking W	ater Protection Area (Map A)	
	В.	Contaminant Source Inventory for A	alaska Trails R.V. Park (Table 1)	
		Contaminant Source Inventory and Viruses (Table 2)	Risk Ranking for Alaska Trails R.V. Park – Bacteria	and
		Contaminant Source Inventory and Nitrates/Nitrites (Table 3)	Risk Ranking for Alaska Trails R.V. Park –	
		,	Risk Ranking for Alaska Trails R.V. Park – Volatile	
	C.	Alaska Trails R.V. Park Drinking W Contaminant Sources (Map C)	Vater Protection Area and Potential and Existing	

# Source Water Assessment for Alaska Trails R.V. Park Source of Public Drinking Water, Wasilla Area, Alaska

## **Drinking Water Protection Alaska Department of Environmental Conservation**

### **EXECUTIVE SUMMARY**

The public water system for Alaska Trails R.V. Park is a Class B (transient/non-community) water system consisting of one well on the Parks Highway near Wasilla, Alaska. The wellhead received a susceptibility rating of **Low** and the aquifer received a susceptibility rating of Low. Combining these two ratings produces a **Low** rating for the natural susceptibility of the well. Identified potential and current sources of contaminants for Alaska Trails R.V. Park public drinking water source include: assumed septic systems, assumed heating oil tanks, roads, and a rail corridor. These identified potential and existing sources of contamination are considered as sources of bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals. Overall, the public water sources for Alaska Trails R.V. Park received a vulnerability rating of Low for all three contaminant categories. This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Alaska Trails R.V. Park to protect public health.

## ALASKA TRAILS R.V. PARK PUBLIC DRINKING WATER SYSTEM

Alaska Trails R.V. Park public water system is a Class B (transient/non-community) water system. The system consists of one well located 5 road miles west of Wasilla, Alaska at Mile 48 of the Parks Highway (see Map A in Appendix A). Another well exists on the property, but is not connected to this system. Wasilla has a population of 7,028 and lies about 12 miles north of the Knik Arm of Cook Inlet along the George Parks Highway (ADCED, 2008).

The majority of residents in the Wasilla area have individual wells and septic systems, but the city does operate a water and sewer system. Homes are heated by piped natural gas, provided by Enstar. Refuse is transported by a private firm to the Borough landfill (ADCED, 2008).

Due to the glacial influence in the formation of the Wasilla area, the landforms in Wasilla are made up of ridges of glacial till and flat benches of gravel and sand out wash (Matanuska-Susitna Borough, 1985). The altitude of the Wasilla area ranges from about 300 feet

to 500 feet above sea level, gradually sloping downwards towards Cook Inlet. There are hundreds of small lakes in the area, several larger lakes, and two large streams (Renshaw Consulting Engineers, 1983).

According to the sanitary survey (2/19/2007), the well extends approximately 120 feet below the ground surface and is completed in a confined aquifer. This system operates from April to September and serves up to 393 non-residents through 5 service connections.

## ALASKA TRAILS R.V. PARK DRINKING WATER PROTECTION AREA

In order to evaluate whether a drinking water source is at risk, we must first evaluate what are the most likely pathways for surface contamination to reach the groundwater. These areas are determined by looking at the characteristics of the soil, groundwater, aquifer, and well.

The most probable area for contamination to reach the drinking water well is the drinking water protection area. The drinking water protection area is the area circling the well (the area influenced by pumping) and also the area upgradient of the well, usually forming a parabola shape. Because releases of contaminants within the protection area are most likely to impact the well, this area will serve as the focus for voluntary protection efforts.

There are many different methods for calculating the size of protection areas. Drinking Water Protection (DWP) uses a combination of two simple groundwater flow equations, the Thiem and uniform flow equations for all groundwater wells screened in unconsolidated material. The orientation of the protection zone is then drawn using a water table elevation map (if available) or a land surface elevation map of the area. The protection zone calculated by DWP is an estimate using the available information and resources, and may differ slightly from the actual capture zone. Because of uncertainties and changing site conditions, a factor of safety is added to the protection zone to form the drinking water protection area for the well.

The parameters used to calculate the shape of this protection zone are general for the whole alluvial plain and were obtained from various United States Geological Survey (USGS) reports, area well logs, and

the Groundwater textbook by Freeze and Cherry (Freeze and Cherry, 1979).

The protection areas established for wells by the DEC are usually separated into two zones, limited by the watershed. These zones correspond to differences in the time-of-travel (TOT) of the water moving through the aquifer to the well. An analytical calculation was used to determine the size and shape of the protection area. The input parameters describing the attributes of the aquifer in this calculation were adopted from the State of Alaska Department of Water Resources (Jokela et. al., 1991).

The time-of-travel for contaminants within the water varies and is dependent on the physical and chemical characteristics of each contaminant. The following is a summary of the two protection area zones for wells and the calculated time-of-travel for each:

Table 1. Definition of Zones

Zone	Definition
A	Several months time-of-travel
В	Less than the 2 year time-of-travel

The drinking water protection area for Alaska Trails R.V. Park was determined using an analytical calculation and includes Zones A and B (see Map A of Appendix A).

## INVENTORY OF POTENTIAL AND EXISTING CONTAMINANT SOURCES

DWP has completed an inventory of potential and existing sources of contamination within the Alaska Trails R.V. Park drinking water protection area. This inventory was completed through a search of agency records and other publicly available information. Potential sources of contamination to the drinking water aquifer include a wide range of categories and types. Potential drinking water contaminants are found within agricultural, residential, commercial, and industrial areas, but can also occur within areas that have little or no development.

For the basis of all Class B public water system assessments, the following three categories of drinking water contaminants were inventoried:

- Bacteria and viruses:
- Nitrates and/or nitrites;
- Volatile organic chemicals

The sources are displayed on Map C of Appendix C and summarized in Table 1 of Appendix B.

### RANKING OF CONTAMINANT RISKS

Once the potential and existing sources of contamination have been identified, they are assigned a ranking according to what type and level of risk they represent. Ranking of contaminant risks for a "potential" or "existing" source of contamination is a function of toxicity and volumes of specific contaminants associated with that source. Rankings include:

- Low:
- Medium:
- High; and
- Very High.

Tables 2 through 4 in Appendix B contain the ranking of potential and existing sources of contamination with respect to bacteria and viruses, nitrates and/or nitrites, and volatile organic chemicals.

## VULNERABILITY OF ALASKA TRAILS R.V. PARK DRINKING WATER SYSTEM

Vulnerability of a drinking water source to contamination is a combination of two factors:

- Natural Susceptibility; and
- Contaminant Risks.

A score for the Natural Susceptibility of the well is reached by considering the properties of the well and the aquifer.

Susceptibility of the Wellhead (0-25 Points)

+
Susceptibility of the Aquifer (0-25 Points)

-

Natural Susceptibility of the Well (0-50 Points)

A ranking is assigned for the Natural Susceptibility according to the point score:

Natural Susceptibility Ratings							
40-50 pts	Very High						
30 to < 40 pts	High						
20 to < 30 pts	Medium						
< 20 pts	Low						

Factors contributing to the susceptibility of the wellhead are: whether the sanitary seal is in place, protection from flooding, and if the well casing is properly grouted.

The wellhead for the Alaska Trails R.V. Park received a **Low** susceptibility rating. The most recent sanitary survey (02/19/07) indicates the well is capped with a sanitary seal and the land surface is sloped away from

the well. Other documentation states the well is properly grouted. Sanitary seals prevent potential contaminants from entering the well, while sloping of the land surface away from the wellhead provides adequate surface water drainage, and concrete or grouting around the wellhead helps to prevent potential contaminants from traveling down the outside of the well casing.

Factors contributing to the susceptibility of the aquifer are: whether the aquifer is confined or unconfined, whether the well is completed in unconsolidated or fractured bedrock, whether wells and bore holes are penetrating the aquifer and, if applicable, the confining layer.

The Alaska Trails R.V. Park draw3s water from a confined aquifer overlain by a thick layer of clay. It received a **Low** susceptibility rating because of its deep, confined nature. Deep aquifers protect against surface contaminant migration while confining layers provide protection from any contamination that does manage to penetrate to that depth.

Table 2 summarizes the Susceptibility scores and ratings for the Alaska Trails R.V. Park system.

Table 2. Susceptibility

Score	Rating
0	Low
9	Low
9	Low
	0

Contaminant risks are derived from an evaluation of the routine sampling results of the water system and the presence of potential sources of contamination.

Contaminant risks to a drinking water source depend on the type and distribution of contaminant sources. Flow charts are used to assign a point score, and ratings are assigned in the same way as for the natural susceptibility:

Contaminant Risk Ratings								
40-50 pts	Very High							
30 to < 40 pts	High							
20 to < 30 pts	Medium							
< 20 pts	Low							

Table 3 summarizes the Contaminant Risks for each category of drinking water contaminants for the Alaska Trails R.V. Park system.

**Table 3. Contaminant Risks** 

Category	Score	Rating
Bacteria and Viruses	12	Low
Nitrates and/or Nitrites	12	Low
Volatile Organic Chemicals	30	High

Finally, an overall vulnerability score is assigned for each water system by combining each of the contaminant risk scores with the natural susceptibility score:

Natural Susceptibility (0-50 Points)

+
Contaminant Risks (0-50 Points)

Vulnerability of the Drinking Water Source to Contamination (0-100 Points)

Again, rankings are assigned according to a point score:

Overall Vulnerability Ratings								
80-100 pts	Very High							
60 to < 80 pts	High							
40 to < 60 pts	Medium							
< 40 pts	Low							

Table 4 contains the overall vulnerability scores (0-100) and ratings for each of the three categories of drinking water contaminants for the Alaska Trails R.V. Park system. Note: scores are rounded off to the nearest five

**Table 4. Overall Vulnerability** 

Category	Score	Rating
Bacteria and Viruses	20	Low
Nitrates and/or Nitrites	20	Low
Volatile Organic Chemicals	35	Low

### **Bacteria and Viruses**

The contaminant risk for bacteria and viruses is **Low** with the septic systems and roads contributing to the risk to the drinking water well.

Coliforms (a bacteria) are found naturally in the environment and although they aren't necessarily a health threat, they are an indicator of other potentially harmful bacteria in the water, more specifically, fecal coliforms and E. coli, which only come from human

and animal fecal waste. Harmful bacteria can cause diarrhea, cramps, nausea, headaches, or other symptoms (EPA, 2008).

Only a small amount of bacteria and viruses are required to endanger public health. Positive samples increase the overall vulnerability of the drinking water source, indicating that the source is susceptible to bacteria and virus contamination. Bacteria and viruses have not been detected during recent water sampling at Alaska Trails R.V. Park (data reviewed in April, 2008).

After combining the contaminant risk for bacteria and viruses with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Low**.

### **Nitrates and Nitrites**

The contaminant risk for nitrates and nitrites is **Low** with the septic systems and roads contributing to the risk to the drinking water well.

The sampling history for Alaska Trails R.V. Park indicates that nitrates have not been detected in the water (data reviewed in April, 2008).

After combining the contaminant risk for nitrates and nitrites with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Low**.

### **Volatile Organic Chemicals**

The contaminant risk for volatile organic chemicals is **High** with the septic systems, heating oil tanks, roads, and rail corridor contributing to the risk to the drinking water well.

The drinking water at Alaska Trails R.V. Park has not recently been sampled for volatile organic chemicals (data reviewed in April, 2008).

After combining the contaminant risk for volatile organic chemicals with the natural susceptibility of the well, the overall vulnerability of the well to contamination is **Low**.

### Using the Source Water Assessment

This assessment of contaminant risks can be used as a foundation for local voluntary protection efforts as well as a basis for the continuous efforts on the part of Alaska Trails R.V. Park to protect public health. It is anticipated that Source Water Assessments will be updated every five years to reflect any changes in the vulnerability and/or susceptibility of Alaska Trails R.V. Park drinking water source.

### **REFERENCES**

- Alaska Department of Community and Economic Development (ADCED), Accessed 2008 [WWW document]. URL: http://www.commerce.state.ak.us/dca/commdb/CF\_COMDB.htm
- Freeze, R.A. and Cherry, J.A., 1979. Groundwater. Prentice-Hall, Englewood Cliffs, NJ.
- Jokela, J.B., Munter, J.A., and Evans, J.G., 1991, Ground-water resources of the Palmer-Big Lake area, Alaska: a conceptual model. Division of Geological &Geophysical Surveys Reports of Investigations 90-4, State of Alaska Department of Natural Resources, Fairbanks, AK.
- Matanuska-Susitna Borough, 1985, Knik-Matanuska-Susitna: A Visual History of the Valleys, Wasilla, AK.
- Renshaw Consulting Engineers, 1983, Summary of Mineral Resources, Palmer, AK.
- United States Environmental Protection Agency (EPA), Accessed 2008 [WWW document]. URL: http://www.epa.gov/safewater/contaminants/index.html.

## **APPENDIX A**

Alaska Trails R.V. Park
Drinking Water Protection Area Location Map
(Map A)

## Public Water Well System for PWS #220160.001 Alaskan Trails RV Park



## Legend

Class B Public Water System Well

**Groundwater Protection Zones** 



Zone A Protection Area - Several Months Travel Time



Zone B Protection Area - 2 Years Travel Time


### Data Sources:

Contaminant Sources, Public Water System Wells, Alaska Department of Environmental Conservation (ADEC)

All other data: Alaska Statewide Digital Mapping Initiative (SDMI)

Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class B Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.







Miles 0.5 1

Alaskan Trails RV Park PWS 220160.001

Appendix A Map A

## **APPENDIX B**

Contaminant Source Inventory and Risk Ranking for Alaska Trails R.V. Park (Tables 1-4)

### Table 1

## Contaminant Source Inventory for ALASKAN TRAILS RV PARK

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Map Number	Comments
Septic systems (serves one single-family home)	R02	R02	A	С	4 assumed septic systems
Tanks, heating oil, residential (above ground)	R08	R08	A	C	4 assumed heating oil tanks
Highways and roads, paved (cement or asphalt)	X20	X20	A	С	1 road
Septic systems (serves one single-family home)	R02	R02	В	С	6 assumed septic systems
Tanks, heating oil, residential (above ground)	R08	R08	В	С	6 assumed heating oil tanks
Highways and roads, paved (cement or asphalt)	X20	X20	В	С	2 roads
Rail corridors	X30	X30	В	С	

## Contaminant Source Inventory and Risk Ranking for ALASKAN TRAILS RV PARK

### PWSID 220160.001

## Sources of Bacteria and Viruses

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Risk Ranking for Analysis	Map Number	Comments
Septic systems (serves one single-family home)	R02	R02	A	Low	C	4 assumed septic systems
Highways and roads, paved (cement or asphalt)	X20	X20	A	Low	C	1 road
Septic systems (serves one single-family home)	R02	R02	В	Low	C	6 assumed septic systems
Highways and roads, paved (cement or asphalt)	X20	X20	В	Low	C	2 roads

## Contaminant Source Inventory and Risk Ranking for ALASKAN TRAILS RV PARK

### PWSID 220160.001

## Sources of Nitrates/Nitrites

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Risk Ranking for Analysis	Map Number	Comments
Septic systems (serves one single-family home)	R02	R02	A	Low	C	4 assumed septic systems
Highways and roads, paved (cement or asphalt)	X20	X20	A	Low	C	1 road
Septic systems (serves one single-family home)	R02	R02	В	Low	C	6 assumed septic systems
Highways and roads, paved (cement or asphalt)	X20	X20	В	Low	С	2 roads

### Table 4

## Contaminant Source Inventory and Risk Ranking for ALASKAN TRAILS RV PARK


## Sources of Volatile Organic Chemicals

Contaminant Source Type	Contaminant Source ID	CS ID tag	Zone	Risk Ranking for Analysis	Map Number	Comments
Septic systems (serves one single-family home)	R02	R02	A	Low	С	4 assumed septic systems
Tanks, heating oil, residential (above ground)	R08	R08	A	Medium	C	4 assumed heating oil tanks
Highways and roads, paved (cement or asphalt)	X20	X20	A	Low	C	1 road
Septic systems (serves one single-family home)	R02	R02	В	Low	C	6 assumed septic systems
Tanks, heating oil, residential (above ground)	R08	R08	В	Medium	C	6 assumed heating oil tanks
Highways and roads, paved (cement or asphalt)	X20	X20	В	Low	C	2 roads
Rail corridors	X30	X30	В	Medium	C	

## **APPENDIX C**

Alaska Trails R.V. Park
Drinking Water Protection Area
and Potential and Existing Contaminant Sources
(Map C)

## Public Water Well System for PWS #220160.001 Alaskan Trails RV Park Showing Potential and Existing Sources of Contamination



## **Legend**

- Class A Public Water System
- Class B Public Water System

### **Groundwater Protection Zones**

Zone A Pi

Zone A Protection Area - Several Months Travel Time



Zone B Protection Area - 2 Years Travel Time

### **Data Sources:**


Contaminant Sources, Public Water System Wells, Alaska Department of Environmental Conservation (ADEC)

### All other data:

Alaska Statewide Digital Mapping Initiative (SDMI)

Drinking Water Protection Areas based on "Alaska Drinking Water Protection Program - Guidance Manual for Class B Public Water Systems" published by ADEC

URS Corporation does not guarantee the accuracy or validity of the data provided.







1,000 2,000 4,000

Alaskan Trails RV Park PWS 220160.001

Appendix C Map C