

Site No. 19030004

UNDEVELOPED HYDROELECTRIC SITE

State Alaska County _____ Site Dot Lake SiteLocation T.22N, R.7E Copper R Meridian Stream _____

Planned by (date) _____

Reference Corps - Negative Feasibility Report Date June 25, 1984

Quadrangle coverage _____

Land: Public _____ Private _____ Use: P, I, FC, MI, R

Dam: Height <u>15 ft.</u> Length _____	Undeveloped capacity _____
Normal pool altitude _____	Percent efficiency _____
Reservoir area _____	Annual generation _____
Storage capacity _____	Plant factor _____
Drainage area _____	Mean flow _____
Gross head _____	Period of record _____

Remarks: Hydropower development was rejected because only one side of the proposed site was high enough to support a 15-foot dam. Site was underlain with deep alluvial material was very remote, and would serve an area of small population.

Prepared by BKJ Date 2/85