

Site No. 19030005

UNDEVELOPED HYDROELECTRIC SITE

State Alaska County _____ Site Anaktuvuk Pass
 Location T.15N., R.2E Sec. 29 Div., 19 P.H. Stream Inukpasugruk Creek
 Planned by (date) North Slope Borough
 Reference Corps Negative Feasibility Report Date Dec. 7, 1984
 Quadrangle coverage _____
 Land: Public _____ Private _____ Use: P, I, FC, MI, R

Dam: Height <u>22 feet</u> Length _____	Undeveloped capacity <u>200 KW</u>
Normal pool altitude _____	Percent efficiency _____
Reservoir area _____	Annual generation _____
Storage capacity _____	Plant factor _____
Drainage area _____	Mean flow _____
Gross head _____	Period of record _____

Remarks: 3,250 ft. steel penstock.
benefit-cost ratio of 0.3 to 1

Prepared by RKJ Date 3/85