

Site No. 19030006

UNDEVELOPED HYDROELECTRIC SITE

State Alaska County _____ Site Scammon Bay Site
 Location _____ Stream Unnamed Stream near Scammon Bay
 Planned by (date) Alaska District Corps of Engineers
 Reference Small Hydro. Study and Environment Assessment of Scammon Bay Date Nov. 1981
ER 81/2598
 Quadrangle coverage _____
 Land: Public _____ Private _____ Use: P, I, FC, MI, R

Dam: Height _____ Length <u>50 FT.</u>	Undeveloped capacity <u>100 KW</u>
Normal pool altitude _____	Percent efficiency _____
Reservoir area _____	Annual generation <u>432,000 KWh</u>
Storage capacity <u>1/10 Acre Feet</u>	Plant factor _____
Drainage area <u>3/4 Sq. Mile</u>	Mean flow <u>10 CFS Max</u>
Gross head <u>485 Feet</u>	Period of record _____

Remarks: 3500 FT. of 12 inch buried steel penstockPrepared by RKS Date 1/82