

Site No. 19050002

UNDEVELOPED HYDROELECTRIC SITE

State Alaska County _____ Site Whittier SiteLocation T.8N., R.3E Sec. 7 Seward Meridian Stream Placer River

Planned by (date) _____

Reference Corps - Negative Feasibility Study Date June 25, 1984

Quadrangle coverage _____

Land: Public _____ Private _____ Use: P, I, FC, MI, R

Dam: Height _____ Length _____	Undeveloped capacity _____
Normal pool altitude _____	Percent efficiency _____
Reservoir area _____	Annual generation <u>4,410 mwh</u>
Storage capacity _____	Plant factor _____
Drainage area _____	Mean flow _____
Gross head _____	Period of record _____

Remarks: High construction cost of the Transmission line is the primary reason for economic infeasibility.
 Benefit-to-Cost ratio is 0.21 to 1.0
 An 11 mile Transmission Line.

Prepared by RKS Date 2/85