

Omit from inventory - flow too small.

Site No. 19050002-53 TK  
479

### UNDEVELOPED HYDROELECTRIC SITE

State ALASKA County \_\_\_\_\_ Site RABBIT Creek Diversion

Location Section 6, T11N R 2W Seward Meridian Stream Rabbit Creek

Planned by (date) \_\_\_\_\_

Reference Review of Water Power Withdrawals PSR 674, PSC 107 & PSC 398" F.H. Johnson Date February 1959

Quadrangle coverage Anchorage (A-8) Alaska

Land: Public \_\_\_\_\_ Private \_\_\_\_\_ Use: P, I, FC, MI, R

Dam: Height <u>Diversion</u> Length _____	Undeveloped capacity <u>0.918 mwa @ Q<sub>50</sub> (Theoretical)</u>
Normal pool altitude <u>1500 feet</u>	Percent efficiency _____
Reservoir area <u>-0-</u>	Annual generation _____
Storage capacity <u>-0-</u>	Plant factor _____
Drainage area <u>9.0 square miles</u>	Mean flow <u>Q<sub>50</sub> = 7.2 cfs Q<sub>90</sub> = 2.4 cfs</u>
Gross head <u>1500' - 0 = 1500', ~ 5.75-mile diversion</u>	Period of record <u>1948-1953</u>

Remarks: PSR 674, 1/23/18  
PSC 107, 9/12/25

Prepared by TK Date 8/78