

Omit from inventory - flow too small

Site No. 19050002-55 TK  
1/79

### UNDEVELOPED HYDROELECTRIC SITE

State Alaska County \_\_\_\_\_ Site North Fork Diversion

Location Section 4, T12N, R2W Seward Meridian Stream No FK Campbell Creek

Planned by (date) \_\_\_\_\_

Reference Review of Waterpower Withdrawals PSR 674, PSC 107 & PSC 399, FA Johnson Date Feb. 1959

Quadrangle coverage Anchorage (A-8) Alaska

Land: Public \_\_\_\_\_ Private \_\_\_\_\_ Use: P, I, FC, MI, R

Dam: Height <u>Diversion</u> Length _____	Undeveloped capacity <u>0.578 mw at Q<sub>50</sub> Theoretical</u>
Normal pool altitude <u>1500 feet</u>	Percent efficiency _____
Reservoir area <u>0-</u>	Annual generation _____
Storage capacity <u>0-</u>	Plant factor _____
Drainage area <u>7.5 square miles</u>	Mean flow <u>Q<sub>50</sub> = 6.8 cfs, Q<sub>20</sub> = 2.3 cfs</u>
Gross head <u>1500' - 500' = 1000', 1.9 mile diversion</u>	Period of record <u>1948 - 1953 ?</u>

Remarks: PSR 674, 1/23/18  
PSC 107, 6/12/25

Prepared by TK Date 8/78  
SPo 11/78