

Site No. 19050003

UNDEVELOPED HYDROELECTRIC SITE

State Alaska County _____ Site Kenney Lake
 Location _____ Stream Unnamed Trib. of Tomsina R.
 Planned by (date) Copper Valley Electric Association
 Reference Corps Negative Feasibility Report Date Sept. 27, 1984
 Quadrangle coverage _____
 Land: Public _____ Private _____ Use: P, I, FC, MI, R

Dam: Height <u>13 Feet</u> Length _____	Undeveloped capacity <u>1,500 KW</u>
Normal pool altitude _____	Percent efficiency _____
Reservoir area _____	Annual generation <u>4.7 m kwh</u>
Storage capacity _____	Plant factor _____
Drainage area _____	Mean flow _____
Gross head _____	Period of record _____

Remarks: Benefit - Cost ratio of 0.7 to 1.0
Valdez C-3

Prepared by RKS Date 2/85